

VEGAPULS 60

Revision	Description	Available since
2.01	First sales version including: - Profibus-PA communication - PLICSCOM languages french and spanish - PLICSCOM function "PIN" - PLICSCOM function "Copy sensor data"	06/2003
3.01	New functions: - FF communication - PLICSCOM language russian - Device trend recording	09/2003
3.07	Error correction FF communication.	10/2003
3.11	First sales version VEGAPULS 68 HART. Version for VEGAPULS 68 only.	04/2004
3.22	New function: - PLICSCOM language Italian Error correction FF communication.	07/2004
3.24	First version VEGAPULS 68 Profibus PA and Foundation Fieldbus. Version for VEGAPULS 68 only.	09/2004
3.25	Enhancement in application parameter functionality. Error correction FF communication. Version for VEGAPULS 68 only.	10/2004
3.30	Common: - linearization possible with sensors according to WHG - error correction PLICSCOM: - additional language Chinese and Japanese - PLICSCOM with back light - adjustment of maximum current possible - SIL setting possible - change of name: "false echo memory" to "false signal suppression" HART sensors: - current output allows values between 3.8mA and 20.5mA (reset value 4mA to 20mA) - failure mode according to SIL allows 22mA and <3.6mA (reset value <3.6mA) FF sensors: - change in "block execution time" - error correction - introduction device rev. 3	01/2006
3.32	Error correction Chinese and Japanese menu	02/2006

VEGAPULS 60

Revision	Description	Available since
3.50	PLICSCOM: - additional language Dutch - error correction PA Sensors: - error correction	02/2007
3.80	Common: - SIL certification as order option PLICSCOM: - error correction HART sensors: - default value of the current output set to 3.8 ... 20.5 mA FF sensors: - fixed function bocks. No more dynamic instances - device revision 4 (requires new DD- and CFF-file in the DCS system) - error correction	10/2008
3.90	Support for software update with electronic index PS60HK.-07, PS60HC.-06 and PS60HS.-07 or higher	08/2015