

VEGAFLEX 80 four-wire Modbus

Version, available since	Description	Device Rev.
<p>1.3.0 12/2016</p>	<p>Function extensions</p> <p>New functions and modifications:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – Bulk solids applications <ul style="list-style-type: none"> – Standard deactivation of the automatic false signal suppression – Standard deactivation of the measurement via probe end with Medium/Dielectric constant "Granules, powder, cement/1.5 ... 3" and "Dusts, powder, wood chips/ < 1.5" – Sensitivity increased at 5 mV with Medium/Dielectric constant "Granulates, powder, cement/1.5 ... 3" in the close range – Optimizations for applications with short measuring ranges/probes ≤ 0.4 m <ul style="list-style-type: none"> – New option "False signal suppression with uncovered probe" – Optimization of the measuring cycle time – Reduction of the track number – Optimization of the overflow recognition so that overfillings above the sensor reference point are apparent – To avoid errors during the setup of an interface application, the possibility of a common adjustment or scaling was removed – Instrument function in general: <ul style="list-style-type: none"> – Optimization of the start behaviour PLICSCOM: During the sensor start and with operating sensor, the sensor TAG and the version information are no longer displayed on PLICSCOM. Due to this, the measured value is displayed approx. 10 s earlier. The version information is available in the menu item "Info" – The current output is set by default to "Fix current(4 mA)" if HART address ≠ 0 is selected – Adaptation of the adjustment structure to the standardized VEGA adjustment structure – variable positions after the decimal point for the display value <p>Error corrections:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – For level applications in which the dielectric constant cannot be determined and the HART diagnosis displays an err, this diagnosis can be deactivated via special parameter 23. Then the set dielectric constant is outputted – Instrument software, in general: <ul style="list-style-type: none"> – When reset "Delivery status" is executed, the "Echo curve of the setup" was not deleted – With instruments with customer-specific instrument setting it sometimes happened that after a reset "Delivery status" the parameters depending on the application setting were not disintegrated correctly and remained in a status as after a reset "Basic adjustment" – When using the PLICSCOM function "Copy instrument settings", the 	<p>3</p>

Version, available since	Description	Device Rev.
	<ul style="list-style-type: none"> special parameters 37 and 38 were not copied – The selection of the time format 24/12 hours was not translated correctly in the Spanish language – Wrong presentation of the sensor name in Russian language – The first operation of the instrument via PLICSCOM caused the entry "Plicscom_VU8.FirstContactEnable" in the parameter modification memory – Deactivation of the echo curve memory with a terminal voltage < 12 V, for a higher stability with lower supply voltage – EMC optimization of the communication to PLICSCOM – Error message F261/4004 is set during the sensor start when min. and max. adjustment are identical 	
<p>1.2.1 11/2015</p>	<p>Error corrections:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – For the application "Interface without gas phase (vessel and bypass/standpipe)", a device offset was not taken into account which caused a wrong measured value while correcting through the dielectric constant. – Linearization level measurement: When using the following linearizations: <ul style="list-style-type: none"> – Cylindrical tank – Spherical tank – Venturi, trapezoidal weir, rectangular weir – Palmer-Bowlus-Flume – V-Notch – User-programmable <p>In combination with an adjustment from the basic settings, a measured value deviation of the linearized percentage value is caused after a restart. Due to this, there is a wrong current if the linearized percentage value was assigned to the current output as output variable.</p> – Linearization interface: When using the following linearizations: <ul style="list-style-type: none"> – Cylindrical tank – Spherical tank – Venturi, trapezoidal weir, rectangular weir – Palmer-Bowlus-Flume – V-Notch – User-programmable <p>In combination with two separate adjustments for level and interface, the linearized level value of the instrument is wrong after a restart, the lin. interface value is correct. During operation, always the output value is wrong which was not modified.</p> – Instrument software, in general: <ul style="list-style-type: none"> – Error corrected when loading a corrupt delivery status – HART communication: <ul style="list-style-type: none"> – While enquiring unsupported Device Variables via HART Command 9, the sensor answered with error status "Invalid Selection" instead delivering the special value "Not-A-Number". – While reading out the dynamic variables via HART Command 9, the 	<p>2</p>

Version, available since	Description	Device Rev.
	<p>delivered codes of the measured values do not correspond to the dynamic variables but to the Device Variables</p>	
<p>1.2.0, 04/2015</p>	<p>Function extensions</p> <p>New functions and modifications:</p> <ul style="list-style-type: none"> - Measurement function: <ul style="list-style-type: none"> - Optimization of the interface measurement <ul style="list-style-type: none"> - Easier adaptation to the application - Selection of the next, larger or last echo as interface - Unit change of the reliability from % to unit mV - Introduction of new probe types: <ul style="list-style-type: none"> - 4 mm cable probe - Coax probe 21 x 6 mm for 250 °C applications - Assistant to determine the dielectric value in bulk solids applications with dust/powder/wood chips - Detection threshold for bypass/standpipe applications increased - Treatment of the freely suspended gravity weight echo <ul style="list-style-type: none"> - Sensor outputs probe length and not gravity weight begin - Optimization of high temperature probes with reference <ul style="list-style-type: none"> - Temperature offset reference to product cannot be configured <p>- Instrument software, in general:</p> <ul style="list-style-type: none"> - Introduction of the sensor unit "inch" <p>- PLICSCOM operation:</p> <ul style="list-style-type: none"> - Adaptation of the adjustment structure to the standardized VEGA adjustment structure - Additional menu languages: Turkish, Czech and Polish - Lighting on as default setting - Enquiry of the language setting when switching on the sensor for the first time <p>- HART communication:</p> <ul style="list-style-type: none"> - Optimization of the transmission times (e.g. of echo curves) - Introduction of additional Common Practice Commands <ul style="list-style-type: none"> - CMD 34 Write Primary Variable Damping Value - CMD 35 Write Primary Variable Range Values - CMD43 Set Primary Variable Zero - CMD44 Write Primary Variable Units - Introduction Burst Mode acc. to HART 5 <p>Error corrections:</p> <ul style="list-style-type: none"> - Measurement function: <ul style="list-style-type: none"> - Regulation device offset in case of moisture optimized on the coupling or deactivated in case of couplings with PEEK material - Basic setting "Demonstration" adapted for tests and presentations <ul style="list-style-type: none"> - Open focussing range - Reduced noise suppression - Focussing range interface on the probe end completely open backwards - Calculation of the reference line adapted - Threshold detection probe end with high temperature probes with 	<p>2</p>

Version, available since	Description	Device Rev.
	<p>reference reduced</p> <ul style="list-style-type: none"> – Instrument software, in general: <ul style="list-style-type: none"> – Error while storing switching off times removed – PLICSCOM adjustment: <p>Various fault rectifications:</p>	
<p>1.1.5, 09/2014</p>	<p>Error corrections:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – Error in the compensation of the spreading speed (concerns only instruments with reference distance). The error caused a considerable measurement error as well as an appropriate diagnosis message. – Parameters which only depend on the probe length and probe type do not block the application. Hence these are newly written with a restart of the instrument when dissolving the probe dependence. A manual parameter adjustment will get lost. – PLICSCOM adjustment: <ul style="list-style-type: none"> – In the quick setup assistant, the dielectric figure was enquired with level applications 	<p>1</p>
<p>1.1.3, 04/2014</p>	<p>Error corrections:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – Optimization of the signal processing with: <ul style="list-style-type: none"> – Level measurement statically and dynamically <ul style="list-style-type: none"> – Adaptation of the detection thresholds for different probes and applications, for example interface – Process SIL and non-SIL measurement function standardized – Improvement of the measurement accuracy of negative echoes – Function first large echo with interface can be activated – Determination of the dielectric figure value also possible without movement – Safeties on the probe end with high temperature probes with reference optimized – Reduction of the threshold for the cancellation of the limited decision range – Automatic probe length determination <ul style="list-style-type: none"> – Improved accuracy – Probe length determination with positive probe end – Fault signal echo loss was not effective with probe end tracking – Sensor does not indicate empty with empty vessel and active probe end measurement – Ceramic spacers with high temperature coax probes caused a slope error and the accuracy was not maintained, spacers are now compensated 	<p>1</p>

Version, available since	Description	Device Rev.
	<ul style="list-style-type: none"> – Empty signal with freely suspended cable – Min. amplitude introduced for water sump – Limitation of the measured value to the probe length – Reduction of the safety when creating a gating out of false signals – Dielectric figure value was not taken over into the sensor after calculation through the assistant – Dielectric figure value could not be edited with locked application – Adaptation of the application settings for probes with centering weight – Simulation is now also possible when the instrument is in failure mode – Message 811 "Automatic profile was updated" filled the event memory during operation. Message will no longer be entered – Output of the echo information for test certificates was provided in the unit "dB" without positions after the comma, now in the unit mV available – Search range for cable breakage/probe loss could be invalid with short probes – After the probe length determination, a previously activated measuring range limitation became inactive – Focussing range did not stop at the probe end and did not open backwards – Total level could be behind the interface with interface measurement – Probes with centering weight were only available in the bypass – When restarting with an integration time unequal 0 s, the current value corresponded to the level or interface value only after the integration time – Instrument software, in general: <ul style="list-style-type: none"> – With electronics temperatures outside the limits (-40 °C, +80 °C), no message S600 was outputted – Current value remained with an application change from interface to level when the interface value was assigned to the current output; now fault message F264 is outputted – Interference current "> 21 mA" increased from 21.5 mA to 21.7 mA – With little energy, now the external enquiries are delayed so that the sensor does not crash – Adjusted units were not taken into account for the configuration of the echo curve memory recordings – After a rest Basic settings in the application Interface, the device identification remains on Interface (although the application was reset to Level); this caused problems in the PLICSCOM menu as well as with VEGAMET – PLICSCOM adjustment: <ul style="list-style-type: none"> – Various fault rectifications: – HART communication: <ul style="list-style-type: none"> – After a restart when HART Secondary Value was assigned to the electronics temperature or the measurement reliability, the sensor switched the fault F261/12017 – The flag "Non PV Out of Limits" must only refer to the dynamic variables SV, TV and QV (instead to all Device variables) 	
1.1.2,	Error corrections:	1

Version, available since	Description	Device Rev.
09/2013	<ul style="list-style-type: none"> – Instrument software, in general: <ul style="list-style-type: none"> – Reset could no longer be carried out successfully on instruments with longer operating time System time is only stored in the 10 minute time pattern 	
1.1.1, 04/2013	<p>Error corrections:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – Rectification of device status F040/8000. Monitoring internal reference point of the electronics changes from 0.8 ... 2.8 m to 0.25 ... 2.8 m. Automatic false signal suppression with interface measurements and with probes smaller than 0.5 m deactivated 	1
1.1.0, 03/2013	<p>Function extensions</p> <p>New functions and modifications:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – Compensation of the measurement error and occurring false echoes by condensation on the coupling – Improvement of the accuracy by measurement without safety on the false signal suppression – With coax probes 1 cm safety on the factory false signal suppression – With rod and cable probes 1 cm safety on the manual or automatic false signal suppression – Instrument software, in general: <ul style="list-style-type: none"> – Support of the second current output added – PLICSCOM operation: <ul style="list-style-type: none"> – Quick setup added – Conversion of the menu level "Setup" – Release special parameter for 1 hour after entering the password – Key query optimized <p>Error corrections:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – The function water sump was active with interface measurement without superimposed gas phase. This could cause up measurement jumps – With Application/Medium <1.5 an empty signal was triggered with low level – Pitch error with cable 4 mm liquid of -0.01 % removed – After a waiting period, the measured value is now set to 0 m together with the status overflowing (previously the measured value was set to 0 m before the waiting time) – Set measured value status for interface measured value to invalid if the application is set to Level – Instrument software, in general: <ul style="list-style-type: none"> – Error correction with max. cable length with I²C connection 	1

Version, available since	Description	Device Rev.
	<ul style="list-style-type: none"> – PLICSCOM adjustment: <ul style="list-style-type: none"> – Negative electronics temperature was displayed with wrong signs – HART communication: <ul style="list-style-type: none"> The sensor TAG could not be set correctly with HART command 18 	
<p>1.0.1, 10/2012</p>	<p>Error correction of the first production version</p> <p>New functions and modifications:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – Input filter of the concentric tube added to reduce EMC interferences – Detection filter added to reduce the number of echoes in a search area. Filter only active with bulk solid – Instrument software, in general: <ul style="list-style-type: none"> – In shipping status, the following measured values are now recorded in the measured value memory of the sensor: <ul style="list-style-type: none"> – Distance, – percentage value, – reliability, – Electronics temperature, – Dielectric constant Recording based on: <ul style="list-style-type: none"> – Percentage value with measured value difference 15 % – Time pattern 3 min. <p>Error corrections:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – Error correction on the limits of the detection range. Echoes cut off too early – Error correction when generating a reference line from a profile in the close range Incorrect course of the reference line in the first centimetres – Steam pressure compensation/Reference probe did not function – Error correction of the compensation with reference probes and application interface and no superimposed gas phase – Spreading correction for the coated probes was modified in such a way that the error was minimized within the first 5 m – Activation of the function 1st large echo, now a new decision to level is made – Only probe lengths up to 74.3 m could be used. Now up to 75 m – Measured value arrow in the echo curve presentation jumped to internal reference (in front of 0 m) With invalid echo and no valid dielectric figure – The dielectric figure was outputted as measured value before it could be measured reliably – Instrument software, in general: <ul style="list-style-type: none"> – Event 814/20700 is no longer stored in the event memory – Parameter units were not displayed correctly in the parameter modification memory – Echo curve memory based on events was incorrect – With the partial transmission of the measured value memory, the dates of the measured values were not correct 	<p>1</p>

Version, available since	Description	Device Rev.
	<ul style="list-style-type: none"> – PLICSCOM adjustment: <ul style="list-style-type: none"> – Italian translation was wrong – Current output adjustment values were exchanged – Dielectric figure had only one position after the comma. Now 3 – HART communication: <p>Error correction for certification test DLL010</p>	
<p>1.0.0, 07/2012</p>	<p>First version</p> <p>New functions and modifications relating to VEGAFLEX 60:</p> <ul style="list-style-type: none"> – Measurement function: <ul style="list-style-type: none"> – Increased accuracy – Increased repetition rate – Increased sensitivity by probe end tracking – Extension with application parameter adjustment – Automatic update of the false signal suppression – Probe loss detection added – Measured values can be configured for the current output – Running time correction with steam boiler application – Determination of the dielectric figure added – Instrument software, in general: <ul style="list-style-type: none"> – Lower supply voltages possible – Device status according to NE 107 – Event memory added – Function extension for the measured value memory – Real time clock added – PLICSCOM adjustment: <ul style="list-style-type: none"> – Modification of the menu structure – Modification of the layout with value changes – The following languages are available: <ul style="list-style-type: none"> – German – English – French – Spanish – Russian – Italian – Dutch – Portuguese – Japanese – Chinese – HART communication: <ul style="list-style-type: none"> – HART Revision 7 – HART measured values can be configured 	<p>1</p>

Legend:

Service info plics[®] software versions



Name	Description
Version	Compatibility version.Function extension version.Error correction version
available since	Month/Year
Device Rev.	Version number of the instrument defined by HART. Consecutive integral number Will be increased if in the "Application Layer" modifications were carried out, e.g. new commands, modifications in the data structure in a command