### Translation

## (1) EU-Type Examination Certificate

(2) Equipment and protective systems intended for use in potentially explosive atmospheres, Directive 2014/34/EU



(3) Certificate Number **TÜV 05 ATEX 2799 X**  issue:

(4) for the product: Capacitive continuous level measurement sensors

type VEGACAL CL6\*. DX/DM \*\*\*H/P/F\*\*\*\*

(5) of the manufacturer: VEGA Grieshaber KG

(6) Address: Am Hohenstein 113, 77761 Schiltach

Order number: 8000474578

Date of issue: 2017-07-31

(7) The design of this product and any acceptable variation thereto are specified in the schedule to this EU-Type Examination Certificate and the documents therein referred to.

The TÜV NORD CERT GmbH. Notified Body No. 0044, in accordance with Article 17 of the Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential ATEX Assessment Report No. 17 203 204726.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance

EN 60079-0:2012+A11:2013

EN 60079-26:2015

EN 60079-1:2014

EN 60079-11:2012

except in respect of those requirements listed at item 18 of the schedule.

- (10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions for Use specified in the schedule to this certificate.
- 11) This EU-Type Examination Certificate relates only to the design, and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the product shall include the following:

II 1/2 G Ex ia/db ia IIC T6 ... T1 Ga/Gb II 2 G Ex db ia IIC T6 ... T1 Gb

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, notified by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the notified body

Mever

17-F-011 Rev. 01/04.16

Hanover office, Am TÜV 1, 30519 Hannover, Tel. +49 511 998-61455, Fax +49 511 998-61590



This certificate may only be reproduced without any change, schedule included. Excerpts or changes shall be allowed by the TÜV NORD CERT GmbH



### (13) SCHEDULE

### (14) EU-Type Examination Certificate No. TÜV 05 ATEX 2799 X issue 00

### (15) Description of product

The capacitive continuous level measurement sensors type VEGACAL CL6\*. DX/DM \*\*\*H/P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive continuous level measurement sensors type VEGACAL CL6\*. DX/DM \*\*\*H/P/F\*\*\*\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Machanical basic execution of the electrodes:

Type	Electrodes		
VEGACAL CL62	partly insulated rod electrode, optionally with screening tube or concentric tube		
VEGACAL CL63	fully insulated rod electrode, optionally plated		
VEGACAL CL64	fully insulated rod electrode for viscous and adhesive filling materials		
VEGACAL CL65	partly insulated cable electrode optionally with abrasion protection		
VEGACAL CL66	fully insulated cable electrode		

Electrical data	2			
Type VEGACAL CL6*. DX/DM ***H**** Supply and signal circuit	with barrier P3-2LH: U = 14 36 V d. c. $U_m = 253 V a. c.$			
	with barrier P2-2LH: U = 20 36 V d. c. Um = 253 V a. c.			
Operation and indication circuit	in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61/81 The interconnection of the both intrinsically safe circuits was taken into account. maximum values of the connection cable: $C_o = 2.4 \ \mu F$ $L_o = 160 \ \mu H$			
Operation and indication module circuit(Spring contacts in the housing for the electronics)	in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (PLICSCOM)			
Communication circuit	in type of protection "Intrinsic Safety" Ex ia IIC			
(I <sup>2</sup> C bus in the "i" connection room))	only for connection to the intrinsically safe signal			

circuit of the VEGA interface converter type

**VEGACONNECT** 



lf

- the VEGA interface converter type VEGACONNECT and

- the external VEGA indication unit type VEGADIS61

are connected, the following maximum values of the connection cable to the VEGADIS61/81 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive continuous level measurement sensors with built-in barrier P3-2LH are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier P2-2LH are galvanically connected with the earth potential (measuring circuit excluded).

### Type VEGACAL CL6\*. DX/DM \*\*\*P/F\*\*\*\*

#### Electrical data

> with barrier KLEMP2-2LPAFFD: U = 16 ... 32 V d. c. Um = 253 V a. c.

Operation and indication circuit .... (Terminals 5, 6, 7, 8 in the "Ex i"-connection room) in type of protection "Intrinsic Safety "Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61/81

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_0 = 2.4 \mu F$  $L_0 = 160 \mu H$ 

connection room)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (PLICSCOM)

in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT



If

- the VEGA interface converter type VEGACONNECT and

- the external VEGA indication unit type VEGADIS61

are connected, the following maximum values of the connection cable to the VEGADIS61/81 do result:

 $C_o = 2.8 \mu F$  $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive continuous level measurement sensors with built-in barrier P3-2LPAFF are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LPAFFD are galvanically connected with the earth potential (measuring circuit excluded).

### Thermal data

### Type VEGACAL CL6\*. DX/DM \*\*\*H\*\*\*\*

If the capacitive continuous level measurement sensors are mounted in the partition wall between explosion hazardous areas which require apparatus of the <u>category 1 (electrode)</u> and <u>category 2 (electronics)</u>, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor
Т6	-40 °C +46 °C	
T5	-40 °C+60 °C	
T4		20.00 .00.00
Т3		-20 °C+60 °C
T2		
T1		

The electrodes of the capacitive continuous level measurement sensors are allowed to be operated in an explosion hazardous area, that requires apparatus of the category 1, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



If the capacitive continuous level measurement sensors are mounted in explosion hazardous areas which require apparatus of the <u>category 2</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor		
		PE insulation	PTFE insulation	PTFE insulation with temperature adapter
T6	-40 °C +46 °C	0.1	-50 °C +85 °C	-50 °C +85 °C
T5	-40 °C +60 °C		-50 °C +100 °C	-50 °C +100 °C
T4		40.00 .00.00	-50 °C +135 °C	-50 °C +135 °C
T3		-40 °C +80 °C	-50 °C +150 °C -50 °C .	
T2				-50 °C +200 °C
T1				

If the sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Type VEGACAL CL6\*. DX/DM \*\*\*P/F\*\*\*\*

If the capacitive continuous level measurement sensors are mounted in the partition wall between explosion hazardous areas which require apparatus of the <u>category 1 (electrode) and category 2 (electronics)</u>, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor
Т6	-40 °C +38 °C	
T5	-40 °C+53 °C	20.80 .00.80
T4	-40 °C+60 °C	
T3		-20 °C+60 °C
T2		
T1		

The electrodes of capacitive continuous level measurement sensors are allowed to be operated in an explosion hazardous area, that requires apparatus of the category 1, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



If the capacitive continuous level measurement sensors are mounted in explosion hazardous areas which require apparatus of the <u>category 2</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor		
		PE insulation	PTFE insulation	PTFE insulation with temperature adapter
T6	-40 °C +38 °C		-50 °C +85 °C	-50 °C +85 °C
T5	-40 °C +53 °C		-50 °C +100 °C	-50 °C +100 °C
T4		-40 °C +80 °C	-50 °C +135 °C	-50 °C +135 °C
T3	-40 °C+60 °C	-40 °C +60 °C	-50 °C +150 °C	-50 °C +200 °C
T2				
T1			20 most 242 8	

If the sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

- (16) Drawings and documents are listed in the ATEX Assessment Report No. 17 203 204726
- (17) Specific Conditions for Use
- At the plastic parts of the capacitive continuous level measurement sensors there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
- For zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive continuous level measurement sensors have to be secured effectively against these dangers. Observe manual of the manufacturer.
- For zone 0/1 applications, at the metallic electrode parts of the capacitive continuous level measurement sensors made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- 4. For zone 0/1 applications the medium tangent materials have to be resistant to the media.
- The flameproof terminal box (Ex-d connection room) of this equipment must be provided with cable entries and filler plugs resp. conduits which are certified according to IEC 60079-0 and IEC 60079-1.
- The PA terminal of the capacitive continuous level measurement sensors with the barriers P2-2LH and KLEMP2-2LPAFFD (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area.

Since the intrinsically safe circuits are galvanically connected with the earth potential, potential compensation has to exist in the complete course of the erection of the intrinsically safe operation and indication circuit.

(18) Essential Health and Safety Requirements

no additional ones

- End of Certificate -



# Translation 4. SUPPLEMENT

to Certificate No.

**TÜV 05 ATEX 2799 X** 

Equipment:

Capacitive measuring probe type VEGACAL CL6\*.D\*\*\*\*H\*\*\*\*

Manufacturer:

VEGA Grieshaber KG

Address:

Am Hohenstein 113

77761 Schiltach

Order number: Date of issue: 8000393985 2011-07-20

In the future, the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*\*HD\*\*\* are also allowed to be manufactured according to the documents listed in the test report.

### The changes refer to

 the mechanical execution (material of the insulating bushing, execution of the sealing between cable insulation and the tightening weight),

 the construction of the capacitive measuring probes (Ex-d connection housing according to EC-Type Examination Certificate TÜV 09 ATEX 555501 U, 1<sup>st</sup> and 2<sup>nd</sup> supplement with new Ex-dbushing and galvanically separating barrier P3-2LH) and

the type designation.

In the future, this reads VEGACAL CL6\*.D\*\*\*\*H\*\*\*\*.

The equipment according to this supplement meets the requirements of these standards:

EN 60079-0:2009

EN 60079-1:2007

EN 60079-11:2007

EN 60079-26:2007

All other details remain unchanged.

(16) The test documents are listed in the test report No. 11 203 080449.





### 4. Supplement to Certificate No. TÜV 05 ATEX 2799 X

### (17) Special conditions for safe use

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*H\*\*\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
- For category 1/category 2 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*H\*\*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For category 1/category 2 applications and at risks by pendulum or vibration the respective
  parts of the capacitive measuring probes type capacitive measuring probes type VEGACAL
  CL65.D\*\*\*\*H\*\*\*\* und type VEGACAL CL66.D\*\*\*\* have to be secured effectively against
  these dangers.
- For category 1/category 2 applications the medium tangent materials have to be resistant to the media
- The flameproof terminal housing shall be connected by means of suitable cable entries resp. conduit systems, which meet the requirements of EN 60079-1, sections 13.1 and 13.2, and for which a separate test certificate is available.
- 6. Non-used openings shall be sealed according to EN 60079-1, section 11.9.

## (18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, accredited by the central office of the countries for safety engigleering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the certification body

Schwedt

Hanover office, Am TÜV 1, 30519 Hanover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590



## Translation 3. SUPPLEMENT

to Certificate No.

**TÜV 05 ATEX 2767 X** 

Equipment:

Capacitive measuring probe type VEGACAL CL6\*.D\*\*\*\*HD\*\*\*\*

Manufacturer:

VEGA Grieshaber KG

Address:

Am Hohenstein 113 77761 Schiltach

Order number:

8000555745 2010-04-20

Date of issue: 2010-04-2

In the future, the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*H\*\*\*\* are also allowed to be manufactured according to the documents listed in the test report.

### The changes refer to

- the mechanical execution (new temperature adapter, new execution of the cable electrode),

- the construction of the capacitive measuring probes (Ex-d connection housing according ton EC Type examination certificate TÜV 09 ATEX 555501 U exclusively with the galvanically separating barrier P3-2LH; intrinsically safe part according to EC Type examination certificate TÜV 05 ATEX 552767 X, 3<sup>rd</sup> supplement),
- the tables for the temperature ranges
- the electrical data,
- the "Special conditions for safe use" and
- the marking.

### This reads as follows:

II 1/2 G or II 2 G Ex d ia IIC Tx Ga/Gb or Gb (Tx: See tables below).

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas which require apparatus of the <u>category 1 (electrode) and category 2 (electronics)</u>, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range	
T6	-40°C +54 °C	-20°C +60 °C	
T5, T4, T3, T2, T1	-40°C +60 °C	-20°C +60 °C	

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area, that requires apparatus of the category 1, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



If the capacitive measuring probes are mounted in explosion hazardous areas which require apparatus of the <u>category 2</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range for electrodes with PE/PA-insulation	Medium temperature range for other electrodes
T6	- 40°C + 54°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 60°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 60°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 60°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Electrical data

### With Barrier P3-2LH in the Ex-d-connection room

in the Ex-d connection room)

Operation and indication circuit ............................ (Terminals 5, 6, 7, 8 or plug connection in the "i" connection room)

in type of protection "Intrinsic Safety"

Ex ia IIC

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (PTB 02 ATEX 2136 X)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_o = 2.4 \mu F$  $L_o = 160 \mu H$ 



### 3. Supplement to Certificate No. TÜV 05 ATEX 2799 X

14

- the VEGA interface converter type VEGACONNECT and
- the external VEGA indication unit type VEGADIS61

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier P3-2LH are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

The equipment according to this supplement meets the requirements of these standards:

EN 60079-0:2009 EN 60079-26:2007 FN 60079-1:2004

EN 60079-11:2007

All other details remain unchanged.

(16) The test documents are listed in the test report No. 10 203 555745.



### (17) Special conditions for safe use

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*HD\*\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
- For category 1/category 2 applications, at the metallic electrode parts of the capacitive measuring
  probes type VEGACAL CL6\*.D\*\*\*\*HD\*\*\* made of light metal there is a danger of ignition by impact
  or friction. Observe manual of the manufacturer.
- For category 1/category 2 applications and at risks by pendulum or vibration the respective parts of the capacitive measuring probes type capacitive measuring probes type VEGACAL CL65.D\*\*\*\*HD\*\*\* und type VEGACAL CL66.D\*\*\*\*HD\*\*\* have to be secured effectively against these dangers.
- For category 1/category 2 applications the medium tangent materials have to be resistant to the media.
- The flameproof terminal housing shall be connected by means of suitable cable entries resp. conduit systems, which meet the requirements of EN 60079-1, sections 13.1 and 13.2, and for which a separate test certificate is available.
- 6. Non-used openings shall be sealed according to EN 60079-1, section 11.9.

(18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, accredited by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the certification body

Schwedt

Hanover office, Am TÜV 1, 30519 Hanover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590



## Translation 2. S U P P L E M E N T

to Certificate No. TÜV 05 ATEX 2799 X

Equipment: Capacitive measuring probes

type VEGACAL CL6\*.D\*\*\*\*HD\*\*\*

Manufacturer: VEGA Grieshaber KG
Address: Am Hohenstein 113

Address: Am Hohenstein 11: D-77761 Schiltach

Order number: 8000554576

Date of issue: 2008-07-04

In the future, the capacitive measuring probes type VEGACAL CL6\*.D\_\*\*HD\*\* are also allowed to be manufactured according to the documents listed in the test report.

The changes refer to the type designation, the mechanical and electrical construction and the marking.

Mechanical execution of the measuring probes

Туре	Electrodes	
CL62.D****HD***	partly insulated electrode, optionally with screening tube or concentric tube	
CL63.D****HD***	fully insulated electrode, optionally plated	
CL64.D****HD***	fully insulated electrode, optionally with screening tube, concentric tube or plated	
CL65.D****HD***	** partly insulated cable electrode optionally with additionally insular cable	
CL66.D****HD***	fully insulated cable electrode	
CL69.D****HD***	fully insulated 2-rod electrode	

### Electrical data

Operation and indication circuit ......(Terminals 5, 6, 7, 8 resp. plug connection in the "i"-connection room)

in type of protection "Intrinsic Safety "Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

(PTB 02 ATEX 2136 X)

The interconnection of the both intrinsically safe circuits was

taken into account.

maximum values of the connection cable:

 $C_o = 2.4 \mu F$  $L_o = 160 \mu H$ 

Operation and indication module circuit ... (Spring contacts in the "i"-connection room)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)



### 2. Supplement to Certificate No. TÜV 05 ATEX 2799 X

Communication circuit ..... and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC (I<sup>2</sup>C bus in the housing for the electronics only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT (PTB 01 ATEX 2007 or PTB 07 ATEX 2013 X)

- the VEGA interface converter type VEGACONNECT and
- the external VEGA indication unit type VEGADIS61

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMMP2-2LHD are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier P2-2LH are galvanically connected with the earth potential (measuring circuit excluded).

All other details apply unchanged for this supplement.

The equipment according to this supplement meets the requirements of these standards:

EN 60079-0:2006 EN 60079-26:2004 EN 60079-1:2004

EN 60079-11:2007

(16) The test documents are listed in the test report No. 08 203 554576.



### (17) Special conditions for safe use

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*HD\*\*\*
  there is a danger of ignition by electrostatic discharge. Observe manual of the
  manufacturer and warning label.
- For category 1/category 2 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*HD\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For category 1/category 2 applications and at risks by pendulum or vibration the respective
  parts of the capacitive measuring probes type capacitive measuring probes type VEGACAL
  CL65.D\*\*\*\*HD\*\*\* and type VEGACAL CL66.D\*\*\*\*HD\*\*\* have to be secured effectively
  against these dangers.
- 4. For category 1/category 2 applications the medium tangent materials have to be resistant to the media.
- 5. The PA terminal of the capacitive measuring probes with the barrier P2-2LH (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area. Since the intrinsically safe circuits are galvanically connected with the earth potential, potential compensation has to exist in the complete course of the erection of the intrinsically safe operation and indication circuit.
- The flameproof terminal housing shall be connected by means of suitable cable entries resp. conduit systems, which meet the requirements of EN 60079-1, sections 13.1 and 13.2, and for which a separate test certificate is available.
- Cable entries as well as sealing plugs of simple construction shall not be used. For connection of the flameproof terminal housing by means of an approved conduit entry the associated sealing facility must be arranged directly on the enclosure.
- 8. Non-used openings shall be sealed according to EN 60079-1, section 11.9.

### (18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, accredited by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the certification body

Schwedt

Hanover office, Am TÜV 1, 30519 Hanover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590



### Translation 1. SUPPLEMENT

to Certificate No.

**TÜV 05 ATEX 2799 X** 

Equipment:

Capacitive measuring probe type VEGACAL CL6\*.D \*\*HD\*\*

Manufacturer:

VEGA Grieshaber KG

Address:

Am Hohenstein 113

D-77761 Schiltach

Order number:

8000553042

Date of issue:

2006-07-03

In the future, the capacitive measuring probes type VEGACAL CL6\*.C \*\*H\*\* are allowed to be manufactured according to the documents listed in the test report.

The changes refer to the mechanical and electrical construction of the measuring probes as well as to the electrical data for the intrinsically safe circuits.

Mechanical execution of the measuring probes

Type	Electrodes	
CL62.D_**HD**	partly insulated electrode, optionally with screening tube or concentric tube	
CL63.D_**HD**	fully insulated electrode, optionally plated	
CL64.D_**HD**	fully insulated electrode, optionally with screening tube, concentric tube or plated	
CL65.D_**HD**	partly insulated cable electrode optionally with additionally insulated cable	
CL66.D_**HD**	fully insulated cable electrode	
CL69.D **HD**	fully insulated 2-rod electrode	

### Electrical data

Operation and indication circuit ..... (Terminals 5, 6, 7, 8 or plug connection in in type of protection "Intrinsic Safety"

EEx ia IIC

the "i"-connection room) only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

(PTB 02 ATEX 2136 X) The interconnection of the both intrinsically safe circuits

was taken into account. maximum values of the connection cable:

 $C_o = 2.4 \mu F$ Lo  $= 160 \mu H$ 

Communication circuit ..... (I2C bus in the "i"-connection room))

in type of protection "Intrinsic Safety"

EEx ia IIC

only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT 3

(PTB 01 ATEX 2007)

If



### 1. Supplement to Certificate No. TÜV 05 ATEX 2799 X

- the VEGA interface converter type VEGACONNECT 3 and
- the external VEGA indication unit type VEGADIS61

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMMP2-2LHD are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier P2-2LH are galvanically connected with the earth potential (measuring circuit excluded).

All other details as well as the "Special conditions for safe" use apply unchanged for this supplement.

The equipment incl. of this supplement meets the requirements of these standards:

EN 50 014:1997+A1+A2

EN 50 018:2000+A1

EN 50 020:2002

EN 50 284:1999

- (16) The test documents are listed in the test report No. 06 YEX 553040.
- (17) Special conditions for safe use

no changes

(18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, accredited by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the certification body

Schwedt

Hanover office, Am TÜV 1, 30519 Hanover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590

### Translation

### (1) EC-Type Examination Certificate



(2) Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/FC



(3) EC-Type Examination Certificate Number

### **TÜV 05 ATEX 2799 X**

(4) Equipment: Capacitive measuring probe type VEGACAL CL6\*.D \*\*HD\*\*

(5) Manufacturer: VEGA Grieshaber KG

(6) Address: Am Hohenstein 113

D-77761 Schiltach

- (7) This equipment or protective system and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- (8) The TÜV NORD CERT GmbH & Co. KG, TÜV CERT-Certification Body, notified body number N° 0032 in accordance with Article 9 of the Council Directive of the EC of March 23, 1994 (94/9/EC), certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential report N° 05 YEX 552075

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50 014:1997 + A1 + A2 EN 50 018:2000 + A1 EN 50 020:2002 EN 50 284:1999

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-type examination certificate relates only to the design, examination and tests of the specified equipment in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the equipment or protective system must include the following:

⟨Ex⟩ II 1/2 G or II 2 G EEx d ia IIC T6

TÜV NORD CERT GmbH & Co. KG Am TÜV 1

30519 Hannover Tel.: +49 511 986-1470 Fax: +49 511 986-1590

Head of the Certification Body Hanover, 2005-04-20

ERT.AM VU-H 02:05 9000 die



### (13) SCHEDULE

### (14) EC-Type Examination Certificate N° TÜV 05 ATEX 2799 X

### (15) Description of equipment

The capacitive measuring probes type VEGACAL CL6\*.D\_\*\*HD\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\*.D\_\*\*HD\* consist of an electronic housing for the barriers with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Mechanical execution of the capacitive measuring probes:

type	electrodes	
CL62.D_**HD**	partly insulated electrode, optionally with screening tube or concentric tube	
CL63.D_**HD**	fully insulated electrode, optionally plated	
CL64.D_**HD**	fully insulated electrode, optionally with screening tube, concentric tube or plated	
CL65.D_**HD**	partly insulated cable electrode optionally with additionally insulated cable	
CL66.D_**HD**	fully insulated cable electrode	

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas which require apparatus of the category 1 (electrode) and category 2 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature	medium temperature	
	range	range	
T6	-40°C +57 °C	-20°C +60 °C	
T5, T4, T3, T2, T1	-40°C +68 °C	-20°C +60 °C	

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area, that requires apparatus of the category 1, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



### Schedule EC-Type Examination Certificate Nº TÜV 05 ATEX 2799 X

If the capacitive measuring probes are mounted in explosion hazardous areas which require apparatus of the <u>category 2</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA-insulation	medium temperature range for other electrodes
T6	- 40°C + 57°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 68°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 68°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 68°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Electrical data

Supply and signal circuit (Terminals KI1/1, KI1/2;

"d"-connection room)

U = 12...36V

 $U_{\rm m} = 253$  Va.c.

PA terminal of the capacitive measuring probe with barrier P2-2LH (Screw terminal) Connection to the potential equalisation in the explosion hazardous area

Operation and indication circuit (Terminals 5, 6, 7, 8 resp. plug connection in the "i"-connection room)

in type of protection "Intrinsic Safety "EEx ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (PTB 02 ATEX 2136 X)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_o = 2,4 \mu F$  $L_o = 160 \mu H$ 

Operation and indication module circuit (Spring contacts in the "i"connection room) in type of protection "Intrinsic Safety" EEx ia IIC only for connection to the VEGA operation and indication module (Plicscom)



### Schedule EC-Type Examination Certificate Nº TÜV 05 ATEX 2799 X

Communication circuit (I<sup>2</sup>C bus in the "i"-connection room)

in type of protection "Intrinsic Safety" EEx ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT3 (PTB 01 ATEX 2007)

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMMP2-2LHD are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier P2-2LH are galvanically connected with the earth potential (measuring circuit excluded).

- (16) The Test documents are listed in the test report N° 05 YEX 552075.
- (17) Special conditions for safe use
  - At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.C\_\*\*HD\*\*
    there is a danger of ignition by electrostatic discharge. Observe manual of the
    manufacturer and warning label.
  - For category 1/category 2 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CL6\*.C\_\*\*HD\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
  - For category 1/category 2 applications and at risks by pendulum or vibration the respective
    parts of the capacitive measuring probes type capacitive measuring probes type VEGACAL
    CL65.D\_\*\*HD\*\* and type VEGACAL CL66.D\_\*\*HD\*\* have to be secured effectively against
    these dangers.
  - For category 1/category 2 applications the medium tangent materials have to be resistant to the media.
  - 5. The PA terminal of the capacitive measuring probes with the barrier P2-2LH (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area. Since the intrinsically safe circuits are galvanically connected with the earth potential, potential compensation has to exist in the complete course of the erection of the intrinsically safe operation and indication circuit.



### Schedule EC-Type Examination Certificate N° TÜV 05 ATEX 2799 X

- The flameproof terminal housing shall be connected by means of suitable cable entries resp. conduit systems, which meet the requirements of EN 50 018, sections 13.1 and 13.2, and for which a separate test certificate is available.
- Cable entries as well as sealing plugs of simple construction shall not be used. For
  connection of the flameproof terminal housing by means of an approved conduit entry the
  associated sealing facility must be arranged directly on the enclosure.
- 8. Non-used openings shall be sealed according to EN 50 018, section 11.9.
- (18) Essential Health and Safety Requirements

no additional ones



# Translation 4. SUPPLEMENT

to Certificate No.

**TÜV 05 ATEX 2827 X** 

Equipment:

Capacitive Measuring Probe

VEGACAL CL6\*(\*).D\*\*\*\*P/F\*\*\*\*(\*)(\*)

Manufacturer:

VEGA Grieshaber KG

Address:

Am Hohenstein 113 77761 Schiltach

Germany

Order number:

8000434381

Date of issue:

2014-07-23

In the future, the capacitive measuring probe VEGACAL CL6\*.D\*\*\*\*P/F\*\*\*\* may be manufactured to documents listed above with following changes:

1. Update to actual standards

2. Changes regarding technical and electrical data

3. Changes regarding electric diagram

4. Changes to the layout

5. New components used

6. Application with PLICSCOM 02 added

7. Application with VEGADIS81 added

8. Introduction of new cables

9. Changes of the type code/marking

Due to changes listed above the technical data change as follow:

The new marking of the capacitive measuring probe type VEGACAL CL6\*(\*).D\*\*\*\*P/F\*\*\*\*(\*)(\*)

### Category 1/2G instruments:

VEGACAL CL6\*(\*).D\*\*\*\*H\*\*\*\*(\*)(\*)

Temperature class	Permissible ambient temperature on the electronics	Permissible ambient temperature on the sensor
T6	-40°C +57°C	-20°C +60°C
T5 T1	-40°C +60°C	-20°C +60°C

VEGACAL CL6\*(\*).D\*\*\*\*P/F\*\*\*\*(\*)(\*)

Temperature class	Permissible ambient temperature on the electronics	Permissible ambient temperature on the sensor
T6	-40°C +38°C	-20°C +60°C
T5	-40°C +53°C	-20°C +60°C
T4 T1	-40°C +60°C	-20°C +60°C

Category 2G instruments:

VEGACAL CL6\*(\*).D\*\*\*\*H\*\*\*\*(\*)(\*) Permissible ambient ambient ambient Permissible Temperature Permissible Permissible on the temperature on the other temperature class ambient temperature on the with temperature on the sensor with PE/PA sensors without other sensors insulation temperature adapter temperature adapter electronics -50°C ... +85°C -50°C ... +85°C -40°C ... +80°C -40°C ... +57°C T6 -50°C ... +100°C -50°C ... +100°C -40°C ... +80°C T5 -40°C ... +60°C -50°C ... +135°C -50°C ... +135°C -40°C ... -40°C ... +60°C +80°C T4 -50°C +200°C -50°C ... +150°C -40°C ... +60°C -40°C ... +80°C T3, T2, T1

Temperature class	Permissible ambient temperature on the electronics	temperature on the	temperature on the other	Permissible ambient temperature on the other sensors with temperature adapter
T6	-40°C +38°C	-40°C +80°C	-50°C +85°C	-50°C +85°C
T5	-40°C +53°C	-40°C +80°C	-50°C +100°C	-50°C +100°C
T4	-40°C +60°C	-40°C +80°C	-50°C +135°C	-50°C +135°C
T3, T2, T1	-40°C +60°C	-40°C +80°C	-50°C +150°C	-50°C +200°C

All other data remain unchanged.

The equipment incl. of this supplement meets the requirements of these standards:

EN 60079-0:2012

EN 60079-1:2007

EN60079-11:2012

EN60079-26:2007

The marking of the equipment is:

- ⟨Ex⟩ II 1/2 G resp. II 2 G Ex d ia IIC T6...T1 Ga/Gb resp. Gb
- (16) The test documents are listed in the test report No. 14 203 141328.
- (17) Special conditions for safe use

no additional ones

(18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, notified by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the notified body

Schwedt

Hanover office, Am TÜV 1, 30519 Hannover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590



## Translation 3. SUPPLEMENT

to Certificate No.

**TÜV 05 ATEX 2827 X** 

Equipment:

Capacitive measuring probe

type VEGACAL CL6\*.D\*\*\*\*P/F\*\*\*\*

Manufacturer:

VEGA Grieshaber KG

Address:

Am Hohenstein 113 77761 Schiltach

8000393981

Order number:

2011-07-19

In the future, the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*P/FD\*\*\* are also allowed to be manufactured according to the documents listed in the test report.

### The changes refer to

- the mechanical execution (material of the insulating bushing, execution of the sealing between cable insulation and the gravity weight, temperature adapter for medium temperatures >150 °C),
- the construction of the capacitive measuring probes (Ex-d connection housing according to EC Type examination certificate TÜV 09 ATEX 555501 U, 1<sup>st</sup> and 2<sup>nd</sup> supplement, with new Ex-d-bushing and galvanically separating barrier P3-2LPAFF; see also "Electrical data" and "Special conditions for safe use"),
- the ambient temperature ranges (see tables listed below),
- the execution of the built-in PLICSCOM module according to 3<sup>rd</sup> supplement to EC-Type Examination Certificate 05 ATEX 2808 X.
- the marking with II 1/2 G oder II 2 G Ex d ia IIC T6 ... T1 Ga/Gb oder Gb and
- the type designation.

In the future, this reads VEGACAL CL6\*.D\*\*\*\*P/F\*\*\*\*.

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas which require apparatus of the category 1 (electrode) and category 2 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range -20 °C +60 °C	
T6	-40 °C +47 °C		
T5, T4, T3, T2, T1	-40 °C +60 °C	-20 °C +60 °C	

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area, that requires apparatus of the category 1, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



If the capacitive measuring probes are mounted in explosion hazardous areas which require apparatus of the <u>category 2</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range for electrodes with PE/PA-insulation	Medium temperature range for other electrodes
T6	-40 °C +47 °C	-40 °C +80 °C	-50 °C +85 °C
T5	-40 °C +60 °C	-40 °C +80 °C	-50 °C +100 °C
T4	-40 °C +60 °C	-40 °C +80 °C	-50 °C +135 °C
T3*, T2*, T1*	-40 °C +60 °C	-40 °C +80 °C	-50 °C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures >150 °C ... 200 °C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Electrical data

Supply and signal circuit .....

(Terminals KI1/1, KI1/2; "Ex d"-connection room)

Operation and indication circuit ....
(Terminals 5, 6, 7, 8 in the "Ex i"-

connection room)

U = 14 ... 32V d. c.

 $U_m = 253$  V a. c.

in type of protection "Intrinsic Safety "Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

(PTB 02 ATEX 2136 X)

The interconnection of the both intrinsically safe circuits was

taken into account.

maximum values of the connection cable:

 $C_o = 2.4 \mu F$  $L_o = 160 \mu H$ 

Operation and indication module circuit .....

(Spring contacts in the "Ex i"connection room)

Communication circuit ......(I<sup>2</sup>C bus in the "Ex i"-connection

in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the VEGA operation and indication module (Plicscom)

in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT3 (PTB

01 ATEX 2007 or PTB 07 ATEX 2013 X)

If

room)

- the VEGA interface converter type VEGACONNECT and

- the external VEGA indication unit type VEGADIS61

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

 $C_o = 2.8 \mu F$  $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

P17-F-016 06-06



### 3. Supplement to Certificate No. TÜV 05 ATEX 2827 X

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier P3-2LPAFF are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

The equipment according to this supplement meets the requirements of these standards:

EN 60079-0:2009 EN 60079-26:2007 EN 60079-1:2007

EN 60079-11:2007

(16) The test documents are listed in the test report No. 11 203 080448.

### (17) Special conditions for safe use

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*P/F\*\*\*\* there
  is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and
  warning label.
- For category 1/category 2 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*P/F\*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For category 1/category 2 applications and at risks by pendulum or vibration the respective
  parts of the capacitive measuring probes type capacitive measuring probes type VEGACAL
  CL65.D\*\*\*\*P/F\*\*\* und type VEGACAL CL66.D\*\*\*\*P/F\*\*\*\* have to be secured effectively
  against these dangers.
- For category 1/category 2 applications the medium tangent materials have to be resistant to the media.
- The flameproof terminal housing shall be connected by means of suitable cable entries resp. conduit systems, which meet the requirements of EN 60079-1, sections 13.1 and 13.2, and for which a separate test certificate is available.
- 6. Non-used openings shall be sealed according to EN 60079-1, section 11.9.

### (18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, accredited by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the certification body

Schwedt

Hanover office, Am TÜV 1, 30519 Hanover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590



# Translation 2. SUPPLEMENT

to Certificate No.

**TÜV 05 ATEX 2827 X** 

Equipment:

Capacitive measuring probes

type VEGACAL CL6\*.D\*\*\*\*P/FD\*\*\*

Manufacturer:

VEGA Grieshaber KG

Address:

Am Hohenstein 113 D-77761 Schiltach

Order number:

8000554577

Date of issue:

2008-07-15

In the future, the capacitive measuring probes type VEGACAL CL6\*.D\_\*\*P/FD\*\* are also allowed to be manufactured according to the documents listed in the test report.

The changes refer to the type designation, the mechanical and electrical construction and the marking.

Mechanical execution of the measuring probes

Туре	Electrodes		
CL62.D****P/FD***	partly insulated electrode, optionally with screening tube or concentric tube		
CL63.D****P/FD***	fully insulated electrode, optionally plated		
CL64.D****P/FD***	fully insulated electrode, optionally with screening tube, concentric tube or plated		
CL65.D****P/FD***	partly insulated cable electrode optionally with additionally insulated cable		
CL66.D****P/FD***	fully insulated cable electrode		
CL69.D****P/FD***	fully insulated 2-rod electrode		

### Electrical data

Supply and signal circuit ...... U =  $16 \dots 32$  V d. c. (Terminals KI1/1, KI1/2; U<sub>m</sub> = 253 V a. c. "d"-connection room)

Operation and indication circuit ......(Terminals 5, 6, 7, 8 resp. plug connection in the "i"-connection room)

in type of protection "Intrinsic Safety "Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (PTB 02 ATEX 2136 X)

The interconnection of the both intrinsically safe circuits was

taken into account.
maximum values of the connection cable:

 $C_o = 2.4 \mu F$  $L_o = 160 \mu H$ 

Operation and indication module circuit ... (Spring contacts in the "i"-connection room)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)



### 2. Supplement to Certificate No. TÜV 05 ATEX 2827 X

Communication circuit	
(I2C bus in the in the "i"-connection roo	m

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT (PTB 01 ATEX 2007 or PTB 07 ATEX 2013 X)

If

- the VEGA interface converter type VEGACONNECT and
- the external VEGA indication unit type VEGADIS61

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LPA/FFD are galvanically connected with the earth potential (measuring circuit excluded).

All other details apply unchanged for this supplement.

The equipment according to this supplement meets the requirements of these standards:

EN 60079-0:2006 EN 60079-26:2004 EN 60079-1:2004

EN 60079-11:2007

(16) The test documents are listed in the test report No. 08 203 554577.





### (17) Special conditions for safe use

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\*P/FD\*\*\*
  there is a danger of ignition by electrostatic discharge. Observe manual of the
  manufacturer and warning label.
- For category 1/category 2 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CL6\*.D\*\*\*\* P/FD \*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For category 1/category 2 applications and at risks by pendulum or vibration the respective
  parts of the capacitive measuring probes type capacitive measuring probes type VEGACAL
  CL65.D\*\*\*\*P/FD\*\*\* and type VEGACAL CL66.D\*\*\*\*P/FD\*\*\* have to be secured effectively
  against these dangers.
- For category 1/category 2 applications the medium tangent materials have to be resistant to the media.
- The flameproof terminal housing shall be connected by means of suitable cable entries resp. conduit systems, which meet the requirements of EN 60079-1, sections 13.1 and 13.2, and for which a separate test certificate is available.
- Cable entries as well as sealing plugs of simple construction shall not be used. For connection of the flameproof terminal housing by means of an approved conduit entry the associated sealing facility must be arranged directly on the enclosure.
- 7. Non-used openings shall be sealed according to EN 60079-1, section 11.9.
- 8. The PA terminal of the capacitive measuring probes with the barrier KLEMP2-2LPA/FFD (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area. Since the intrinsically safe circuits are galvanically connected with the earth potential, potential compensation has to exist in the complete course of the erection of the intrinsically safe operation and indication circuit.

### (18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, accredited by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the certification body

Schwedt

Hanover office, Am TÜV 1, 30519 Hanover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590



### Translation

### 1. SUPPLEMENT

to Certificate No. TÜV 05 ATEX 2827 X

Equipment: Capacitive measuring probe type VEGACAL

CL6\*.D\_\*\*P/FD\*\*

Manufacturer: VEGA Grieshaber KG

Address: Am Hohenstein 113 D-77761 Schiltach

D-11161 Schilla

Order number: 8000553281

Date of issue: 2006-12-05

In the future, the capacitive measuring probes type VEGACAL CL6\*.C\_\*\*P/F\*\* are allowed to be manufactured according to the documents listed in the test report.

The changes refer to the mounting of the barrier type KLEMP2-2LPA/FFD according to the 4. supplement to EC-Type Examination Certificate PTB 02 ATEX 1127U, the mechanical and electrical construction of the measuring probes as well as to the electrical data for the intrinsically safe circuits and the "Special conditions for safe use".

Mechanical execution of the capacitive measuring probes:

Type	Electrodes	
CL62.D_**P/FD**	partly insulated electrode, optionally with screening tube or concentric tube	
CL63.D_**P/FD**	fully insulated electrode, optionally plated	
CL62.D_**P/FD**	fully insulated electrode, optionally with screening tube, concentric tube or plated	
CL63.D_**P/FD**	partly insulated cable electrode optionally with additionally insulated cable	
CL62.D_**P/FD**	fully insulated cable electrode	
CL63.D **P/FD**	fully insulated 2-rod electrode	

### Electrical data

in type of protection "Intrinsic Safety" EEx ia IIC

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (PTB 02 ATEX 2136 X)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_o = 2.4 \mu F$  $L_o = 160 \mu H$ 



### 1. Supplement to Certificate No. TÜV 05 ATEX 2827 X

Operation and

room) module (Plicscom)

Communication circuit ...... in type of protection "Intrinsic Safety" EEx ia IIC

(I<sup>2</sup>C bus in the "i"-connection room) only for connection to the intrinsically safe signal circuit of

the VEGA interface converter type VEGACONNECT 3 (PTB 01 ATEX 2007)

- the VEGA interface converter type VEGACONNECT 3 and

the external VEGA indication unit type VEGADIS61

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

 $C_o = 2.8 \mu F$  $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LPA/FFD are galvanically connected with the earth potential (measuring circuit excluded).

The "Special conditions for safe use" are supplemented accordingly.

All other details apply unchanged.

The equipment incl. of this supplement meets the requirements of these standards:

EN 50 014:1997+A1+A2 EN 50 018:2000+A1 EN 50 020:2002 EN 50 284:1999

(16) The test documents are listed in the test report No. 06 YEX 553281.



### (17) Special conditions for safe use

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.C\_\*\*P/FD\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
- For category 1/2 applications, at the metallic electrode parts of the capacitive measuring probes type VEGACAL CL6\*.C\_\*\*P/FD\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For category 1/2 applications and at risks by pendulum or vibration the respective parts of the capacitive measuring probes type capacitive measuring probes type VEGACAL CL65.D\_\*\*P/FD\* and type VEGACAL CL66.D\_\*\*P/FD\* have to be secured effectively against these dangers.
- For category 1/2 applications the medium tangent materials have to be resistant to the media
- The flameproof terminal housing shall be connected by means of suitable cable entries resp. conduit systems, which meet the requirements of EN 50 018, sections 13.1 and 13.2, and for which a separate test certificate is available.
- Cable entries as well as sealing plugs of simple construction shall not be used. For connection of the flameproof terminal housing by means of an approved conduit entry the associated sealing facility must be arranged directly on the enclosure.
- 7. Non-used openings shall be sealed according to EN 50 018, section 11.9.
- 8. The PA terminal of the capacitive measuring probes with the barrier KLEMP2-2LPA/FFD (internal or external screw terminal) has to be connected with the potential equalization of the explosion hazardous area. Since the intrinsically safe circuits are galvanically connected with the earth potential, potential compensation has to exist in the complete course of the erection of the intrinsically safe operation and indication circuit.

### (18) Essential Health and Safety Requirements

no additional ones

TÜV NORD CERT GmbH, Langemarckstraße 20, 45141 Essen, accredited by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The head of the certification body

Schwedt

Hanover office, Am TÜV 1, 30519 Hanover, Tel.: +49 (0) 511 986-1455, Fax: +49 (0) 511 986-1590

### Translation

### (1) EC-Type Examination Certificate



(2) Equipment and protective systems intended for use in potentially explosive atmospheres - Directive 94/9/EC



(3) EC-Type Examination Certificate Number

### **TÜV 05 ATEX 2827 X**

(4) Equipment: Capacitive measuring probe type VEGACAL CL6\*.D \*\*P/FD\*

Manufacturer: VEGA Grieshaber KG (5)(6) Address: Am Hohenstein 113

D-77761 Schiltach

(7)This equipment or protective system and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

The TÜV NORD CERT GmbH & Co. KG, TÜV CERT-Certification Body, notified body number (8) N° 0032 in accordance with Article 9 of the Council Directive of the EC of March 23, 1994 (94/9/EC), certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential report N° 05 YEX 552076

(9)Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50 014:1997 + A1 + A2 EN 50 018:2000 + A1 EN 50 020:2002 EN 50 284:1999

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EC-type examination certificate relates only to the design, examination and tests of the specified equipment in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
- (12) The marking of the equipment or protective system must include the following:

(Ex) II 1/2 G or II 2 G EEx d ia IIC T6

TÜV NORD CERT GmbH & Co. KG Am TÜY 1

Hanover, 2005-06-08

30519 Hannover Tel.: +49 511 986-1470 Fax: +49 511 986-1590

Head of the **Certification Body** 



(13) SCHEDULE

### (14) EC-Type Examination Certificate N° TÜV 05 ATEX 2827 X

### (15) Description of equipment

The capacitive measuring probes type VEGACAL CL6\*.D\_\*\*P/FD\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive measuring probes type VEGACAL CL6\*.D\_\*\*P/FD\* consist of an electronic housing for the barrier with an Ex-d connection room, an Ex-i connection room with inserted measuring electronics, a process adapting element and a measuring sensor.

Mechanical execution of the capacitive measuring probes:

type	electrodes	
CL62.D_**P/FD*	partly insulated electrode, optionally with screening tube or concentric tube	
CL63.D_**P/FD*	fully insulated electrode, optionally plated	
CL64.D_**P/FD*	fully insulated electrode, optionally with screening tube, concentric tube or plated	
CL65.D_**P/FD*	partly insulated cable electrode optionally with additionally insulated cable	
CL66.D_**P/FD*	fully insulated cable electrode	

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas which require apparatus of the category 1 (electrode) and category 2 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range	
T6	-40°C +47 °C	-20°C +60 °C	
T5	-40°C +62 °C	-20°C +60 °C	
T4, T3, T2, T1	-40°C +74 °C	-20°C +60 °C	

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area, that requires apparatus of the category 1, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



### Schedule EC-Type Examination Certificate N° TÜV 05 ATEX 2827 X

If the capacitive measuring probes are mounted in explosion hazardous areas which require apparatus of the <u>category 2</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA-insulation	medium temperature range for other electrodes
T6	- 40°C + 47°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 62°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 74°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 74°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Electrical data

Supply and signal circuit (Terminals KI1/1, KI1/2; "d"-connection room) U = 9 ... 36 V d. c. $U_m = 253 V a. c.$ 

Operation and indication circuit (Terminals 5, 6, 7, 8 resp. plug connection in the "i"-connection room)

in type of protection "Intrinsic Safety "EEx ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (PTB 02 ATEX 2136 X)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_o = 2.4 \mu F$  $L_o = 160 \mu H$ 

Operation and indication module circuit (Spring contacts in the "i"connection room) in type of protection "Intrinsic Safety" EEx ia IIC only for connection to the VEGA operation and indication module (Plicscom)



### Schedule EC-Type Examination Certificate Nº TÜV 05 ATEX 2827 X

Communication circuit (I<sup>2</sup>C bus in the "i"-connection room)

in type of protection "Intrinsic Safety" EEx ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT3 (PTB 01 ATEX 2007)

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

All intrinsically safe circuits of the capacitive measuring probes with built-in barrier KLEMP2-2LPAD are safe galvanically separated from the non intrinsically safe supply and signal circuit and the parts which can be earthed.

- (16) The Test documents are listed in the test report N° 05 YEX 552076.
- (17) Special conditions for safe use
  - At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.C\_\*\*P/FD\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
  - For category 1/category 2 applications, at the metallic electrode parts of the capacitive
    measuring probes type VEGACAL CL6\*.C\_\*\*P/FD\* made of light metal there is a danger of
    ignition by impact or friction. Observe manual of the manufacturer.
  - For category 1/category 2 applications and at risks by pendulum or vibration the respective
    parts of the capacitive measuring probes type capacitive measuring probes type VEGACAL
    CL65.D\_\*\*P/FD\* and type VEGACAL CL66.D\_\*\*P/FD\* have to be secured effectively
    against these dangers.
  - For category 1/category 2 applications the medium tangent materials have to be resistant to the media.
  - The flameproof terminal housing shall be connected by means of suitable cable entries resp. conduit systems, which meet the requirements of EN 50 018, sections 13.1 and 13.2, and for which a separate test certificate is available.
  - Cable entries as well as sealing plugs of simple construction shall not be used. For connection of the flameproof terminal housing by means of an approved conduit entry the associated sealing facility must be arranged directly on the enclosure.
  - Non-used openings shall be sealed according to EN 50 018, section 11.9.
- (18) Essential Health and Safety Requirements

no additional ones