

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate	No.:

IECEx TUN 05 0008X

issue No.:6

Status:

Current

2017-09-12

Page 1 of 4

Capacitive continuous level measurement sensor type VEGACAL CL6\*.Cl \*\*\*H/X/P/F\*\*\*\*

Certificate history:

Issue No. 6 (2017-9-12)

Issue No. 5 (2014-8-7) Issue No. 4 (2010-5-5)

Issue No. 3 (2008-7-8)

Issue No. 2 (2007-11-21) Issue No. 1 (2006-11-7)

Applicant:

Date of Issue:

VEGA Grieshaber KG Am Hohenstein 113

77761 Schiltach

Equipment:

Optional accessory:

Type of Protection:

Intrinsic safety

Marking:

Ex ia IIC T6 ... T1 Ga, Ga/Gb, Gb

Approved for issue on behalf of the IECEx

Certification Body:

Meyer

Position:

Head of IECEx Certification Body

Signature:

(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:







Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2017-09-12

Issue No.: 6 Page 2 of 4

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

Additional Manufacturing location(s):

**VEGA Americas. Inc.** 4241 Allendorf Drive Cincinnati, Ohio 45209 United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011

Explosive atmospheres - Part 0: General requirements

Edition: 6.0

IEC 60079-11: 2011

Edition: 6.0

IEC 60079-26: 2014-

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

10

Explosive atmospheres - Part 26: Equipment with Equipment Protection Level (EPL) Ga

Edition: 3.0

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

DE/TUN/ExTR08.0020/04 IECEY OAR

DE/TUN/QAR06.0002/07

File Reference: 17 217 207384



# of Conformity

Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2017-09-12

Issue No.: 6

Page 3 of 4

Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive continuous level measurement sensors type VEGACAL CL6\*.CI \*\*\*H/X/P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The capacitive continuous level measurement sensors type VEGACAL CL6\*.Cl \*\*\*H/X/P/F\*\*\*\* consist of a single chamber housing or a double chamber housing, a process adapting element and a measuring sensor,

For further information see attachment.

### SPECIFIC CONDITIONS OF USE: YES as shown below:

- 1.At the plastic parts of the capacitive continuous level measurement sensors there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
- 2.For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive continuous level measurement sensors have to be secured effectively against these dangers. Observe manual of the manufacturer.
- 3. For zone 0 resp. zone 0/1 applications, at the metallic electrode parts of the capacitive continuous level measurement sensors made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- 4. For zone 0/1 applications the medium tangent materials have to be resistant to the media.



# of Conformity

_		
Cert	ificate	No.:

IECEx TUN 05.0008X

Date of Issue:

2017-09-12

Issue No.: 6

Page 4 of 4

### DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

See documentation of the manufacturer and attachment for details.

Annex: \_Attachment\_VEGACAL\_C\_X,H,P\_F\_ia\_TUN05.0008X.pdf



## Page 1 of 6 Attachment to IECEx TUN 05.0008 X issue 06

The capacitive continuous level measurement sensors type VEGACAL CL6\*.CI \*\*\*H/X/P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas. The measuring media are allowed to be combustible liquids, gases, mists or vapours. The capacitive continuous level measurement sensors type VEGACAL CL6\*.CI \*\*\*H/X/P/F\*\*\*\* consist of a single chamber housing or a double chamber housing, a process adapting element and a measuring sensor.

Mechanical basic execution of the electrodes:

Wiconamical Bacic	excedition of the electrodes.
Type	Electrodes
VEGACAL CL62	partly insulated rod electrode, optionally with screening tube or concentric tube
VEGACAL CL63	fully insulated rod electrode, optionally plated
VEGACAL CL64	fully insulated rod electrode for viscous and adhesive filling materials
VEGACAL CL65	partly insulated cable electrode optionally with abrasion protection
VEGACAL CL66	fully insulated cable electrode

## Electrical data

## Type VEGACAL CL6\*.CI \*\*\*X\*\*\*\*

Supply and signal circuit ..... (Terminals KI1[+], KI2[-]

in the electronics compartment of the single

chamber housing or

in the terminal compartment of the double chamber housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to a certified intrinsically safe circuit

maximum values:

U. = 30 W = 131 mA

= 983 mW

characteristic line: linear

effective internal capacitance: 3 nF

The effective internal inductances are negligibly small.

## Type VEGACAL CL6\*.CI \*\*\*H\*\*\*\*

Supply and signal circuit ..... (Terminals KI1[+], KI2[-]

in the electronics compartment of the single

chamber housing or

in the terminal compartment of the double chamber housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to a certified intrinsically safe circuit

maximum values:

= 30 V= 131 mA

= 983 mW

characteristic line: linear

The effective internal capacitance and inductances are negligibly small.

At connected electronics PLICSZEKX: Effective internal inductance: 5 µH



## Page 2 of 6 Attachment to IECEx TUN 05.0008 X issue 06

## Type VEGACAL CL6\*.CI \*\*\*P/F\*\*\*\*

Supply and signal circuit ......(Terminals Kl1[+], Kl2[-] in the electronics compartment of the single chamber housing or

in the terminal compartment of the double chamber housing)

in type of protection "Intrinsic Safety" Ex ia IIC maximum values:

 $U_i = 17.5 \text{ V}$   $I_i = 500 \text{ mA}$   $P_i = 5.5 \text{ W}$ 

The apparatus is suitable for connection to a fieldbus system according to the FISCO concept (IEC 60 079-27), e. g. Profibus PA or Foundation Fieldbus.

or

 $\begin{array}{lll} U_i & = & 24 & V \\ I_i & = & 250 & mA \\ P_i & = & 1.2 & W \end{array}$ 

The effective internal capacitance is negligibly small.

Effective internal inductance:  $5\,\mu H$  At connected electronics PLICSZEKX: Effective internal inductance:  $10\,\mu H$ 

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

## Type VEGACAL CL6\*.CI \*\*\*H/P/F\*\*\*\*

in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61/81

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_o = 2.4 \mu F$  $L_o = 160 \mu H$ 

Operation
and indication module circuit ......
(Spring contacts
in the electronics compartment of the
single chamber housing or
in the terminal compartment of the double
chamber housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (PLICSCOM)



## Page 3 of 6 Attachment to IECEx TUN 05.0008 X issue 06

lf

- the VEGA interface converter type VEGACONNECT and
- the external VEGA indication unit type VEGADIS61/81 are connected, the following maximum values of the connection cable to the VEGADIS61/81 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

### Thermal data

## Type VEGACAL CL6\*.CI \*\*\*X/H\*\*\*\*

If the capacitive continuous level measurement sensors are mounted in explosion hazardous areas which require apparatus of EPL Ga the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range (electronics) and medium temperature range (measuring sensor)	
T6	-20 ℃ +46 ℃	
T5, T4, T3, T2, T1	-20 ℃ +60 ℃	

The measuring sensors and the electronics of the capacitive continuous level measurement sensors are allowed to be operated in an explosion hazardous area, that requires apparatus of EPL Ga, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the measuring sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



## Page 4 of 6 Attachment to IECEx TUN 05.0008 X issue 06

If the capacitive continuous level measurement sensors are mounted in the partition wall between explosion hazardous areas which require apparatus of the <u>EPL Ga (electrode)</u> and EPL Gb (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor
Т6	-40 ℃ +46 ℃	
T5	-40 ℃+61 ℃	
T4		-20 °C+60 °C
Т3	-40 ℃+80 ℃	-20 C+60 C
T2		
T1		

The measuring sensors of the capacitive continuous level measurement sensors are allowed to be operated in an explosion hazardous area, that requires apparatus of the EPL Ga, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the measuring sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive continuous level measurement sensors are mounted in explosion hazardous areas which require apparatus of the <u>EPL Gb</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

		Medium temperatu	sensor	
Temperature	Ambient			PTFE insulation
class	temperature range	PE insulation	PTFE insulation	with temperature
				adapter
T6	-40 ℃ +46 ℃		-50 ℃ +85 ℃	-50 ℃ +85 ℃
T5	-40 ℃ +61 ℃		-50 ℃ +100 ℃	-50 ℃ +100 ℃
T4		-40 ℃ +80 ℃	-50 ℃ +135 ℃	-50 ℃ +135 ℃
T3	-40 ℃ +80 ℃	-40 C +60 C		
T2	-40 C +00 C		-50 ℃ +150 ℃	-50 ℃ +200 ℃
T1				

If the measuring sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.



## Page 5 of 6 Attachment to IECEx TUN 05.0008 X issue 06

## Type VEGACAL CL6\*.CI \*\*\*P/F\*\*\*\*

If the capacitive continuous level measurement sensors are mounted in explosion hazardous areas which require apparatus of the <u>EPL Ga</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range (electronics) and medium temperature range (measuring sensor)
T6	-20 ℃ +38 ℃
T5	-20 ℃ +53 ℃
T4, T3, T2, T1	-20 ℃ +60 ℃

The measuring sensors and the electronics of the capacitive continuous level measurement sensors are allowed to be operated in an explosion hazardous area, that requires apparatus of the EPL Ga, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar). If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the measuring sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive continuous level measurement sensors are mounted in the partition wall between explosion hazardous areas which require apparatus of the <u>EPL Ga (electrode) and EPL Gb (electronics)</u>, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range at measuring sensor
Т6	-40 ℃ +38 ℃	
T5	-40 ℃+53 ℃	
T4		-20 ℃+60 ℃
T3	-40 ℃+80 ℃	-20 C+00 C
T2		
T1		

The measuring sensors of the capacitive continuous level measurement sensors are allowed to be operated in an explosion hazardous area, that requires apparatus of the EPL Ga, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the measuring sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the



## Page 6 of 6 Attachment to IECEx TUN 05.0008 X issue 06

danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive continuous level measurement sensors are mounted in explosion hazardous areas which require apparatus of the <u>EPL Gb</u> the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

		Medium temperatu	re range at measuring sensor	
Temperature	Ambient			PTFE insulation
class	temperature range	PE insulation	PTFE insulation	with temperature
				adapter
T6	-40 ℃ +38 ℃		-50 ℃ +85 ℃	-50 ℃ +85 ℃
T5	-40 ℃ +53 ℃		-50 ℃ +100 ℃	-50 ℃ +100 ℃
T4		-40 ℃ +80 ℃	-50 ℃ +135 ℃	-50 ℃ +135 ℃
T3	-40 ℃ +80 ℃	-40 C +60 C		
T2	-40 C +00 C		-50 ℃ +150 ℃	-50 ℃ +200 ℃
T1				

If the measuring sensors of the capacitive continuous level measurement sensors are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

## Specific Conditions of Use

- At the plastic parts of the capacitive continuous level measurement sensors there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
- For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive continuous level measurement sensors have to be secured effectively against these dangers. Observe manual of the manufacturer.
- For zone 0 resp. zone 0/1 applications, at the metallic electrode parts of the capacitive continuous level measurement sensors made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- 4. For zone 0/1 applications the medium tangent materials have to be resistant to the media.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

0-40	t			
Certi	nca	le.	NO.	2

IECEx TUN 05.0007X

issue No.:3

Certificate history: Issue No. 3 (2010-5-5) Issue No. 2 (2008-7-4) Issue No. 1 (2006-12-6)

Status:

Current

Date of Issue:

2010-05-05

Page 1 of 5

Applicant:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

Electrical Apparatus: Optional accessory:

Capacitive Measuring Probe VEGACAL CL6\*.CI\*\*H\*\*

Type of Protection:

Intrinsic Safety

Marking:

Ex ia IIC T6 Ga, Ga/Gb, Gb

Approved for issue on behalf of the IECEx

Certification Body:

Karl-Heinz Schwedt

Position:

Head of IECEXCE

Signature:

(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TÜV NORD CERT GmbH Hanover Office Am TÜV 1 30519 Hannover Germany





Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2010-05-05

Issue No.: 3

Page 2 of 5

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

### Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2007-10

Explosive atmospheres - Part 0: Equipment - General requirements

Edition: 5

IEC 60079-11: 2006

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 5

IEC 60079-26: 2006

Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

Edition: 2

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

File Reference:

ExTR 08.0015/01

10 204 555744



Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2010-05-05

Issue No.: 3

Page 3 of 5

Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*H\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**H**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**H**	fully insulated electrode, optionally plated
CL64.CI**H**	fully insulated electrode, optionally with screening tube, concentric tube or pla
CL65.CI**H**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**H**	fully insulated cable electrode

CONDITIONS OF CERTIFICATION: YES as shown below:

See annexe



Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2010-05-05

Issue No.: 3

Page 4 of 5

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):			
See annexe			



Certificate No :

IECEx TUN 05.0007X

Date of Issue:

2010-05-05

Issue No.: 3

Page 5 of 5

### Additional information:

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

Communication circuit (I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Cer	titica	ta I	Vo.

IECEx TUN 05.0007X

issue No.:2

Page 1 of 5

Certificate history: Issue No. 2 (2008-7-4)

Status:

Current

Issue No. 1 (2006-12-6)

Date of Issue:

2008-07-04

Applicant:

VEGA Grieshaber KG

Am Hohenstein 113 D-77761 Schiltach

Germany

Electrical Apparatus:

Capacitive Measuring Probe VEGACAL CL6\*.CI\*\*\*H\*\*\*\*

Optional accessory:

---

Type of Protection:

Intrinsic Safety

Marking:

Zone 0, 0/1 Ex ia IIC T6

Approved for issue on behalf of the IECEx

Certification Body:

Karl-Heinz Schwedt

Position:

Signature: (for printed version)

Date:

Head of IECExCB

2000-07-0

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TÜV NORD CERT GmbH Hanover Office Am TÜV 1 30519 Hannover Germany





Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

Manufacturer:

2008-07-04

Germany

Issue No.: 2 Page 2 of 5

VEGA Grieshaber KG Am Hohenstein 113 D-77761 Schiltach

Manufacturing location(s): VEGA Grieshaber KG Am Hohenstein 113 D-77761 Schiltach Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

Electrical apparatus for explosive gas atmospheres - Part 0: General requirements IEC 60079-0: 2004

Edition: 4.0

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

IEC 60079-11: 2006 Edition: 1

IEC 60079-26: 2004

Electrical apparatus for explosve gas atmospheres - Part 26: Construction, test and

marking of Group II Zone 0 electrical apparatus

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

File Reference:

DE/TUN/ExTR08.0015/00

08 204 554574

IECEx QAR: DE/QAR/TUN/06.0002/00

**QAR TUN 04.0002** 



Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2008-07-04

Issue No : 2

Page 3 of 5

Schedule

### **EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*H\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

	type	electrodes
	CL62.CI**H**	partly insulated electrode, optionally with screening tube or concentric tube
	CL63.CI**H**	fully insulated electrode, optionally plated
	CL64.CI**H**	fully insulated electrode, optionally with screening tube, concentric tube or pla
$\overline{}$	CL65.CI**H**	partly insulated cable electrode optionally with additionally insulated cable
	CL66.CI**H**	fully insulated cable electrode

### CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.Cl\*\*H\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2008-07-04

Issue No.: 2

Page 4 of 5

DETAILS OF	CERTIFICATE	CHANGES (for issues	1 and above):

see annexe		



Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2008-07-04

Issue No.: 2

Page 5 of 5

### Additional information:

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

Communication circuit (I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx TUN 05.0007X	Issue No.: 1
Status:	Current	
Date of Issue:	2006-12-06	Page 1 of 6
Applicant:	VEGA Grieshaber KG Am Hohenstein 113 D-77761 Schiltach Germany	
Electrical Apparatus: Optional accessory:	Capacitive Measuring Probe	VEGACAL CL6*.CI**H**
Type of Protection:	Intrinsic Safety	
Marking:	Ex ia IIC T6	
Approved for issue o Certification Body:	n behalf of the IECEx	Karl-Heinz Schwedt
Position:		Head of IECExCB
Signature: (for printed version)		
Date:		
<ol><li>This certificate is n</li></ol>	d schedule may only be reproduce not transferable and remains the protection of this certificate may be	d in full. roperty of the issuing body. verified by visiting the Official IECEx Website.

Certificate issued by:

## TÜV NORD CERT GmbH & Co.

Am TUV1 D-30519 Hannover Germany





Certificate No.:

IECEx TUN 05,0007X

Date of Issue:

2006-12-06

Issue No.: 1

Page 2 of 6

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 D-77761 Schiltach Germany

Manufacturing location(s):

VEGA Grieshaber KG Am Hohenstein 113 D-77761 Schiltach Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacture'rs quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2000

Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

Edition: 3.1

IEC 60079-11: 1999

Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

Edition: 4

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

File Reference:

DE/TUN/05/551905

05YEX551905



Certificate No.:

**IECEX TUN 05.0007X** 

Date of Issue:

2006-12-06

Issue No.: 1

Page 3 of 6

## Schedule

## **EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*H\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**H**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**H**	fully insulated electrode, optionally plated
CL64.CI**H**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**H**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**H**	fully insulated cable electrode

## CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.CI\*\*H\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2006-12-06

Issue No.: 1

Page 4 of 6

### EQUIPMENT(continued):

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA- insulation	medium temperature range for other electrodes
T6	- 40°C + 57°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 72°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Electrical data

Supply and signal circuit (Terminals KI1[+], KI2[-] in the housing for the electronics resp., in the execution with the 2 cell housing, in the terminal housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to a certified intrinsically safe circuit maximum values:

U<sub>i</sub> = 30 V I<sub>i</sub> = 131 mA P<sub>i</sub> = 983 mW characteristic line: linear

The effective internal capacitances and inductances are negligibly small.

Operation and indication circuit (Terminals 5, 6, 7, 8 in the housing for the electronics resp., plug connection in the execution with the 2 cell housing) in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $Co = 2,4 \mu F$  $Lo = 160 \mu H$ 



Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2006-12-06

Issue No.: 1

Page 5 of 6

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

See annexe



Certificate No.:

**IECEX TUN 05.0007X** 

Date of Issue:

2006-12-06

Issue No.: 1

Page 6 of 6

### Additional information:

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

Communication circuit (I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

## TÜV NORD CERT GmbH & Co. KG Am TÜV 1 30519 Hannover



## Testing Laboratory Explosion Protected Equipment and Monitoring Devices

## Page 1 of 2 Issue No. 1 of IECEx TUN 05.0007 X

IECEx ATR:	File reference:	Colored and a south
DE/TUN/ExTR06.0061/00	06 TUN 553277	
IECEx QAR:	File reference:	
DE/QAR/TUN/06.0002/00	QAR TUN 04.0002	

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*H\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical and electrical construction of the measuring probes as well as to the electrical data.

Mechanical execution of the measuring probes:

Type	Electrodes		
CL62.CI**H**	partly insulated electrode, optionally with screening tube or concentric tube		
CL63.CI**H**	fully insulated electrode, optionally plated		
CL64.CI**H**	fully insulated electrode, optionally with screening tube, concentric tube or plated		
CL65.CI**H**	partly insulated cable electrode optionally with additionally insulated cable		
CL66.CI**H**	fully insulated cable electrode		
CL69.CI**H**	fully insulated 2-rod electrode		

### VEGACAL CL6\*.CI\*\*H3\*, VEGACAL CL6\*.CI\*\*H4\*, VEGACAL CL6\*.CI\*\*H5\*

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to a certified intrinsically safe circuit maximum values:

 $U_i = 30 \text{ V}$   $I_i = 131 \text{ mA}$ 

 $P_i = 983 \text{ mW}$ 

characteristic line: linear

The effective internal capacitances and inductances are negligibly small.

In the execution VEGACAL CL6\*.CI\*\*H3/4/5\* a value of Ci\_wire/wire = 58pF/m und Ci\_wire/shleid = 270pF/m

has to be taken into account.

In the execution VEGACAL CL6\*.CI\*\*H3/4/5\* a value of L´ = 55µH/m has to be taken into account.

## TÜV NORD CERT GmbH & Co. KG Am TÜV 1 30519 Hannover



## Testing Laboratory Explosion Protected Equipment and Monitoring Devices

### Page 2 of 2 Issue No. 1 of IECEx TUN 05.0007 X

Operation and indication circuit ........ (Terminals 5, 6, 7, 8 in the housing for the electronics resp., plug connection in the execution with the 2 cell housing) in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type

VEGADIS61 (IECEx PTB 06.0048)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $Co = 2.4 \mu F$  $Lo = 160 \mu H$ 

Communication circuit ......(I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

If

- the VEGA interface converter type VEGACONNECT and
- the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048) are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

 $C_o = 2.8 \mu F$  $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

All other details as well as the "Special conditions for safe use" apply unchanged for this supplement.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

^~	etifi.	001	hal	No.	

IECEx TUN 05.0007X

Issue No.: 0

Status:

Current

Date of Issue:

2005-03-18

Page 1 of 5

Applicant:

VEGA Grieshaber KG Am Hohenstein 113 D-77761 Schiltach Germany

Electrical Apparatus: Capacitive Measuring Probe VEGACAL CL6\*.Cl\*\*H\*\*

Optional accessory:

\_

Type of Protection:

Intrinsic Safety

Marking:

Fx is IIC T6

Approved for issue on behalf of the IECEx

Certification Body:

Karl-Heinz Schwedt

Position:

Head of IECExCB

Signature:

(for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

## **TÜV NORD CERT GmbH & Co. KG**

Am TUV1 D-30519 Hannover Germany





Cortificate No :

**IECEX TUN 05.0007X** 

Date of Issue:

2005-03-18

Issue No.: 0

Page 2 of 5

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 D-77761 Schiltach Germany

Manufacturing location(s):

VEGA Grieshaber KG Am Hohenstein 113 D-77761 Schiltach Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacture'rs quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2000

Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

IEC 60079-11: 1999

Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

Edition: 3.1 IEC 60079 Edition: 4

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

File Reference:

DE/TUN/05/551905

05YEX551905



Certificate No.: IECEx TUN 05.0007X

Date of Issue: 2005-03-18 Issue No.: 0

Page 3 of 5

## Schedule

#### **EQUIPMENT:**

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*H\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**H**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**H**	fully insulated electrode, optionally plated
CL64.CI**H**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**H**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**H**	fully insulated cable electrode

## CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.Cl\*\*H\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.:

IECEx TUN 05.0007X

Date of Issue:

2005-03-18

Issue No.: 0

Page 4 of 5

### **EQUIPMENT(continued):**

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA- insulation	medium temperature range for other electrodes
T6	- 40°C + 57°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 72°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

### Electrical data

Supply and signal circuit (Terminals KI1[+], KI2[-] in the housing for the electronics resp., in the execution with the 2 cell housing, in the terminal housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to a certified intrinsically safe circuit maximum values:

U<sub>i</sub> = 30 V I<sub>i</sub> = 131 mA P<sub>i</sub> = 983 mW characteristic line: linear

The effective internal capacitances and inductances are negligibly small.

Operation and indication circuit (Terminals 5, 6, 7, 8 in the housing for the electronics resp., plug connection in the execution with the 2 cell housing) in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $Co = 2,4 \mu F$  $Lo = 160 \mu H$ 



Certificate No.: IECEx TUN 05.0007X

Date of Issue: 2005-03-18 Issue No.: 0

Page 5 of 5

### Additional information:

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

Communication circuit (I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

Annexe:



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:

IECEx TUN 05.0008X

issue No.:5

Status:

Current

Date of Issue:

2014-08-07

Page 1 of 4

Certificate history:

Issue No. 5 (2014-8-7) Issue No. 4 (2010-5-5) Issue No. 3 (2008-7-8)

Issue No. 2 (2007-11-

21) Issue No. 1 (2006-11-7)

Applicant:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

Electrical Apparatus: Optional accessory:

Capacitive Measuring Probe type VEGACAL CL6\*(\*).CI\*\*\*P/F\*\*\*\*(\*)(\*)

Type of Protection:

Intrinsic safety

Marking:

Ex ia IIC T6 Ga, Ga/Gb, Gb

Approved for issue on behalf of the IECEx Certification Body:

Meyer

Position:

Head of IECEx Certification Body

Signature: (for printed version)

Date:

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

**TÜV NORD CERT GmbH Hanover Office** Am TÜV 1 30519 Hannover Germany





Certificate No :

IECEX TUN 05 0008X

Date of Issue:

2014-08-07

Issue No · 5

Page 2 of 4

Manufacturer

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

Additional Manufacturing location

VEGA Americas, Inc 4241 Allendorf Drive Cincinnati, Ohio 45209 United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2011

Explosive atmospheres - Part 0: General requirements

Edition: 6.0

IEC 60079-11: 2011

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 6.0

IEC 60079-26: 2006

Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

Edition: 2

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

DE/TUN/ExTR08.0020/03

**IECEX QAR** 

DE/TUN/QAR06.0002/05

File Reference:

14 217 141324



Certificate No.:	IECEx TUN 05.0008X	
Date of Issue:	2014-08-07	Issue No.: 5
		Page 3 of 4
	Schedule	
QUIPMENT: quipment and systems co	vered by this certificate are as follows:	*
ee annexe		
INDITIONS OF CERTIFI	CATION: YES as shown below:	
changed		62



Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2014-08-07

Issue No.: 5

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):



## Page 1 of 4 Annexe to IECEx TUN 05.0008X Issue 5

IECEx TR:	File reference:
DE/TUN/ExTR08.0020/03	14 217 141324
IECEx QAR:	
DE/TUN/QAR/06.0002/05	

In the future, the following changes are performed for Capacitive Measuring Probe type VEGACAL CL6\*(\*).CI\*\*\*P/F\*\*\*\*(\*)(\*):

- 1. Update to actual standards
- 2. Changes regarding technical and electrical data
- 3. Changes regarding electric diagram
- 4. Changes to the layout
- 5. New components used
- 6. Application with PLICSCOM 02 added
- 7. Application with VEGADIS81 added
- 8. Introduction of new cables
- 9. Changes of the type code/marking
- 10. New manufacturing location added

## Electrical data

Power supply and signal circuit: (Terminals 1[+], 2[-] in connection compartment; with double chamber housing version in connection compartment)

Ignition protection type intrinsic safety Ex ia IIC/IIB.

Only for connection to a certified, intrinsically safe circuit.

Maximum values:

 $U_i = 17.5 \text{ V}$   $I_i = 500 \text{ mA}$  $P_i = 5.5 \text{ W}$ 

The instrument is suitable for connection to a Fieldbus system according to the FISCO model, e. g. Profibus PA or Foundation Fieldbus.

or

 $U_i = 24 V$   $I_i = 250 \text{ mA}$   $P_i = 1.2 W$ 

Effective internal capacitance C<sub>i</sub> is negligible.

Effective internal inductance  $L_i \leq 5~\mu H$ . In the version with fix mounted connection cable  $C_{i~wire/wire} = 150~pF/m$ ,  $C_{i~wire/screen} = 270~pF/m$  and additionally  $L_i = 0.55~\mu H/m$  has to be taken into account.



## Page 2 of 4 Annexe to IECEx TUN 05.0008X Issue 5

Circuit between sensor unit and remote processing unit

Indicating and adjustment circuit: (terminals 5, 6, 7, 8 in electronics compartment or plug connection with double chamber housing version)

Indicating and adjustment module circuit: (spring contacts in the electronics compartment; additionally in the electronics compartment with double chamber housing version)

Capacitive measuring circuit (separate version)

In ignition protection "Intrinsic Safety" Ex ia IIC. With VEGADIF type DF65(\*).C\*\*\*\*\*\*\*P/F\*\*\*\*\*\*(\*)(\*) in the version with fix mounted cable on the sensor unit and external processing unit, the supplied cable between the processing unit and the sensor unit must not exceed a length of 47 m. In ignition protection type intrinsic safety

In ignition protection type intrinsic safety Ex ia IIC. For connection to the instrisically safe circuit of the associated external indicating unit VEGADIS 61/81 (IECEX PTB 06.0048).

The rules for the interconnection of intrinsically safe circuits between VEGACAL CL6\*(\*).Cl\*\*\*P/F\*\*\*\*(\*)(\*) and the external indicating and adjustment unit VEGADIS 61/81 are fulfilled, provided that the total inductance and total capacitance of the connection cable between VEGACAL CL6\*(\*).Cl\*\*\*P/F\*\*\*\*(\*)(\*) and the external indicating unit VEGADIS 61/81 L<sub>cable</sub>=100µH and C<sub>cable</sub>=2.4µF are not exceeded. Ignition protection type intrinsic safety Fx ia IIC

Only for connection to the intrinsically safe signal circuit of an interface converter VEGACONNECT.

Ignition protection type intrinsic safety Ex ia IIC.

Only for connection to the indication and adjustment module PLICSCOM.

With the double chamber housing version, the indicating and adjustment module may be either in the electronics housing or in the connection compartment.

Ignition protection type intrinsic safety Ex ia IIC

For the version with separate housing the length of the triax or coax connection cable between housing and electrode housing may not exceed 10 m.

The intrinsically safe circuit is galvanically isolated from the parts which can be grounded. The metallic parts of the sensor are electrically connected with the earth terminal.



## Page 3 of 4 Annexe to IECEx TUN 05.0008X Issue 5

For applications requiring instruments of EPL-Ga resp. EPL-Ga/Gb, the VEGACAL CL6\*(\*).Cl\*\*\*P/F\*\*\*\*(\*)(\*) is preferably connected to associated apparatus with galvanically isolated, intrinsically safe circuits.

The maximum permissible ambient temperatures depending on the temperature classes are specified in the following tables:

## EPL-Ga instruments:

Temperature class	Ambient temperature range of the sensor and electronics
T4, T3, T2, T1	-20°C +60°C

For applications requiring instruments EPL-Ga the pressure at the sensor probe must be between 0.8 bar to 1.1 bar.

The permissible operating temperatures and pressures without explosive atmosphere are mentioned in the manufacturer instructions.

## EPL-Ga/Gb instruments:

Temperature class	Ambient temperature on the electronics	Ambient temperature on the sensor
T6	-40°C +38°C	-20°C +60°C
T5	-40°C +53°C	-20°C +60°C
T4, T3, T2, T1	-40°C +80°C	-20°C +60°C

For applications requiring instruments EPL-Ga the pressure at the sensor probe must be between 0.8 bar to 1.1 bar. If the sensors of the capacitive probes are operated at higher temperatures as mentioned in the above table, appropriate measures need to be performed that the danger of ignition caused by these hot surfaces is excluded. The maximum permissible temperature on the electronics/housing should not exceed the values according to the above table. The application conditions during operation in the without explosive atmosphere are mentioned in the respective manufacturer instructions for each probe type.

### EPL-Gb instruments:

Temperature class	temperature on	Ambient temperature on the sensor with PE/PA insulation	other sensors	Ambient temperature on the other sensors with temperature adapter
T6	-40°C +38°C	-40°C +80°C	-50°C +85°C	-50°C +85°C
T5	-40°C +53°C	-40°C +80°C	-50°C +100°C	-50°C +100°C
T4	-40°C +80°C	-40°C +80°C	-50°C +135°C	-50°C +135°C
T3, T2, T1	-40°C +80°C	-40°C +80°C	-50°C +150°C	-50°C +200°C



## Page 4 of 4 Annexe to IECEx TUN 05.0008X Issue 5

If the sensors of the capacitive probes are operated at temperatures higher than those specified in the above table, appropriate measures need to be performed that the danger of ignition caused by these hot surfaces is excluded.

The maximum permissible temperature on the electronics/housing should not exceed the values according to the above table. The application conditions during operation in the without explosive atmosphere are mentioned in the manufacturer information.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

	Cer	tifica	te I	No.:
--	-----	--------	------	------

IECEx TUN 05.0008X

issue No.:4

Status:

Current

Date of Issue:

2010-05-05

Page 1 of 4

Certificate history:

Issue No. 4 (2010-5-5) Issue No. 3 (2008-7-8) Issue No. 2 (2007-11-

21)

Issue No. 1 (2006-11-7)

Applicant:

VEGA Grieshaber KG Am Hohenstein 113

77761 Schiltach

Germany

Electrical Apparatus: Optional accessory:

Capacitive Measuring Probe type VEGACAL CL6\*.CI\*\*PF\*\*

Type of Protection:

Intrinsic safety

Marking:

Ex ia IIC T6 Ga, Ga/Gb, Gb

Approved for issue on behalf of the IECEx

Certification Body:

Karl-Heinz Schwedt

Position:

Signature:

(for printed version)

Date:

Head of IECEXCE

1. This certificate and schedule may only be reproduced in full.

This certificate is not transferable and remains the property of the issuing body.
 The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TÜV NORD CERT GmbH Hanover Office Am TÜV 1 30519 Hannover Germany





Certificate No.:

IECEx TUN 05.0008X

Date of Issue

2010-05-05

Issue No.: 4

Page 2 of 4

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

#### Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2007-10

Explosive atmospheres - Part 0: Equipment - General requirements

Edition: 5

IEC 60079-11: 2006

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 5

IEC 60079-26: 2006

Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

Edition: 2

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

## **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

File Reference:

ExTR 08.0020/01

10 204 555742



Certificate No.: IECEx TUN 05.0008X

Date of Issue: 2010-05-05 Issue No.: 4

Page 3 of 4

Schedule

#### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*P/F\*\* are used for monitoring or control of filling levels in explosion hazardous areas. The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

	type	electrodes
	CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
	CL63.CI**P/F**	fully insulated electrode, optionally plated
Г	CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated
	CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
	CL66.CI**P/F**	fully insulated cable electrode

CONDITIONS OF CERTIFICATION: YES as shown below:

See annexe



Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2010-05-05

Issue No.: 4

Page 4 of 4

FAILS OF CERTIFICATE CHANGES (for issues 1 and above):	
annexe	

**IECEx Certification Body** 



## Page 1 of 1 Issue No. 4 of IECEx TUN 05.0008 X

IECEx ExTR:	File reference:
DE/TUN/ExTR08.0020/01	10 204 555742
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/01	QAR TUN 04.0002

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*\*P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical and electrical construction (new temperature adapter, new version of cable electrode, 2 chamber housing made of plastics; new PLICSCOM module and minor changes at the HF board) and the marking.

The marking reads as follows:

Ex ia IIC Tx Ga, Ga/Gb, Gb (Tx: see tables for temperature ranges in issue no. 3 of IECEx TUN 05.0008 X).

All other details remain unchanged.

## Special conditions for safe use:

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.CI\*\*\*P/F\*\*\*\* there
  is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and
  warning label.
- For zone 0 applications, at the metallic parts of the capacitive measuring probes type VEGACAL CL6\*.Cl\*\*\*P/F\*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- 3. For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the respective parts of the capacitive measuring probes type VEGACAL CL65.Cl\*\*\*P/F\*\*\*\* and type VEGACAL CL66.Cl\*\*\*P/F\*\*\*\* have to be secured effectively against these dangers. Observe manual of the manufacturer.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Cert	ificate	No.	

Date of Issue:

IECEx TUN 05.0008X

issue No.:3

Status:

Current

2008-07-08

Page 1 of 5

Issue No. 3 (2008-7-8) Issue No. 2 (2007-11-21)

Certificate history:

Issue No. 1 (2006-11-7)

Applicant:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach

Germany

Electrical Apparatus: Optional accessory: Capacitive Measuring Probe type VEGACAL CL6\*.CI\*\*\*P/F\*\*\*\*

Optional accessory

Type of Protection:

Intrinsic safety

Marking:

Zone 0, 0/1 Ex ia IIC T6

Approved for issue on behalf of the IECEx

Karl Heinz Schwedt

Certification Body:

Position:

Head of IECExCB

Signature:

(for printed version)

Date:

2008-07-08

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TÜV NORD CERT GmbH Hanover Office Am TÜV 1 30519 Hannover Germany





Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2008-07-08

Issue No.: 3

Page 2 of 5

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

### Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2004

Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

Edition: 4.0

IEC 60079-11: 2006

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 5 IEC 60079-26: 2004

Electrical apparatus for explosve gas atmospheres - Part 26: Construction, test and

Edition: 1

marking of Group II Zone 0 electrical apparatus

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEX ATR:

DE/TUN/ExTR08.0020/00 **IECEX OAR** DE/QAR/TUN/06.0002/00 File Reference:

08 204 554573

**QAR TUN 04.0002** 



Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2008-07-08

Issue No.: 3

Page 3 of 5

Schedule

#### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*P/F\*\* are used for monitoring or control of fillir hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**P/F**	fully insulated electrode, optionally plated
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or pla
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**P/F**	fully insulated cable electrode

## CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.CI\*\*P/F\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2008-07-08

Issue No.: 3

Page 4 of 5

DETAILS OF	CERTIFICATE	CHANGES (for issues 1	and above):

See annexe



Certificate No.:

IECEX TUN 05 0008X

Date of Issue:

2008-07-08

Issue No.: 3

Page 5 of 5

### Additional information:

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

Communication circuit (I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

**IECEx Certification Body** 



## Page 1 of 4 Issue No. 3 of IECEx TUN 05.0008 X

IECEx ExTR:	File reference:
DE/TUN/ExTR08.0020/00	08 204 554573
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR TUN 04.0002

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*\*P/F\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the type designation, the mechanical and electrical construction, the temperature range in the area of the electronics/of the medium, the special conditions for safe use and the marking.

The marking reads as follows: Zone 0, 0/1 Ex ia IIC Tx (see tables for temperature ranges).

Type designation and mechanical execution of the measuring probes:

Type	Electrodes
CL62.CI*** P/F ****	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI*** P/F ****	fully insulated electrode, optionally plated
CL64.CI*** P/F ****	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI*** P/F ****	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI*** P/F ****	fully insulated cable electrode
CL69.CI*** P/F ****	fully insulated 2-rod electrode

If the capacitive measuring probes are used in explosion hazardous areas of zone 0, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature	Medium temperature	
Temperature class	range	range	
T6	-20 °C +47 °C	-20°C +47 °C	
T5, T4, T3, T2, T1	-20 °C +60 °C	-20°C +60 °C	

The capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar). If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

**IECEx Certification Body** 



## Page 2 of 4 Issue No. 3 of IECEx TUN 05.0008 X

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas of the zone 0 (electrode) and zone 1 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

ı	Temperature class	Ambient temperature	Medium temperature
ı	Temperature class	range	range
ı	T6	-40 °C +47 °C	-20°C +60 °C
ı	T5	-40 °C +62 °C	-20°C +60 °C
ı	T4, T3, T2, T1	-40 °C +80 °C	-20°C +60 °C

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature at the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive measuring probes are mounted in explosion hazardous areas of the zone 1, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature	ambient	medium temperature	medium temperature
class	temperature range	range	range for other
		for electrodes with	electrodes
		PE/PA-insulation	
T6	- 40°C + 47°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 62°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

## **IECEx Certification Body**



## Page 3 of 4 Issue No. 3 of IECEx TUN 05.0008 X

## Electrical data

in type of protection "Intrinsic Safety" Ex ia IIC/IIB only for connection to a certified intrinsically safe circuit maximum values:

 $U_i = 17.5 \text{ V}$   $I_i = 500 \text{ mA}$  $P_i = 5.5 \text{ W}$ 

The apparatus is suitable for connection to a fieldbus system according to the FISCO concept (IEC 60 079-27), e. g. Profibus PA or Foundation Fieldbus.

or

 $U_i = 24 \text{ V}$   $I_i = 250 \text{ mA}$  $P_i = 1.2 \text{ W}$ 

The effective internal capacitance is negligibly small. effective internal inductance:  $5~\mu H$ 

In the execution VEGACAL CL62.Cl\*\*\* P/F3/4/5/9\*\*\* a value of Ci´wire/wire = 58pF/m und Ci´wire/shield = 270pF/m has to be taken into account. In the execution

VEGACAL CL6\*. Cl\*\*\* P/F3/4/5/9\*\*\* a value of Li' = 55µH/m has to be taken into account additionally.

Operation and indication circuit ...... (Terminals 5, 6, 7, 8 in the housing for the electronics resp., plug connection in the execution with the 2 cell housing) in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (IECEX PTB 06.0048)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

Co =  $2.4 \mu F$ Lo =  $160 \mu H$ 

**IECEx Certification Body** 



## Page 4 of 4 Issue No. 3 of IECEx TUN 05.0008 X

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

lf

- the VEGA interface converter type VEGACONNECT and

- the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

 $C_o = 2.8 \mu F$  $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

All other details remain unchanged.

## Special conditions for safe use:

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.Cl\*\*\*P/F\*\*\*\* there
  is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and
  warning label.
- For zone 0 applications, at the metallic parts of the capacitive measuring probes type VEGACAL CL6\*.Cl\*\*\*P/F\*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the respective parts
  of the capacitive measuring probes type VEGACAL CL65.Cl\*\*\*P/F\*\*\*\* and type VEGACAL
  CL66.Cl\*\*\*P/F\*\*\*\* have to be secured effectively against these dangers. Observe manual of the
  manufacturer.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

	- (	æı	rtı	Tue	`A	te:
Certificate						

IECEx TUN 05.0008X

issue No :2

Status

Current

Certificate history Issue No. 2 (2007-11-21) Issue No. 1 (2006-11-7)

Date of Issue:

2007-11-21

Page 1 of 6

Applicant:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

Electrical Apparatus: Optional accessory:

Capacitive Measuring Probe type VEGACAL CL6\*.CI\*\*PF\*\*

Type of Protection:

Intrinsic safety

Marking:

Ex ia IIC T6

Karl Heinz Schwedt

Approved for issue on behalf of the IECEx Certification Body:

Head of IECExCB

Position:

Signature:

(for printed version)

Date:

00

This certificate and schedule may only be reproduced in full.
 This certificate is not transferable and remains the property of the issuing body.
 The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by

TÜV NORD CERT GmbH & Co. KG Am TUV1 D-30519 Hannover Germany





Certificate No.: IECEx TUN 05.0008X

Date of Issue: 2007-11-21 Issue No.: 2

Page 2 of 6

Manufacturer: VEGA Grieshaber KG

Am Hohenstein 113 77761 Schiltach Germany

#### Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2000 Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

Edition: 3.1

IEC 60079-11: 1999 Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety T

Edition: A

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR: File Reference: DE/TUN/05/551991 05 TUN 551991



Certificate No.: IECEx TUN 05.0008X

Date of Issue: 2007-11-21 Issue No.: 2

Page 3 of 6

Schedule

#### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*PIF\*\* are used for monitoring or control of filling levels in explosion hazardous areas. The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**P/F**	fully insulated electrode, optionally plated
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**P/F**	fully insulated cable electrode

## CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\* Cl\*\*P/F\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.:

2007-11-21

IECEx TUN 05.0008X

Issue No.: 2

Page 4 of 6

EQUIPMENT(continued):

Date of Issue:

Only changes regarding the formatting; see annexe



Certificate No.: IECEx TUN 05.0008X

Date of Issue: 2007-11-21

Issue No.: 2 Page 5 of 6

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Only changes regarding the formatting; see annexe



Certificate No.: IECEx TUN 05.0008X

Date of Issue: 2007-11-21 Issue No.: 2

Page 6 of 6

Additional information:

Only changes regarding the formatting; see annexe

## TÜV NORD CERT GmbH & Co. KG Am TÜV 1 30519 Hannover



## Testing Laboratory Explosion Protected Equipment and **Monitoring Devices**

## Page 1 of 2 Issue No. 1 of IECEx TUN 05,0008 X

IECEx ATR: File reference:	
DE/TUN/ExTR06.0044/01	06 TUN 553279
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*P/F\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical and electrical construction of the measuring probes as well as to the electrical data.

Mechanical execution of the measuring probes

Type	Electrodes
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**P/F**	fully insulated electrode, optionally plated
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**P/F**	fully insulated cable electrode
CL69.CI**P/F**	fully insulated 2-rod electrode

## Electrical data

## VEGACAL CL6\*.C\_\*\*P/F3\*, VEGACAL CL6\*.C\_\*\*P/F4\*, VEGACAL CL6\*.C\_\*\*P/F5\*

electronics resp., in the execution with the 2 cell housing, at the terminal housing)

Supply and signal circuit ...... in type of protection "Intrinsic Safety" Ex ia IIC/IIB (Connection cable at the housing for the only for connection to a certified intrinsically safe circuit

maximum values:

 $U_1 = 17.5 \text{ V}$  $I_i = 500 \text{ mA}$ 

 $P_1 = 5.5 \text{ W}$ 

The apparatus is suitable for connection to a fieldbus system according to the FISCO concept (IEC 60 079-27), e. g. Profibus PA or Foundation Fieldbus.

## TÜV NORD CERT GmbH & Co. KG Am TÜV 1 30519 Hannover



## Testing Laboratory Explosion Protected Equipment and **Monitoring Devices**

## Page 2 of 2 Issue No. 1 of IECEx TUN 05,0008 X

 $U_i = 24$  $l_{i} = 250 \text{ mA}$  $P_{i} = 1.2 \text{ W}$ 

In the execution VEGACAL CL6\*.C \*\*P/F3/4/5\* a value of Ci' wire/wire = 58pF/m und Ci' wire/shield = 270pF/m has to be taken into account. effective internal inductance: 5 µH The effective internal capacitance is negligibly small. In the execution VEGACAL CL6\*.C \*\*P/F3/4/5\* a value of Li' = 55µH/m has to be taken into account additionally.

Operation and indication circuit ...... in type of protection "Intrinsic Safety" Ex ia IIC (Terminals 5, 6, 7, 8 in the housing for the electronics resp. plug connection in the execution with the 2 cell housing)

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_0 = 2.4 \mu F$  $L_0 = 160 \mu H$ 

Communication circuit ..... (I2C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

- the VEGA interface converter type VEGACONNECT and

- the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

All other details as well as the "Special conditions for safe" use apply unchanged for this supplement.



Ex ia IIC/IIB

## Testing Laboratory Explosion Protected Equipment and Monitoring Devices

## Page 1 of 2 Issue No. 2 of IECEx TUN 05.0008 X

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*P/F\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**P/F**	fully insulated electrode, optionally plated
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**P/F**	fully insulated cable electrode

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA- insulation	medium temperature range for other electrodes
T6	- 40°C + 47°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 62°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

## Electrical data

Supply and signal circuit (Terminals KI1[+], KI2[-] in the housing for the electronics resp., in the execution with the 2 cell housing, in the terminal housing)

in type of protection "Intrinsic Safety" maximum values:

 $U_i = 17.5 \text{ V}$  $I_i = 500 \text{ mA}$ 

 $P_1 = 5.5 \text{ W}$ 

The apparatus is suitable for connection to a fieldbus system according to the FISCO concept (IEC 60 079-27), e. g. Profibus PA or Foundation Fieldbus.

or

U<sub>i</sub> = 24 V I<sub>i</sub> = 250 mA P<sub>i</sub> = 1.2 W

The effective internal capacitance is negligibly small. effective internal inductance: 5  $\mu H$ 



## Testing Laboratory Explosion Protected Equipment and Monitoring Devices

## Page 2 of 2 Issue No. 2 of IECEx TUN 05.0008 X

Operation and indication circuit (Terminals 5, 6, 7, 8 in the housing for the electronics resp., plug connection in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_0 = 2.4 \mu F$  $L_0 = 160 \mu H$ 

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

#### Communication circuit

(I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing) in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

#### Conditions of Certification

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.Cl\*\*P/F\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Ex ia IIC/IIB

## Testing Laboratory Explosion Protected Equipment and Monitoring Devices

## Page 1 of 2 Issue No. 2 of IECEx TUN 05.0008 X

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*P/F\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**P/F**	fully insulated electrode, optionally plated
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**P/F**	fully insulated cable electrode

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA- insulation	medium temperature range for other electrodes
T6	- 40°C + 47°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 62°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

## Electrical data

Supply and signal circuit

(Terminals KI1[+], KI2[-] in the housing for the electronics resp., in the execution with the 2 cell housing, in the terminal housing) in type of protection "Intrinsic Safety"

maximum values:  $U_i = 17.5 \text{ V}$ 

 $I_i = 500 \text{ mA}$  $P_i = 5.5 \text{ W}$ 

The apparatus is suitable for connection to a fieldbus system according to the FISCO concept (IEC 60 079-27), e. g. Profibus PA or Foundation Fieldbus.

or

 $U_i = 24 V$   $I_i = 250 mA$  $P_i = 1.2 W$ 

The effective internal capacitance is negligibly small. effective internal inductance: 5  $\mu H$ 



## Testing Laboratory Explosion Protected Equipment and Monitoring Devices

## Page 2 of 2 Issue No. 2 of IECEx TUN 05.0008 X

Operation and indication circuit (Terminals 5, 6, 7, 8 in the housing for the electronics resp., plug connection in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

The interconnection of the both intrinsically safe circuits was taken

into account.

maximum values of the connection cable:

 $C_o = 2.4 \mu F$  $L_o = 160 \mu H$ 

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

#### Communication circuit

(I²C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

## Conditions of Certification

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.CI\*\*P/F\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx TUN 05.0008X	Issue No.: 1
Status:	Current	
Date of Issue:	2006-11-07	Page 1 of 6
Applicant:	VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany	
Electrical Apparatus: Optional accessory:	Capacitive Measuring Probe ty	pe VEGACAL CL6*.CI**PF**
Type of Protection:	Intrinsic safety	
Marking:	Ex ia IIC T6	
Approved for issue of Certification Body:	on behalf of the IECEx	Karl Heinz Schwedt
Position:		Head of IECExCB
Signature: (for printed version)		
Date:		
2. This certificate is	d schedule may only be reproduced not transferable and remains the pro uthenticity of this certificate may be v	in full. perty of the issuing body. erified by visiting the Official IECEx Website.
Certificate issued by		
TÜV NO	RD CERT Gmbl	1 & Co.

Am TUV1 **TUV NORD** D-30519 Hannover Germany



Certificate No.:

**IECEx TUN 05.0008X** 

Date of Issue:

2006-11-07

Issue No · 1

Page 2 of 6

Manufacturer:

**VEGA Grieshaber KG** Am Hohenstein 113 77761 Schiltach Germany

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacture is quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

## STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2000

Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

Edition: 3.1 Edition: 4

IEC 60079-11: 1999

Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

## **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEX ATR:

File Reference:

DE/TUN/05/551991

05 TUN 551991



Certificate No.:

Date of Issue: 2006-11-07

IECEx TUN 05.0008X

Issue No.: 1
Page 3 of 6

## Schedule

#### EQUIPMENT

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*P/F\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes	
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube	
CL63.CI**P/F**	fully insulated electrode, optionally plated	
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated	
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable	
CL66.CI**P/F**	fully insulated cable electrode	

## CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.CI\*\*P/F\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.: IECEx TUN 05.0008X

Date of Issue: 2006-11-07 Issue No.: 1

Page 4 of 6

#### EQUIPMENT(continued):

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA- insulation	medium temperature range for other electrodes
T6	- 40°C + 47°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 62°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

## Electrical data

Supply and signal circuit

(Terminals KI1[+], KI2[-] in the housing for the electronics resp., in the execution with the 2 cell housing, in the terminal

housing)

in type of protection "Intrinsic Safety"

maximum values: U<sub>i</sub> = 17.5 V

= 500 mA

The apparatus is suitable for connection to a fieldbus system according to the FISCO concept (IEC 60 079-27), e. g. Profibus PA or Foundation Fieldbus.

Ex ia IIC/IIB

or.

 $U_i = 24 V$   $I_i = 250 mA$ 

P. = 1.2 W

The effective internal capacitance is negligibly small. effective internal inductance: 5 µH

Operation and indication circuit (Terminals 5, 6, 7, 8 in the housing for the electronics resp., plug connection in the execution with the 2 cell housing) in type of protection "Intrinsic Safety" Ex ia III only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_0 = 2.4 \mu F$  $L_1 = 160 \mu H$ 



Certificate No.:

**IECEx TUN 05.0008X** 

Date of Issue:

2006-11-07

Issue No.: 1

Page 5 of 6

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

See annexe



Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2006-11-07

Issue No.: 1

Page 6 of 6

### Additional information:

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

Communication circuit (I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.



### Testing Laboratory Explosion Protected Equipment and **Monitoring Devices**

### Page 1 of 2 Issue No. 1 of IECEx TUN 05,0008 X

IECEx ATR:	File reference:
DE/TUN/ExTR06.0044/01	06 TUN 553279
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*P/F\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical and electrical construction of the measuring probes as well as to the electrical data.

Mechanical execution of the measuring probes

Type	Electrodes
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**P/F**	fully insulated electrode, optionally plated
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**P/F**	fully insulated cable electrode
CL69.CI**P/F**	fully insulated 2-rod electrode

### Electrical data

### VEGACAL CL6\*.C \*\*P/F3\*, VEGACAL CL6\*.C \*\*P/F4\*, VEGACAL CL6\*.C \*\*P/F5\*

electronics resp., in the execution with the 2 cell housing, at the terminal housing)

Supply and signal circuit ...... in type of protection "Intrinsic Safety" Ex ia IIC/IIB (Connection cable at the housing for the only for connection to a certified intrinsically safe circuit

maximum values:

 $U_1 = 17.5 \text{ V}$  $I_i = 500 \text{ mA}$  $P_{i} = 5.5 \text{ W}$ 

The apparatus is suitable for connection to a fieldbus

system according to the FISCO concept

(IEC 60 079-27), e. g. Profibus PA or Foundation

Fieldbus.



### Testing Laboratory Explosion Protected Equipment and **Monitoring Devices**

### Page 2 of 2 Issue No. 1 of IECEx TUN 05.0008 X

 $U_1 = 24$ = 250 mA $P_{i} = 1.2 \text{ W}$ 

In the execution VEGACAL CL6\*.C \*\*P/F3/4/5\* a value of Ci' wire/wire = 58pF/m und Ci' wire/shield = 270pF/m has to be taken into account. effective internal inductance: 5 µH The effective internal capacitance is negligibly small. In the execution VEGACAL CL6\*.C \*\*P/F3/4/5\* a value of Li' = 55µH/m has to be taken into account additionally.

Operation and indication circuit ...... in type of protection "Intrinsic Safety" Ex ia IIC (Terminals 5, 6, 7, 8 in the housing for the electronics resp. plug connection

in the execution with the 2 cell housing)

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

(IECEx PTB 06.0048)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_0 = 2.4 \mu F$  $L_0 = 160 \mu H$ 

(I2C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

Communication circuit ...... in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

- the VEGA interface converter type VEGACONNECT and

- the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048)

are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

All other details as well as the "Special conditions for safe" use apply unchanged for this supplement.



### Testing Laboratory Explosion Protected Equipment and **Monitoring Devices**

### Page 1 of 2 Issue No. 1 of IECEx TUN 05.0008 X

IECEx ATR:	File reference:
DE/TUN/ExTR06.0044/01	06 TUN 553279
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR/TUN/QAR06.0002/00

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*P/F\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical and electrical construction of the measuring probes as well as to the electrical data.

Mechanical execution of the measuring probes

Туре	Electrodes
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**P/F**	fully insulated electrode, optionally plated
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**P/F**	fully insulated cable electrode
CL69.CI**P/F**	fully insulated 2-rod electrode

### Electrical data

### VEGACAL CL6\*.C\_\*\*P/F3\*, VEGACAL CL6\*.C\_\*\*P/F4\*, VEGACAL CL6\*.C\_\*\*P/F5\*

electronics resp., in the execution with the 2 cell housing, at the terminal housing)

Supply and signal circuit ...... in type of protection "Intrinsic Safety" Ex ia IIC/IIB (Connection cable at the housing for the only for connection to a certified intrinsically safe circuit

maximum values:

 $U_i = 17.5 \text{ V}$  $I_i = 500 \text{ mA}$  $P_i = 5.5 \text{ W}$ 

The apparatus is suitable for connection to a fieldbus

system according to the FISCO concept

(IEC 60 079-27), e. g. Profibus PA or Foundation

Fieldbus.



### Testing Laboratory Explosion Protected Equipment and **Monitoring Devices**

Page 2 of 2 Issue No. 1 of IECEx TUN 05.0008 X

> $U_i = 24$ = 250 mA  $P_{i} = 1.2 \text{ W}$

In the execution VEGACAL CL6\*.C\_\*\*P/F3/4/5\* a value of Ci' wire/wire = 58pF/m und Ci' wire/shield = 270pF/m has to be taken into account. effective internal inductance: 5 µH

The effective internal capacitance is negligibly small. In the execution VEGACAL CL6\*.C\_\*\*P/F3/4/5\* a value of Li' = 55uH/m has to be taken into account

additionally.

(Terminals 5, 6, 7, 8 in the housing for the electronics resp.

plua connection in the execution with the

2 cell housing)

Operation and indication circuit ...... in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type

VEGADIS61

(IECEx PTB 06.0048)

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

 $C_0 = 2.4 \text{ uF}$  $L_0 = 160 \mu H$ 

(I2C bus in the housing for the electronics and additionally

in the terminal housing

in the execution with the 2 cell housing)

Communication circuit ...... in type of protection "Intrinsic Safety" Ex ia IIC

only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

- the VEGA interface converter type VEGACONNECT and
- the external VEGA indication unit type VEGADIS61 (IECEx PTB 06.0048) are connected, the following maximum values of the connection cable to the VEGADIS61 do result:

$$C_o = 2.8 \mu F$$
  
 $L_o = 100 \mu H$ 

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

All other details as well as the "Special conditions for safe" use apply unchanged for this supplement.



### INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.lecex.com

Certificate No.:	IECEx TUN 05.0008X	Issue No.: 0
Status:	Current	
Date of Issue:	2005-05-11	Page 1 of 5
Applicant:	VEGA Grieshaber KG Am Hohenstein 113 77761 Schilitach Germany	
Electrical Apparatus: Optional accessory:	Capacitive Measuring Probe type VEGAC	CAL CL6*.CI**PF**
Type of Protection:	Intrinsic safety	
Marking:	Ex ia IIC T6	
Approved for issue on Certification Body:	behalf of the IECEx	Herbert Stürwold
Position:		Head of IECExCB
Signature: (for printed version)		
Date:		
<ol><li>This certificate is no</li></ol>	schedule may only be reproduced in full. It transferable and remains the property of the iss nenticity of this certificate may be verified by visiti	suing body. ing the Official IECEx Website.

Certificate issued by:

### TÜV NORD CERT GmbH & Co. KG

Am TUV1 D-30519 Hannover Germany





Certificate No.:

IECEX TUN 05.0008X

Date of Issue:

2005-05-11

Issue No.: 0

Page 2 of 5

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacture'rs quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Do as amended.

#### STANDARDS:

Edition: 3.1

Edition: 4

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2000

Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

IEC 60079-11: 1999

Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEX ATR:

File Reference:

DE/TUN/05/551991

05 TUN 551991



Certificate No.:

IECEx TUN 05.0008X

Date of Issue:

2005-05-11

Issue No.: 0

Page 3 of 5

### Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*P/F\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**P/F**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**P/F**	fully insulated electrode, optionally plated
CL64.CI**P/F**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**P/F**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**P/F**	fully insulated cable electrode

### CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.Cl\*\*P/F\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.:

**IECEX TUN 05.0008X** 

Date of Issue:

2005-05-11

Issue No.: 0

Page 4 of 5

#### EQUIPMENT(continued):

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA- insulation	medium temperature range for other electrodes
T6	- 40°C + 47°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 62°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m.

#### Electrical data

Supply and signal circuit (Terminals KI1[+], KI2[-] in the housing for the electronics resp., in the execution with the 2 cell housing, in the terminal housing)

in type of protection "Intrinsic Safety" maximum values:

W

Ex ia IIC/IIB

The apparatus is suitable for connection to a fieldbus system according to the FISCO concept (IEC 60 079-27), e. g. Profibus PA or Foundation Fieldbus.

$$U_i = 24 V$$
  
 $I_i = 250 mA$   
 $P_i = 1.2 W$ 

The effective internal capacitance is negligibly small. effective internal inductance: 5 µH

Operation and indication circuit (Terminals 5, 6, 7, 8 in the housing for the electronics resp., plug connection in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe circuit of the belonging external VEGA indication unit type VEGADIS61

The interconnection of the both intrinsically safe circuits was taken into account.

maximum values of the connection cable:

$$C_o = 2,4 \mu F$$
  
 $L_o = 160 \mu H$ 



Certificate No.:

**IECEX TUN 05.0008X** 

Date of Issue:

2005-05-11

Issue No.: 0

Page 5 of 5

### Additional information:

Operation and indication module circuit (Spring contacts in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the VEGA operation and indication module (Plicscom)

In the execution with the 2 cell housing the VEGA operation and indication module may only be implemented either in the housing for the electronics or in the terminal housing.

Communication circuit (I<sup>2</sup>C bus in the housing for the electronics and additionally in the terminal housing in the execution with the 2 cell housing)

in type of protection "Intrinsic Safety" Ex ia IIC only for connection to the intrinsically safe signal circuit of the VEGA interface converter type VEGACONNECT

The VEGA interface converter may only be operated together with the capacitive measuring probe, if no explosion hazardous atmosphere exists.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

Annexe:



### INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certific	ate i	Nō.	
----------	-------	-----	--

IECEx TUN 05.0002X

issue No.:2

Certificate history: Issue No. 2 (2010-5-5) Issue No. 1 (2008-7-4) Issue No. 0 (2005-2-23)

Status:

Current

2010-05-05

Page 1 of 4

Date of Issue:
Applicant:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

Electrical Apparatus: Optional accessory: Capacitive measuring probe VEGACAL CL6\*.Cl\*\*X\*\*

Type of Protection:

Intrinsic safety

Marking:

Ex ia IIC T6 Ga, Ga/Gb, Gb

Approved for issue on behalf of the IECEx

Certification Body:

Karl-Heinz Schwedt

Position:

Signature:

(for printed version)

Date:

Head of IECExCB

2010-05-05

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TÜV NORD CERT GmbH Hanover Office Am TÜV 1 30519 Hannover Germany





Certificate No :

IECEx TUN 05.0002X

Date of Issue:

2010-05-05

Issue No.: 2

Page 2 of 4

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

#### Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2007-10

Explosive atmospheres - Part 0: Equipment - General requirements

Edition: 5

IEC 60079-11: 2006

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 5

IEC 60079-26 : 2006

Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

Edition: 2

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

File Reference:

ExTR 08.0018/01

10 204 555743



Certificate No.:

IECEx TUN 05.0002X

Date of Issue:

2010-05-05

Issue No.: 2

Page 3 of 4

Schedule

#### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*X\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes	
CL62.CI**X**	partly insulated electrode, optionally with screening tube or concen	
CL63.CI**X**	fully insulated electrode, optionally plated	
CL64.CI**X**	fully insulated electrode, optionally with screening tube, concentric tube of	
CL65.CI**X**	partly insulated cable electrode optionally with additionally insulated cable	
CL66.CI**X**	fully insulated cable electrode	

### CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.CI\*\*X\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.:

IECEx TUN 05.0002X

Date of Issue:

2010-05-05

Issue No.: 2

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

See annexe

**IECEx Certification Body** 



### Page 1 of 1 Issue No. 2 of IECEx TUN 05.0002 X

IECEx ExTR:	File reference:
DE/TUN/ExTR08.0018/01	10 204 555743
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/01	QAR TUN 04.0002

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*\*X\*\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the mechanical construction (new temperature adapter, new version of cable electrode, 2 chamber housing made of plastics) and the marking.

The marking reads as follows:

Ex ia IIC Tx Ga, Ga/Gb, Gb (Tx: see tables for temperature ranges in issue no. 1 of IECEx TUN 05.0002 X).

All other details remain unchanged.

### Special conditions for safe use:

- At the plastic parts of the capacitive measuring probes type VEGACAL CP6\*.CI\*\*\*X\*\*\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.
- For zone 0 applications, at the metallic parts of the capacitive measuring probes type VEGACAL CP6\*.CI\*\*\* X \*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the respective parts
  of the capacitive measuring probes type VEGACAL CP65.CI\*\*\* X \*\*\*\* and type VEGACAL
  CP66.CI\*\*\* X \*\*\*\* have to be secured effectively against these dangers. Observe manual of the
  manufacturer



### INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Cert		

IECEx TUN 05.0002X

issue No.:1

Issue No. 1 (2008-7-4) Issue No. 0 (2005-2-23)

Status:

Current

Page 1 of 5

Date of Issue:

Applicant:

2008-07-04

VEGA Grieshaber KG

Am Hohenstein 113 77761 Schiltach Germany

Electrical Apparatus:

Capacitive measuring probe VEGACAL CL6\*.CI\*\*\*X\*\*\*\*

Optional accessory:

Type of Protection:

Intrinsic safety

Marking:

Zone 0, 0/1 Ex ia IIC T6

Approved for issue on behalf of the IECEx Certification Body:

Karl-Heinz Schwedt

Position:

....

Signature: (for printed version)

Date:

Head of IECExCB

1. This certificate and schedule may only be reproduced in full.

2. This certificate is not transferable and remains the property of the issuing body.

3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

TÜV NORD CERT GmbH Hanover Office Am TÜV 1 30519 Hannover Germany





Certificate No.:

IECEx TUN 05.0002X

Date of Issue:

2008-07-04

Issue No.: 1

Page 2 of 5

Manufacturer:

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany

#### Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

#### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2004 Edition: 4.0

Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

IEC 60079-11: 2006

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition: 5

IEC 60079-26: 2004

Electrical apparatus for explosve gas atmospheres - Part 26: Construction, test and

Edition: 1

marking of Group II Zone 0 electrical apparatus

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEX ATR:

DE / TUN / 08.0018/00 **IECEx QAR** DE/QAR/TUN/06.0002/00 File Reference: 08 204 554572

**QAR TUN 04.0002** 



Certificate No.:

IECEx TUN 05.0002X

Date of Issue:

2008-07-04

Issue No.: 1

Page 3 of 5

Schedule

### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*X\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**X**	partly insulated electrode, optionally with screening tube or concentric tul
CL63.CI**X**	fully insulated electrode, optionally plated
CL64.CI**X**	fully insulated electrode, optionally with screening tube, concentric tube of
CL65.CI**X**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**X**	fully insulated cable electrode

### CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.CI\*\*X\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No :

IECEx TUN 05.0002X

Date of Issue:

2008-07-04

Issue No.: 1

Page 4 of 5

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

See annexe



Certificate No.:

IECEx TUN 05.0002X

Date of Issue:

2008-07-04

Issue No.: 1

Page 5 of 5

Additional information:

none

**IECEx Certification Body** 



### Page 1 of 3 Issue No. 1 of IECEx TUN 05.0002 X

IECEx ExTR:	File reference:	
DE/TUN/ExTR08.0018/00	08 204 554572	
IECEx QAR:	File reference:	
DE/QAR/TUN/06.0002/00	QAR TUN 04.0002	

The capacitive measuring probes type VEGACAL CL6\*.Cl\*\*\*X\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the type designation, the mechanical and electrical construction, the temperature range in the area of the electronics/of the medium, the special conditions for safe use and the marking.

The marking reads as follows: Zone 0, 0/1 Ex ia IIC Tx (see tables for temperature ranges).

Type designation and mechanical execution of the measuring probes:

Type	Electrodes	
CL62.CI***X****	partly insulated electrode, optionally with screening tube or concentric tube	
CL63.CI***X****	fully insulated electrode, optionally plated	
CL64.CI***X****	fully insulated electrode, optionally with screening tube, concentric tube or plated	
CL65.CI***X****	partly insulated cable electrode optionally with additionally insulated cable	
CL66.CI***X****	fully insulated cable electrode	
CL69.CI***X****	fully insulated 2-rod electrode	

If the capacitive measuring probes are used in explosion hazardous areas of zone 0, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6, T5, T4, T3, T2, T1	-20 °C +60 °C	-20°C +60 °C

The capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar). If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

**IECEx Certification Body** 



### Page 2 of 3 Issue No. 1 of IECEx TUN 05.0002 X

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas of the zone 0 (electrode) and zone 1 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature range	Medium temperature range
T6	-40 °C +64 °C	-20°C +60 °C
T5	-40 °C +79 °C	-20°C +60 °C
T4, T3, T2, T1	-40 °C +80 °C	-20°C +60 °C

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature at the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive measuring probes are mounted in explosion hazardous areas of the zone 1, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE- insulation	medium temperature range for other electrodes
T6	- 40°C + 64°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 79°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

**IECEx Certification Body** 



### Page 3 of 3 Issue No. 1 of IECEx TUN 05.0002 X

### Electrical data

in type of protection "Intrinsic Safety" Ex ia IIC Only for connection to a certified intrinsically safe circuit

maximum values:

 $U_i = 30 \text{ V}$  $I_i = 131 \text{ mA}$ 

 $P_i = 983 \text{ mW}$ 

characteristic line: linear

effective internal capacitance: 3 nF

The effective internal inductances are negligibly small.

In the execution VEGACAL CL6\*.CI\*\*\*X3/4/5/9\*\*\* a value of  $C_{i}^{'}$  wire/wire = 58pF/m und  $C_{i}^{'}$  wire/shield = 270pF/m has to be taken into account.

In the execution VEGACAL CL6\*.CI\*\*\*X3/4/5/9\*\*\* a

In the execution VEGACAL CL6\*.CI\*\*\*X3/4/5/9\*\*\* a value of L<sub>i</sub>' =  $55\mu$ H/m has to be taken into account.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

### Special conditions for safe use:

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.CI\*\*\*X\*\*\*\*
  there is a danger of ignition by electrostatic discharge. Observe manual of the
  manufacturer and warning label.
- For zone 0 applications, at the metallic parts of the capacitive measuring probes type VEGACAL CL6\*.Cl\*\*\*X\*\*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the
  respective parts of the capacitive measuring probes type VEGACAL CL65.CI\*\*\*X\*\*\*\* and
  type VEGACAL CL66.CI\*\*\*X\*\*\*\* have to be secured effectively against these dangers.
  Observe manual of the manufacturer.

**IECEx Certification Body** 



### Page 1 of 3 Issue No. 1 of IECEx TUN 05.0002 X

IECEx ExTR:	File reference:
DE/TUN/ExTR08.0018/00	08 204 554572
IECEx QAR:	File reference:
DE/QAR/TUN/06.0002/00	QAR TUN 04.0002

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*\*X\*\*\*\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

The changes refer to the type designation, the mechanical and electrical construction, the temperature range in the area of the electronics/of the medium, the special conditions for safe use and the marking.

The marking reads as follows: Zone 0, 0/1 Ex ia IIC Tx (see tables for temperature ranges).

Type designation and mechanical execution of the measuring probes:

Туре	Electrodes
CL62.CI***X****	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI***X****	fully insulated electrode, optionally plated
CL64.CI***X****	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI***X****	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI***X****	fully insulated cable electrode
CL69.CI***X****	fully insulated 2-rod electrode

If the capacitive measuring probes are used in explosion hazardous areas of zone 0, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature	Medium temperature
Temperature class	range	range
T6, T5, T4, T3, T2, T1	-20 °C +60 °C	-20°C +60 °C

The capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar). If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

**IECEx Certification Body** 



### Page 2 of 3 Issue No. 1 of IECEx TUN 05.0002 X

If the capacitive measuring probes are mounted in the partition wall between explosion hazardous areas of the zone 0 (electrode) and zone 1 (electronics), the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

Temperature class	Ambient temperature	Medium temperature
Temperature class	range	range
T6	-40 °C +64 °C	-20°C +60 °C
T5	-40 °C +79 °C	-20°C +60 °C
T4, T3, T2, T1	-40 °C +80 °C	-20°C +60 °C

The electrodes of the capacitive measuring probes are allowed to be operated in an explosion hazardous area of the zone 0, only if atmospheric conditions exist (pressure from 0.8 bar to 1.1 bar).

If no explosion hazardous atmospheres exist, the permissible operating temperatures and pressures have to be taken from the manufacturer's data (manual).

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature at the electronics/housing must not exceed the values as mentioned in the a.m. table.

If the capacitive measuring probes are mounted in explosion hazardous areas of the zone 1, the permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

and temperature diade had to be taken from the following table:			
temperature	ambient	medium temperature	medium temperature
class	temperature range	range	range for other
		for electrodes with PE-	electrodes
		insulation	
T6	- 40°C + 64°C	- 40°C + 80°C	-50°C +85 °C
T5	- 40°C + 79°C	- 40°C + 80°C	-50°C +100 °C
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

**IECEx Certification Body** 



### Page 3 of 3 Issue No. 1 of IECEx TUN 05.0002 X

### Electrical data

in type of protection "Intrinsic Safety" Ex ia IIC Only for connection to a certified intrinsically safe circuit

maximum values:

 $\begin{array}{lll} U_i &=& 30 & V \\ I_i &=& 131 & mA \\ P_i &=& 983 & mW \\ characteristic line: linear \end{array}$ 

effective internal capacitance: 3 nF

ellective internal capacitance: 3 nr

The effective internal inductances are negligibly small.

In the execution VEGACAL CL6\*.Cl\*\*\*X3/4/5/9\*\*\* a value of Ci $^{'}_{\rm wire/wire}$  = 58pF/m und Ci $^{'}_{\rm wire/shield}$  = 270pF/m has to be taken into account.

In the execution VEGACAL CL6\*.Cl\*\*\*X3/4/5/9\*\*\* a value of Li′ =  $55\mu$ H/m has to be taken into account.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

### Special conditions for safe use:

- At the plastic parts of the capacitive measuring probes type VEGACAL CL6\*.Cl\*\*X\*\*\*\*
  there is a danger of ignition by electrostatic discharge. Observe manual of the
  manufacturer and warning label.
- For zone 0 applications, at the metallic parts of the capacitive measuring probes type VEGACAL CL6\*.CI\*\*\*X\*\*\*\*\* made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
- For zone 0 resp. zone 0/1 applications and at risks by pendulum or vibration the
  respective parts of the capacitive measuring probes type VEGACAL CL65.Cl\*\*\*X\*\*\*\* and
  type VEGACAL CL66.Cl\*\*\*X\*\*\*\* have to be secured effectively against these dangers.
  Observe manual of the manufacturer.



### INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx TUN 05.0002X	Issue No.: 0
Status:	Current	
Date of Issue:	2005-02-23	Page 1 of 4
Applicant:	VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach Germany	
Electrical Apparatus: Optional accessory:	Capacitive measuring probe VE	GACAL CL6*.CI**X**
Type of Protection:	Intrinsic safety	
Marking:	Ex ia IIC T6	
Approved for issue on Certification Body:	behalf of the IECEx	Herbert Stürwold
Position:		Head of IECExCB
Signature: (for printed version)		
Date:		
2. This certificate is no	schedule may only be reproduced in fu to transferable and remains the propert henticity of this certificate may be verifi	all. y of the issuing body. ed by visiting the Official IECEx Website.
Certificate issued by:	RD CERT GmbH	& Co. KG

Am TUV1 D-30519 Hannover Germany



Certificate No.: IECEx TUN 05.0002X

Date of Issue: 2005-02-23 Issue No.: 0

Page 2 of 4

Manufacturer: VEGA Grieshaber KG

Am Hohenstein 113 77761 Schiltach Germany

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacture'rs quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

### STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0: 2000 Electrical apparatus for explosive gas atmospheres - Part 0: General requirements

Edition: 3.1

Electrical apparatus for explosive gas atmospheres - Part 11: Intrinsic safety 'i'

IEC 60079-11 : 1999 Edition: 4

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

IECEx ATR:

File Reference:

DE / TUN / 05 / 551794

05 YEX 551794



Certificate No.:

**IECEX TUN 05.0002X** 

Date of Issue:

2005-02-23

Issue No.: 0

Page 3 of 4

### Schedule

#### EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The capacitive measuring probes type VEGACAL CL6\*.CI\*\*X\*\* are used for monitoring or control of filling levels in explosion hazardous areas.

The measuring media are allowed to be combustible liquids, gases, mists or vapours.

Mechanical execution of the capacitive measuring probes:

type	electrodes
CL62.CI**X**	partly insulated electrode, optionally with screening tube or concentric tube
CL63.CI**X**	fully insulated electrode, optionally plated
CL64.CI**X**	fully insulated electrode, optionally with screening tube, concentric tube or plated
CL65.CI**X**	partly insulated cable electrode optionally with additionally insulated cable
CL66.CI**X**	fully insulated cable electrode

### CONDITIONS OF CERTIFICATION: YES as shown below:

At the plastic parts of the capacitive measuring probe type VEGACAL CL6\*.Cl\*\*X\*\* there is a danger of ignition by electrostatic discharge. Observe manual of the manufacturer and warning label.



Certificate No.:

IECEX TUN 05.0002X

Date of Issue:

2005-02-23

Issue No.: 0

Page 4 of 4

### EQUIPMENT(continued):

The permissible temperature range in the area of the electronics/of the medium dependent on the temperature class has to be taken from the following table:

temperature class	ambient temperature range	medium temperature range for electrodes with PE/PA- insulation	medium temperature range for other electrodes	
T6	- 40°C + 64°C	- 40°C + 80°C	-50°C +85 °C -50°C +100 °C	
T5	- 40°C + 79°C	- 40°C + 80°C		
T4	- 40°C + 80°C	- 40°C + 80°C	-50°C +135 °C	
T3*, T2*, T1*	- 40°C + 80°C	- 40°C + 80°C	-50°C +150 °C	

<sup>\*</sup> with temperature adapter for medium temperatures > 150°C ... 200°C

If the sensors of the capacitive measuring probes are operated at higher medium temperatures as listed in the a.m. table, measures have to be taken, that the danger of ignition caused by these hot surfaces is excluded. The max. permissible temperature on the electronics/housing must not exceed the values as mentioned in the a.m. table.

#### Electrical data

Supply and signal circuit (Terminals KI1[+], KI2[-] in the housing for the electronics resp., in the execution with the 2 cell housing, in the terminal housing) in type of protection "Intrinsic Safety" Ex ia IIC only for connection to a certified intrinsically safe circuit maximum values:

U<sub>i</sub> = 30 V I<sub>i</sub> = 131 mA P<sub>i</sub> = 983 mW characteristic line: linear

effective internal capacitance: 3 nF The effective internal inductances are negligibly small.

A length of the triax cable resp. coax cable between the housing for the electronics and the terminal housing of 10 m is permissible.

The intrinsically safe supply and signal circuit is safe galvanically separated from the parts which can be earthed.

## INTERNATIONAL ELECTROTECHNICAL COMMISSION (IEC) COMMISSION ELECTROTECHNIQUE INTERNATIONALE (CEI)

Ref. No.

DE/TUN/05/551794

IEC SCHEME FOR CERTIFICATION TO STANDARDS FOR ELECTRICAL EQUIPMENT FOR EXPLOSIVE ATMOSPHERES (IECEx Scheme) SYSTEME CEI POUR CERTIFICATION SELON LES NORMES RELATIVES AUX APPAREILS ELECTRIQUES DESTINES A ETRE UTILISES EN ATMOSPHERES EXPLOSIBLES (SYSTEME CEIEX)

### IECEX TEST REPORT RAPPORT CEIEX D'ESSAIS

Product Produit

Name and address of the applicant Nom et adresse du demandeur

Name and address of the manufacturer Nom et adresse du fabricant

Rating and principal characteristics Valeurs nominales et caractéristiques principales

Trade mark (if any)
Marque de fabrique (si elle existe)

Model/type Ref. Ref. de type

Additional information (if necessary)
Information complémentaire (si nécessaire)

A sample of the product was tested and found to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la

as shown in the Test Report, Ref. No. comme indiqué dans le Rapport d'essais, numéro de référence

Capacitive measuring probe

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach

VEGA Grieshaber KG Am Hohenstein 113 77761 Schiltach

Rating: See ExTR Principal characteristics: intrinsically safe apparatus Ex ia IIC T6

VEGACAL CL6\*.CI\*\*X\*\*

PUBLICATION IEC 60079-0 IEC 60079-11 EDITION 3.1 4

DE/TUN/04/551794

The ExTR is issued by the following Certification Body
Le Rapport ExTR Ex est émis par l'organisme de certification suivante

TÜV NORD CERT GmbH & Co. KG Am TÜV 1 D-30519 Hannover

24.02.2005

Date

Signature

The well