

## Overview of the software versions

### VEGAPOINT 11

Three-wire transistor (inclusive IO-Link)

Version, available since	Description	Device Rev.
<b>1.2.1</b> <b>11/2020</b>	<b>Error corrections:</b> <ul style="list-style-type: none"> <li>- While setting the switching output:               <ul style="list-style-type: none"> <li>- Switching delay &gt; 0s</li> <li>- Switch back delay = 0s</li> </ul> </li> </ul> the switching command was not implemented on the output.	<b>1</b>
<b>1.2.0</b> <b>08/2020</b>	<b>New functions:</b> <ul style="list-style-type: none"> <li>- IO-Link 1.1 communication</li> <li>- Pointer</li> <li>- Setting of the switching behaviour               <ul style="list-style-type: none"> <li>- Application standard of user-defined</li> <li>- Window or hysteresis function</li> </ul> </li> <li>- Setting of the switching/switch back point</li> <li>- Setting of the delay time</li> <li>- Implementation customer-specific adjustment</li> </ul>	<b>1</b>
<b>1.0.0,</b> <b>05/2019</b>	<b>First version</b> <b>New functions:</b> <ul style="list-style-type: none"> <li>- Measurement function:               <ul style="list-style-type: none"> <li>- Determination of the switching point by means of high-frequency capacitance determination</li> </ul> </li> <li>- Instrument software, in general:               <ul style="list-style-type: none"> <li>- Device status according to NE107</li> </ul> </li> </ul>	<b>1</b>

#### Legend:

Name	Description
Version	xx.yy.zz xx: Compatibility version. Will be increased when the compatibility to the previous version is no longer given. Value range 0 ... 99. yy: Function extension version. Will be increased when new functions or function changes were carried out on the previous version. Also errors can have been corrected with a function change. Value range 0 ... 99. zz: Error correction version. Will be increased when only errors were corrected on the previous version. Value range 0 ... 99.
available since	Month/Year

## Overview of the software versions

Name	Description
Device Rev.	Version number of the instrument defined by Fieldbus. Consecutive integral number Will be increased if in the "Application Layer" modifications were carried out. E.g. new commands, modifications in the data structure in a command.