

EU-TYPE EXAMINATION CERTIFICATE



Equipment or Protective System intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

- [1] EU-Type Examination Certificate Number: **DEMKO 20 ATEX 2382X Rev. 1**
- [2] Product: **Industrial Controllers, VEGAMET 341(*), VEGAMET 342(*)**
- [3] Manufacturer: **VEGA Grieshaber KG**
- [4] Address: **Am Hohenstein 113, 77761 Schiltach, Germany**
- [5] This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- [6] UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres, given in Annex II to the Directive.
- [7] The examination and test results are recorded in the confidential report no. **DK/ULD/ExTR20.0029/01**.
- [8] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
- EN IEC 60079-0:2018** **EN IEC 60079-0:2018/A11:2024**
EN IEC 60079-11:2024 **EN 60079-11:2012**
- [9] Where additional criteria beyond those given here have been used, they are listed at item 18 in the Schedule.
- [10] If the sign "X" is placed after the certificate number, it indicates that the product is subject to the "Specific Conditions of Use" listed under item 17 of this certificate.
- [11] This EU-Type Examination Certificate relates only to the technical design of the specified product in accordance to the Directive 2014/34/EU. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by the certificate.
- [12] The marking of the product shall include the following (marking is provided in the Schedule as a part of item 15, if applicable):

 **II (1) G [Ex ia Ga] IIC**

 **II (1) D [Ex ia Da] IIIC**

Certification Manager
Thomas Wilson



This is to certify that the sample(s) of the Product described herein ("Certified Product") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured product. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all product to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2021-02-08

Re-issued: 2025-10-23

Notified Body UL International Demko A/S, Borupvang 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com



Solutions

Accredited by DANAK under registration number 7011 to certification of products.

Form-ULID-000217 (DCS:00-IC-F0056-1) – Issue 29.0

This certificate may only be reproduced in its entirety and without any change.

Page 1 of 3

64253-EN-251030

[13]

[14]

Schedule

EU-TYPE EXAMINATION CERTIFICATE No.

DEMKO 20 ATEX 2382X Rev. 1

Sensor input circuit:
(terminals 1, 2 [VEGAMET 341(*)])
(terminals 1, 2, 4, 5 [VEGAMET 342(*)])

4...20 mA

Maximum values of the intrinsically safe signal circuit:
 $U_o \leq 23.3 \text{ V}$
 $I_o \leq 109.8 \text{ mA}$
 $P_o \leq 639.6 \text{ mW}$

characteristic: linear
 C_i is negligibly small
 L_i is negligibly small

The maximum values in the table may be used as concentrated capacitances and concentrated inductances.

Ex ia	IIC		IIB, IIIC		IIA
Permissible external inductance L_o	0.2 mH	0.5 mH	0.5 mH	2 mH	10 mH
Permissible external capacitance C_o	120 nF	88 nF	580 nF	470 nF	770 nF
Permissible outer L_o/R_o ratio	55 $\mu\text{H}/\text{Ohm}$	55 $\mu\text{H}/\text{Ohm}$	221 $\mu\text{H}/\text{Ohm}$	221 $\mu\text{H}/\text{Ohm}$	443 $\mu\text{H}/\text{Ohm}$

The intrinsically safe circuit is safely separated from the non-intrinsically safe circuits up to a peak value of the nominal voltage of 375V.

The maximum voltage at the non-intrinsically safe circuits must not exceed 253Vrms in the event of a fault. VEGAMET 340(*) series have intrinsically safe circuits and non-intrinsically safe circuits.

Routine tests

Transformer TR101 and TR201 shall be subjected to a voltage of 2500 V rms between primary and secondary windings, for at least 60 seconds, in accordance with the requirements of Clause 11.2 of EN 60079-11. Alternatively, the test may be carried out at 1.2 times the test voltage, but with a reduced duration of at least 1 second.

The devices shall be subjected to a routine verification of coatings in accordance with document no. OS-3885.

[16]

Descriptive Documents

The scheduled drawings are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.

[17]

Specific conditions of use:

The installer must also ensure that the rated ambient temperature range of the equipment is not exceeded when installed in an enclosure with other equipment and that sufficient separation is provided around the device.

[18]

Essential Health and Safety Requirements

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.



The trademark **VEGA** will be used as the company identifier on the marking label.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.

