



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx ULD 20.0018X** Page 1 of 3 [Certificate history:](#)

Status: **Current** Issue No: 0

Date of Issue: 2021-02-20

Applicant: **VEGA Grieshaber KG**
Am Hohenstein 113
77761 Schiltach
Germany

Equipment: **Ex Separators for one or two intrinsically safe 4 ... 20 mA/HART sensors, VEGATRENN 141(*), VEGATRENN 142(*)**.

Optional accessory:

Type of Protection: **Increased Safety "ec", Intrinsic Safety "ia"**

Marking: Ex ec [ia Ga] IIC T4 Gc
Ex ec [ia IIIC Da] IIC T4 Gc
Ex ec [ia I Ma] IIC T4 Gc
Ta = -20°C ... +60°C

Approved for issue on behalf of the IECEx
Certification Body:

Erin LaRocco

Position:

Staff Engineer

Signature:
(for printed version)

Date:

2021-02-20

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

UL International DEMKO A/S
Borupvang 5A
DK-2750 Ballerup
Denmark





IECEx Certificate of Conformity

Certificate No.: **IECEx ULD 20.0018X**

Page 2 of 3

Date of issue: 2021-02-20

Issue No: 0

Manufacturer: **VEGA Grieshaber KG**
Am Hohenstein 113
77761 Schiltach
Germany

Additional manufacturing locations: **VEGA Americas, Inc**
4241 Allendorf Drive
Cincinnati, Ohio 45209
United States of America

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DK/ULD/ExTR20.0018/00](#)

Quality Assessment Report:

[DE/TUN/QAR06.0002/10](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx ULD 20.0018X**

Page 3 of 3

Date of issue: 2021-02-20

Issue No: 0

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The VEGATRENN 140(*) series are Ex Separators for one or two intrinsically safe 4 ... 20 mA/HART sensors.

They are used for galvanic separation, intrinsically safe power supply as well as the signal transmission of Ex approved 4... 20 mA/HART sensors in hazardous areas.

The single channel Ex separator VEGATRENN 141(*) is used for one intrinsically safe 4 ... 20 mA/HART sensor and the double channel Ex separator VEGATRENN 142(*) for two intrinsically safe 4 ... 20 mA/HART sensors.

They are able to supply up to two sensors with an intrinsically safe circuit (Ex ia) and can convert their measurement values through a 4...20 mA output.

Up to 2 current outputs can be used for data transmission to other control equipment or external indicating instruments can be used to operate equipment.

The VEGATRENN 140(*) series are suitable for bidirectional transmission of HART signals. The HART signal can be tapped via the front-mounted HART communication sockets or the terminals.

VEGATRENN 140(*) series can be mounted in control cabinet / carrier rail. The VEGATRENN 140 series supplies the sensor with 4...20mA interface.

The intrinsically safe circuit is safely separated from the non-intrinsically safe circuits up to a peak value of the nominal voltage of 375V.

The maximum voltage at the non-intrinsically safe circuits must not exceed 253Vrms in the event of a fault.

Please see Annex for additional information.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The equipment must be mounted in a housing that has been tested according to IEC 60079-0 and meets the requirements of protection class IP54.
- The device may only be used in an area with a pollution degree of 2 or better.
- The installer must ensure that the rated ambient temperature range of the equipment is not exceeded when installed in an enclosure with other equipment and that sufficient separation is provided around the device.
- The installation orientation of the device must be in accordance with the instructions.

Annex:

[Annex to IECEx ULD 20.0018X Issue 0.pdf](#)



IECEx Certificate of Conformity

Certificate No.: IECEx ULD 20.0018X

Issue No.: 0

Page 1 of 3

TYPE DESIGNATION

Models VEGATRENN 141(*), VEGATRENN 142(*)

Nomenclature:

VEGATRENN	a	b	c
	1	Housing for the installation in the control cabinet (indoor)	
		4	Active, separate power supply
			1 Single channel version, for use with one sensor
			2 Dual channel version, for use with one or two sensors
			(*) Reserved for OEM partners with same device

The placeholder within brackets (VEGATRENN 14x(*)) is reserved for internal production control without effect on the product construction.

PARAMETERS RELATING TO THE SAFETY

Electrical parameters:

Power supply: Nominal range: VEGATRENN 141(*):
(terminals 16, 17) 24 V ... 230 V AC 50/60 Hz; 15 VA
24 V ... 65 V DC; 3 W
Um = 253V AC for [Ex ia] only

Power supply: Nominal range: VEGATRENN 142(*):
(terminals 16, 17) 24 V ... 31 V DC; 5 W
Um = 253V AC for [Ex ia] only

Current output:
(terminals 10 to 12 [TRENN 141(*)]) 4...20 mA/HART active
(terminals 10 to 15 [TRENN 142(*)]) U ≤ 16.5 V
Load = max. 600 Ω (without internal HART resistor)
Um = 253V AC for [Ex ia] only

Sensor input circuit:
(terminals 1,2 [TRENN 141(*)]) 4...20 mA/HART
(terminals 1,2, 4,5 [TRENN 142(*)]) Maximum values of the intrinsically safe signal circuit:
Uo ≤ 26.3 V
Io ≤ 100 mA
Po ≤ 658 mW
characteristic: linear

Ci = 1.2 nF
Li = negligibly small

Certificate No.: IECEx ULD 20.0018X

Issue No.: 0

Page 2 of 3

The maximum values in the following table may be used as concentrated capacitances and concentrated inductances.

The maximum values of the table are also allowed to be used up to the permissible limits as concentrated capacitances and concentrated inductances.

Ex ia	IIC		IIB, IIIC		IIA	I
Permissible external inductance L_o	0.2 mH	1 mH	0.2 mH	2 mH	10 mH	5 mH
Permissible external capacitance C_o	95.8 nF	54.8 nF	618.8 nF	328.8 nF	508.8 nF	708.8 nF
Permissible L_o/R_o ratio	-		216 μ H / Ω	216 μ H / Ω	433 μ H / Ω	710 μ H / Ω

Environmental Ratings: -20 °C ≤ Tamb ≤ +60 °C

MARKING

Marking has to be readable and indelible; it has to include the following indications:

VEGATRENN 141(*)	
<p>IECEx ULD 20.0018X Ex ec Ia Gq IIC T4 Gc, Exec [Ia IIIC Daj IIC T4 Gc, Exec [Ia I Ma] IIC T4 Gc Associated Apparatus for use in Hazardous Locations (see doc. 64575) $U_o \leq 26.3V, I_o \leq 100mA, P_o \leq 658mW, U_{lim} \leq 253V, I_{IC}, C_o \leq 958nF, L_o \leq 0.2mH$ $T_a: -20^\circ C \dots +60^\circ C$ WARNING – POTENTIAL ELECTROSTATIC CHARGING HAZARD – SEE INSTRUCTIONS WARNING – EXPLOSION HAZARD: DO NOT CONNECT OR DISCONNECT WHEN ENERGIZED</p>	
<p>~ 24...65V ^{III} 24...230V ~ 50/60Hz</p> <p>⊕ 4...20mA ⊖ 4...20mA</p> <p>3W, 15VA IP20</p>	<div style="text-align: right;">  2020 </div> <div style="text-align: center;">  </div>
<p>VEGA Grieshaber KG D-77761 Schiltach Made in Germany www.vega.com</p> <p style="text-align: right; font-weight: bold;">s/n 12345678</p>	

Certificate No.: IECEx ULD 20.0018X

Issue No.: 0

Page 3 of 3

VEGATRENN 141(*)	
<p>UL 20 ATEX 2404X</p> <p>II 3(I)G Ex ec [ja Ga] IIC T4 Gc, II 3G(I)D Ex ec [ja I] IIC De] IIC T4 Gc, II 3G(M1) Ex ec [ja I Me] IIC T4 Gc</p> <p>Associated Apparatus for use in Hazardous Locations (see doc: 64573)</p> <p>U_o ≤ 26.3V, I_o ≤ 100mA, P_o ≤ 693mW, U_m ≤ 253V, I_c Co ≤ 95.8nF, L_o ≤ 0.2mH</p> <p>T_a: -20°C... +60°C</p> <p>WARNING – POTENTIAL ELECTROSTATIC CHARGING HAZARD – SEE INSTRUCTIONS</p> <p>WARNING – EXPLOSION HAZARD: DO NOT CONNECT OR DISCONNECT WHEN ENERGIZED</p>	
<p>→ 24...65V ~</p> <p>24...230V ~ 50/60Hz</p> <p>→ 4...20mA</p> <p>→ 4...20mA</p> <p>3W, 15VA</p> <p>IP 20</p>	<div style="text-align: center;">  </div> <p style="text-align: center;">s/n 12345678</p>
<p>VEGA Grieshaber KG D-77761 Schiltach Made in Germany www.vega.com</p>	

ROUTINE EXAMINATIONS AND TESTS

Each pieces of equipment defined above has to have successfully passed; before delivery:

Transformer TR101 and TR201 (VEGA TRENN 142(*) only) shall be subjected to a voltage of 1500 V rms between primary and secondary windings, for at least 60 seconds, in accordance with the requirements of Clause 11.2 of IEC 60079-11. Alternatively, the test may be carried out at 1.2 times the test voltage, but with a reduced duration of at least 1 second.

