

IN TERMS OF ARP 0108: "REGULATORY REQUIREMENTS FOR EXPLOSION PROTECTED APPARATUS"

Date Issued: 13 Sep 2024  
\*Expiry date: 13 Sep 2027  
Page 1 of 5  
Issue: 2

Certificate Number:	<b>S-XPL/090937 X</b>
Equipment:	<b>Vibrating level switch</b>
Model / Type:	<b>VEGASWING SG66(*) I E * * * * * and/or VEGASWING SG66(*) A E * * * * *</b>
Applicant:	<b>Vega Instruments (Pty) Ltd</b> <b>PO Box 692</b> <b>Wilgeheuwels</b> <b>1736</b>
Manufacturer:	<b>VEGA Grieshaber KG</b>
Serial No:	All serial numbers imported between issued- and expire date and all serial numbers covered by a valid report or acceptable product certification mark.

Supplied by  
**Vega Instruments (Pty) Ltd**  
Identified by Inspection Authority Number  
**S-XPL/090937 X**

And as described in the Explolabs file number **XPL/10628/090937** is hereby certified "Explosion Protected (Refer to clause 1, for Ex Rating)", having been examined and inspected in accordance with the relevant requirements of the South African National Standards.

<b>SANS 60079-0: 2019 Ed 6</b>	Explosive atmospheres Part 0: Equipment — General requirements
<b>IEC 60079-0: 2017 Ed 7</b>	
<b>SANS 60079-1: 2015 Ed 5</b>	Explosive atmospheres Part 1: Equipment protection by flameproof enclosures "d"
<b>IEC 60079-1: 2014 Ed 7</b>	
<b>IEC/SANS 60079-26: 2021</b>	Explosive atmospheres – Part 26: Equipment with equipment protection level (EPL) Ga

Risk of ignition provided:

Protection afforded	Equipment Protection Level (EPL)	Performance of protection	Conditions of operation	T class or Max Surface Temp (°C)
	Group			
Very high	Ga Group II	Two independent means of protection or safe even when two faults occur independently of each other	Equipment remains functioning in zones 0, 1 and 2	T6 (85°C) ... T1 (450°C)
High	Gb Group II	Suitable for normal operation and frequently occurring disturbances or equipment where faults are normally taken into account	Equipment remains functioning in zones 1 and 2	T6 (85°C) ... T1 (450°C)

This certificate supersedes all previous documents bearing the reference no XPL/10628/090937 Issue 1.

DOCUMENT No: XPL0213      RELEASE DATE: 30/01/2024      REV: 8

## 1. GENERAL

The marking of the Vibrating level switch shall include the following:

**Ex db IIC T6...T1 Ga/Gb or**

**Ex db IIC T6...T1 Gb**

**Description**

Vibrating level switch type VEGASWING is used for level monitoring or regulating in explosive atmospheres. It consists of a metal enclosure with built in electronics and a vibrating fork as sensor.


The Vibrating level switch for use as EPL Ga/Gb equipment is intended to be mounted in a forming part of the boundary wall to Zone 0. In such a case the sensor is situated in Zone 0 whereas the electronics enclosure is situated in Zone 1.

The thickness of the pipe and vibrating fork is > 1 mm and fulfils the mechanical requirements for an equipment which is mounted through the wall to an area requiring EPL Ga.

**Subject and Type**

Vibrating level switch type VEGASWING

SG66(\*)\*\*\*\*\*



This certificate supersedes all previous documents bearing the reference no XPU/10628/090937 Issue 1.

DOCUMENT No: XPL0213 | RELEASE DATE: 30/01/2024 | REV: 8

This document is an Explolabs Controlled Document – Responsibility falls on personnel to ensure correct revision is applied as noted in the electronic system.

**Parameters****Electrical data**

VEGASWING SWING SG66.(\*) IE\*\*\*\*R/S\*\*\* and/or SG66.(\*) AE\*\*\*\*R/S\*\*\*

with built in electronics insert SG60HT-R/S

supply

U = 20...253 V AC, 50/60 Hz

(terminals 1, 2)

U = 20... 72 V DC

Power dissipation

max. 3 VA, max. 1 W

Relay circuit

Maximum values:

Set of contacts 1 (terminals 3, 4, 5)

AC 253 V, 5A, 1250 VA

Set of contacts 2 (terminals 6, 7, 8)

DC 253 V, 1A, 40 W

VEGASWING SWING SG66.(\*) IE\*\*\*\*T/I\*\*\* and/or SG66.(\*) AE\*\*\*\*T/I\*\*\*

with built in electronics insert SG60HT-T/I

Supply

U = 9.6...55 V DC

(terminals 1, 4)

Power dissipation

max. 2 W

Load current, transistor-output (NPN/PNP)

(terminals 2, 3)

max. 400 mA and 55 V DC

VEGASWING SWING SG66.(\*) IE\*\*\*\*Z/L\*\*\* and/or SG66.(\*) AE\*\*\*\*Z/L\*\*\*

with built in electronics insert SG60HT-Z/L

Supply

U = 9.6...35 V DC

(terminals 1, 2)

**Thermal data**

Process- and ambient temperature range

Equipment in Zone 1

Temperature class	Permitted process temperature range at the sensor	Permitted ambient temperature range at the electronics enclosure
T6	-196 °C... +85 °C	-50 °C...+60 °C
T5	-196 °C...+100 °C	-50 °C...+60 °C
T4	-196 °C...+135 °C	-50 °C...+60 °C
T3	-196 °C...+200 °C	-50 °C...+60 °C
T2	-196 °C...+300 °C	-50 °C...+60 °C
T1	-196 °C...+450 °C	-50 °C...+60 °C

Equipment mounted in a boundary wall (electronics enclosure in Zone 1, sensor in Zone 0)

Temperature class	Permitted process temperature range at the sensor	Permitted ambient temperature range at the electronics enclosure
T6	-20 °C...+60 °C	-50 °C...+60 °C
T5		
T4		
T3		
T2		
T1		

Degree of protection according to IEC/SANS 60529

IP66

This certificate supersedes all previous documents bearing the reference no XPU/10628/090937 Issue 1.

DOCUMENT No: XPL0213 RELEASE DATE: 30/01/2024 REV: 8

This document is an Explorabs Controlled Document – Responsibility falls on personnel to ensure correct revision is applied as noted in the electronic system.

**Details of certificate changes**

Updating to the current standards  
Mechanical modifications without impact on explosion protection  
Slight modification of the type code  
Changes to the special conditions of use

**Remarks and additional information**

Drawings and documents are listed in the confidential report.

Based on the following documentation:

IECEx BVS 13.0022X Issue No. 3 and/or BVS 12 ATEX E 154 X Issue 1

**2. INSTALLATION INSTRUCTIONS**

It is the manufacturer's responsibility to supply installation instructions with each unit offered for sale as required by IEC/SANS 60079-0 Clause 30.

**3. SPECIAL CONDITIONS FOR SAFE USE** *(denoted by "X" after certificate number)*

Intensive electrostatic charging, for example through the process, must be avoided.

The capacity of the metallic measuring point identification plates is to be taken from the safety instructions and a suitability is to be checked.

**4. SCHEDULE OF LIMITATIONS** *(denoted by "U" after certificate number)*

Not applicable.

**5. CONDITIONS OF CERTIFICATION**

All production units must be covered by a QAN (Quality Assurance Notification), Product Mark Scheme or batch evaluation.

This certificate supersedes all previous documents bearing the reference no XPU/10628/090937 Issue 1.

DOCUMENT No: XPL0213	RELEASE DATE: 30/01/2024	REV: 8
----------------------	--------------------------	--------

This document is an Explolabs Controlled Document – Responsibility falls on personnel to ensure correct revision is applied as noted in the electronic system.
--

**6. MARKING**

The following (or similar) information have to be clearly and permanently marked on all units:

Supplier : Vega Instruments (Pty) Ltd  
Manufacturer : VEGA Grieshaber KG  
Equipment : Vibrating level switch  
Model/Type : VEGASWING SG66(\*)..I E \* \* \* \* \* and/or  
VEGASWING SG66(\*)..A E \* \* \* \* \*  
Serial No. : ---  
Ex Rating : Ex db IIC T6...T1 Ga/Gb or  
Ex db IIC T6...T1 Gb  
IA Certificate No : S-XPL/090937 X

*This certification indicates compliance with R10.1 of the Mines Health and Safety Act and/or EMR 9(2) of the Occupational Health and Safety Act, provided that the apparatus is used as relevant in accordance with:*

- i) SANS 10086 and IEC/SANS 61241-14 requirements as applicable;
  - ii) Any conditions mentioned in the above report;
  - iii) Any relevant requirements and codes of practice enforced in terms of the Mine Health and Safety Act or Occupational Health and Safety Act; and
  - iv) Any restrictions and conditions enforced by the Chief Inspector of Mines or the Principal Inspector or the Chief Inspector: Occupational Health and Safety.
- v) A revision certificate replaces all previous version of the certificate.  
vi) \* - Only covers equipment Imported between the "Issued" and "Expire" dates.  
vii) If and when your QAN (Quality Assurance Notification) Certificate for your equipment manufacturer expires during the valid period of the IA Certification (issued for your equipment) and a new certificate is not submitted the existing IA Certification will then be cancelled. It is thus the client's responsibility to always submit the updated and valid QAN certificate(s) to Explolabs (Pty) Ltd

**Reviewed by:**



**C Lourens**

**Technical Specialist**

**EXPLOLABS EXPLOSION PREVENTION SERVICES**

*This report/certificate shall not be reproduced except in full without the written approval of the company Explolabs (Pty) Ltd shall not be liable for any losses or damages sustained on account of any failure or omission to properly perform our duties in terms of any contract undertaken by us. This disclaimer is immutable and automatically incorporated in any contract undertaken by us; notwithstanding anything to the contrary, save for the express written waiver of our managing director. By marking the equipment in accordance with the documentation/standard, the manufacturer attests on his own responsibility that the equipment has been constructed in accordance with the applicable requirements of the relevant standards and that the routine verifications and tests have been successfully completed and that the product complies with the documentation and standard(s). The contents of electronic reports/certificates cannot be guaranteed. Original certification documents will be kept on file at Explolabs (Pty) Ltd*

This certificate supersedes all previous documents bearing the reference no XPLU/10628/090937 Issue 1.

DOCUMENT No: XPL0213	RELEASE DATE: 30/01/2024	REV: 8
----------------------	--------------------------	--------

*This document is an Explolabs Controlled Document – Responsibility falls on personnel to ensure correct revision is applied as noted in the electronic system.*





