



July 11, 2025

TITAN RESEARCH GROUP (6870830 Canada Inc)
1920 Yonge St. Ste 200
Toronto, ON M4S 3E2

Dear Rob McGregor,

Re: Reciprocal CRN Registration in Manitoba

As indicated by the Regulatory Reconciliation and Cooperation Table and the Reconciliation Agreement for the Canadian Registration Number (CRN) for Pressure Equipment, the design reviews conducted and accepted by the Canadian province or territory, or their delegated safety authority, will be mutually recognized in the Province of Manitoba. If a registration is conditionally based on compliance with the notes set by the original issuing Jurisdiction, such compliance shall be applied the same to this Province.

Your submission has been registered, as follows:

File Number: 74-R5174
CRN: 0F1454.94
Scope: SOR-VP1x2x-Rev.2 : See ACI CRN Registration
Manufacturer: VEGA AMERICAS INC
Expiry Date: 2 May 2035

Along with this letter is the invoice for registration.

In addition, every Pressure Vessel, Boiler, and Heat Exchanger shall be stamped with the registration number and as required by CSA Code B51, a Manufacturer's Data Report (MDR) must be forwarded to this office immediately at the time a unit is shipped to Manitoba. Send your MDR to gasupport@gov.mb.ca. In your subject line, indicate "*Manufacturer's Data Report-CRN No.*" A fee shall be billed to the Manufacturer to process data reports in accordance with the Steam and Pressure Plants Regulation section 17.1.

Please contact gasupport@gov.mb.ca for any questions or concerns.

Inspection and Technical Services

Labour and Immigration
508 – 401 York Avenue, Winnipeg, MB R3C 0P8
T (204) 945-3373 | F (204) 948-2089



SOR-VP1x2x-Rev. 2. VEGAPOINT Level Switch 11 [REDACTED], 21, 23, 31
Scope of Registration Summary

Product Assembly Type	Maximum Design Pressure (bar) and Temperature (°C)	Fitting Description	Materials of Construction	Code of Construction
VEGAPOINT 11 [REDACTED]	Up to 64 bar Maximum -20 °C up to 100 °C	(G1/2, G3/4, G1) ⁴⁾ M24 x 1.5 ²⁾ (1/2 NPT, 3/4 NPT, 1 NPT) ⁴⁾ Hygienic adapter ³⁾	UNS S31603, A479 (316L, 1.4404, 1.4435)	ASME B31.3 - 2020
VEGAPOINT 21	Up to 64 bar Maximum -40 °C up to 115 °C			
VEGAPOINT 23	Up to 64 bar Maximum Tube extension < 250 mm -40 °C up to 115 °C Tube extension ≥ 250 mm -40 °C up to 80 °C	(G1/2, G3/4, G1) ¹⁾ M24 x 1.5 ²⁾ (1/2 NPT, 3/4 NPT, 1 NPT) ⁴⁾ Clamp (1", 1 1/2") ²⁾ , 2" ¹⁾ Collar socket ³⁾ Hygienic adapter ³⁾		
VEGAPOINT 31	Up to 64 bar Maximum -40 °C up to 115 °C			

Footnotes: ¹⁾ max. 16 bar, ²⁾ max. 25 bar, ³⁾ max. 40 bar, ⁴⁾ max. 64 bar

Approved by: Matthias Kunz

Title: Product Safety Engineer

Signed by:

Date approved: October 23, 2024