



**Translation**

(1) **EU-Type Examination Certificate**

(2) Equipment and protective systems intended for use in potentially explosive atmospheres, **Directive 2014/34/EU**

(3) <b>Certificate Number</b>	<b>TÜV 03 ATEX 2269</b>	<b>Issue:</b>	00
(4) for the product:	Signal conditioning instrument type VEGAMET 624, VEGAMET 625 and VEGASCAN 693		
(5) of the manufacturer:	<b>VEGA Grieshaber KG</b>		
(6) Address:	Am Hohenstein 113, 77761 Schiltach, Germany		
Order number:	8003032445		
Date of issue:	See date of signature		

(7) The design of this product and any acceptable variation thereto are specified in the schedule to this EU-Type Examination Certificate and the documents therein referred to.

(8) The TÜV NORD CERT GmbH, Notified Body No. 0044, in accordance with Article 17 of the Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
The examination and test results are recorded in the confidential ATEX Assessment Report No. 22 203 296649.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:  
**EN IEC 60079-0:2018/AC:2020-02** **EN 60079-11:2012**  
except in respect of those requirements listed at item 18 of the schedule.

(10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions for Use specified in the schedule to this certificate.

(11) This EU-Type Examination Certificate relates only to the design, and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.

(12) The marking of the product shall include the following:

 **See "Type code and Marking"**

TÜV NORD CERT GmbH, Am TÜV 1, 45307 Essen, notified by the central office of the countries for safety engineering (ZLS), Ident. Nr. 0044, legal successor of the TÜV NORD CERT GmbH & Co. KG Ident. Nr. 0032

The deputy head of the notified body



Digital  
unterschrieben  
von Drews Anke  
Datum: 2024.04.24  
14:25:09 +02'00'

Hanover office, Am TÜV 1, 30519 Hannover, Tel. +49 511 998-61455, Fax +49 511 998-61590



(13) **SCHEDULE**

(14) **EU-Type Examination Certificate No. TÜV 03 ATEX 2269**

**Issue 00**

(15) **Description of product:**

The signal conditioning instruments type VEGAMET 624, VEGAMET 625 and VEGASCAN 693 are used for the intrinsically safe supply of two-wire sensors and for the safe galvanic separation of the intrinsically safe circuit from the non-intrinsically safe circuits.

The measuring values are converted into standardised outlet signals. The device consists of an electronic casing and a connection socket.

**Type code and Marking:**

VEGAMET 624	I (M1) [Ex ia Ma] I or
VEGAMET 625	II (1) G [Ex ia Ga] IIC or
VEGASCAN 693	II (1) D [Ex ia Da] IIIC

**Electrical data:**

Supply voltage  
(Connections KI17 and KI18)

For connection to non-intrinsically safe circuits with following maximum values:

$$U = 24 \dots 65 \text{ V d. c. } (-15\% \dots +10\%)$$

$$U = 24 \dots 230 \text{ V a.c. } (-15\% \dots +10\%)$$

$$U_m = 253 \text{ V a.c. } / 125 \text{ V d.c.}$$

Signal circuit  
(Connections KI1 and KI2)

In type of protection Intrinsic Safety Ex ia I/II/IIB(IIIC) with following maximum values:

$$U_o = 23.9 \text{ V}$$

$$I_o = 108 \text{ mA}$$

$$P_o = 645 \text{ mW}$$

Characteristic line: linear

Negligibly small

Negligibly small

Effective internal capacitance  $C_i$

Effective internal inductance  $L_i$

The maximum permissible values for the external inductance  $L_o$  and the external capacitance  $C_o$  can be taken from the following tables:

<b>Ex ia I</b>	$L_o$ [mH]	63	10	0.5	0.2	0.1
	$C_o$ [ $\mu$ F]	1.8	2.6	3.4	4.3	4.7

<b>Ex ia IIC</b>	$L_o$ [mH]	1.8	1	0.5	0.2	0.1
	$C_o$ [ $\mu$ F]	0.051	0.068	0.088	0.12	0.126

<b>Ex ia IIB (IIIC)</b>	$L_o$ [mH]	18	1	0.5	0.2	--
	$C_o$ [ $\mu$ F]	0.58	0.65	0.77	0.94	--

**Schedule to EU-Type Examination Certificate No. TÜV 03 ATEX 2269 Issue 00**

Relay circuits  
(Relay output 1:  
connections KI20, KI21 and KI22  
Relay output 2:  
connections KI23, KI24 and KI25  
Relay output 3:  
connections KI26, KI27 and KI28  
Interference signal relay output 4:  
connections KI6, KI7 and KI8)

For connection to non-intrinsically safe circuits with following maximum values per relay:

a. c. current: 253 V; 2 A; 125 VA

d. c. current: 60 V; 1 A; 54 W

Current output  
(Current output 1:  
Connections KI11, KI12  
Current output 2:  
Connections KI13, KI14  
Current output 3:  
Connections KI15, KI16)

For connection to non-intrinsically safe circuits with following maximum values:

0/4 ... 20 mA

$U_m = 253 \text{ V a.c.}$

**Digital outputs**

RS232 connection  
(Bushing at the casing bottom part)  
or

For connection to a RS232 interface  
 $U_m = 50 \text{ V}$

Ethernet-connection  
(Bushing at the casing bottom part)

For connection to an Ethernet interface  
 $U_m = 50 \text{ V}$

I<sup>2</sup>C bus connection  
(Bushing on the front plate)

For connection of the VEGACONNECT3 according to type examination certificate PTB 01 ATEX 2007 X

The intrinsically safe signal circuit is safe galvanically separated from the non-intrinsically safe circuits up to a peak value of the voltage of 375 V.

**Thermal data:**

Permissible ambient temperature range during operation:  $-20 \text{ °C} \leq T_a \leq +60 \text{ °C}$

(16) Drawings and documents are listed in the ATEX Assessment Report No. 22 203 296649

(17) **Specific Conditions for Use:**

None.

(18) **Essential Health and Safety Requirements:**

No additional ones.

- End of EU-Type Examination Certificate -

