# **Operating Instructions**

# **VEGAMIP T61**

**Emitting unit** 





Document ID: 36998







# **Contents**

1	About this document					
	1.1	Function	4			
	1.2	Target group				
	1.3	Symbols used	4			
2	For v	For your safety				
_	2.1	Authorised personnel				
	2.2	Appropriate use				
	2.3	Warning about incorrect use				
	2.4	General safety instructions				
	2.5	EU conformity				
	2.6	Radio license for Europe	6			
	2.7	Radio license for USA/Canada				
	2.8	Installation and operation in the USA and Canada				
	2.9	Environmental instructions	6			
3	Prod	uct description	. 8			
•	3.1	Configuration				
	3.2	Principle of operation.				
	3.3	Packaging, transport and storage				
	3.4	Accessories				
4	N/ - · · ·	Alia a	4.0			
4		nting				
	4.1	General instructions				
	4.2	Mounting instructions	10			
5	Conr	ecting to power supply	14			
	5.1	Preparing the connection	14			
	5.2	Connection procedure	15			
	5.3	Wiring plan, single chamber housing	16			
6	Setu	0	17			
٠	6.1	Adjustment elements				
	• • •	•				
7	Main	tenance and fault rectification	18			
	7.1	Maintenance	18			
	7.2	Rectify faults				
	7.3	Exchanging the electronics				
	7.4	How to proceed if a repair is necessary	18			
8	Dism	ount	19			
-	8.1	Dismounting steps				
	8.2	Disposal				
_		·				
9		lement				
	9.1	Technical data				
	9.2	Dimensions				
	9.3	Industrial property rights				
	9.4	Trademark	27			



# 36998-EN-220505

# Safety instructions for Ex areas:



Take note of the Ex specific safety instructions for Ex applications. These instructions are attached as documents to each instrument with Ex approval and are part of the operating instructions.

Editing status: 2022-04-27



#### 1 About this document

#### 1.1 Function

This instruction provides all the information you need for mounting, connection and setup as well as important instructions for maintenance, fault rectification, the exchange of parts and the safety of the user. Please read this information before putting the instrument into operation and keep this manual accessible in the immediate vicinity of the device.

## 1.2 Target group

This operating instructions manual is directed to trained personnel. The contents of this manual must be made available to the qualified personnel and implemented.

# 1.3 Symbols used



#### ☐ Document ID

This symbol on the front page of this instruction refers to the Document ID. By entering the Document ID on <a href="www.vega.com">www.vega.com</a> you will reach the document download.



**Information**, **note**, **tip**: This symbol indicates helpful additional information and tips for successful work.



**Note:** This symbol indicates notes to prevent failures, malfunctions, damage to devices or plants.



**Caution:** Non-observance of the information marked with this symbol may result in personal injury.



**Warning:** Non-observance of the information marked with this symbol may result in serious or fatal personal injury.



**Danger:** Non-observance of the information marked with this symbol results in serious or fatal personal injury.



#### Ex applications

This symbol indicates special instructions for Ex applications.

Lis

The dot set in front indicates a list with no implied sequence.

# 1 Sequence of actions

Numbers set in front indicate successive steps in a procedure.



#### Disposa

This symbol indicates special instructions for disposal.



# 2 For your safety

# 2.1 Authorised personnel

All operations described in this documentation must be carried out only by trained, qualified personnel authorised by the plant operator.

During work on and with the device, the required personal protective equipment must always be worn.

# 2.2 Appropriate use

The VEGAMIP 61 is a sensor for point level detection.

You can find detailed information about the area of application in chapter " *Product description*".

Operational reliability is ensured only if the instrument is properly used according to the specifications in the operating instructions manual as well as possible supplementary instructions.

# 2.3 Warning about incorrect use

Inappropriate or incorrect use of this product can give rise to application-specific hazards, e.g. vessel overfill through incorrect mounting or adjustment. Damage to property and persons or environmental contamination can result. Also, the protective characteristics of the instrument can be impaired.

# 2.4 General safety instructions

This is a state-of-the-art instrument complying with all prevailing regulations and directives. The instrument must only be operated in a technically flawless and reliable condition. The operator is responsible for the trouble-free operation of the instrument. When measuring aggressive or corrosive media that can cause a dangerous situation if the instrument malfunctions, the operator has to implement suitable measures to make sure the instrument is functioning properly.

The safety instructions in this operating instructions manual, the national installation standards as well as the valid safety regulations and accident prevention rules must be observed by the user.

For safety and warranty reasons, any invasive work on the device beyond that described in the operating instructions manual may be carried out only by personnel authorised by the manufacturer. Arbitrary conversions or modifications are explicitly forbidden. For safety reasons, only the accessory specified by the manufacturer must be

To avoid any danger, the safety approval markings and safety tips on the device must also be observed.

The emitting frequencies of the sensors depend on the model, but are all in the K band range. The low transmitting power lies far below the internationally permitted limit value. When the instrument is used correctly, it presents no danger to human health. It may be operated without restriction outside of closed vessels.



# 2.5 EU conformity

The device fulfils the legal requirements of the applicable EU directives. By affixing the CE marking, we confirm the conformity of the instrument with these directives.

The EU conformity declaration can be found on our homepage.

#### Electromagnetic compatibility

Instruments in four-wire or Ex-d-ia version are designed for use in an industrial environment. Nevertheless, electromagnetic interference from electrical conductors and radiated emissions must be taken into account, as is usual with class A instruments according to EN 61326-1. If the instrument is used in a different environment, the electromagnetic compatibility to other instruments must be ensured by suitable measures.

## 2.6 Radio license for Europe

The instrument was tested according to the latest issue of the following harmonized standards:

EN 300440-1 - Short Range Devices (SRD)

#### 2.7 Radio license for USA/Canada

Operation is only permitted if the following two conditions are fulfilled:

- The instrument must not emit interference radiation
- The instrument must operate without being affected by incoming interference radiation, including such that may trigger unwanted operating conditions.

The instrument is in conformity with the following regulations:

FCC: Part 15 of the FCC regulations

IC: RSS-210 Issue 7, RSS-GEN Issue 2 and RSS-102 Issue 4 of the IC regulations.

Conversions or modifications of the instrument not expressly approved by the manufacturer will lead to loss of the approval.

Before use, make sure that the respective approval numbers are stated on the type label (see chapter " *Configuration*").

# 2.8 Installation and operation in the USA and Canada

This information is only valid for USA and Canada. Hence the following text is only available in the English language.

Installations in the US shall comply with the relevant requirements of the National Electrical Code (ANSI/NFPA 70).

Installations in Canada shall comply with the relevant requirements of the Canadian Electrical Code.

#### 2.9 Environmental instructions

Protection of the environment is one of our most important duties. That is why we have introduced an environment management system



with the goal of continuously improving company environmental protection. The environment management system is certified according to DIN EN ISO 14001.

Please help us fulfil this obligation by observing the environmental instructions in this manual:

- Chapter " Packaging, transport and storage"Chapter " Disposal"



# 3 Product description

# 3.1 Configuration

#### Type label

The type label contains the most important data for identification and use of the instrument:

- Article number
- Serial number
- Technical data
- ID numbers, instrument documentation

#### Serial number - Instrument search

The type label contains the serial number of the instrument. With it you can find the following instrument data on our homepage:

- Product code (HTML)
- Delivery date (HTML)
- Order-specific instrument features (HTML)
- Operating instructions and quick setup guide at the time of shipment (PDF)
- Test certificate (PDF) optional

Move to "www.vega.com" and enter in the search field the serial number of your instrument.

Alternatively, you can access the data via your smartphone:

- Download the VEGA Tools app from the "Apple App Store" or the "Google Play Store"
- Scan the QR-code on the type label of the device or
- Enter the serial number manually in the app

#### Scope of delivery

The scope of delivery encompasses:

Point level sensor VEGAMIP T61 (emitting unit)

The further scope of delivery encompasses:

- Documentation
  - Operating instructions VEGAMIP 61
  - Instructions for optional instrument features
  - Ex-specific " Safety instructions" (with Ex versions)
  - If necessary, further certificates

The corresponding receiving unit VEGAMIP R61 is described in a separate operating instructions manual.

# 3.2 Principle of operation

# **Application area**

VEGAMIP 61 is a microwave barrier for level detection.

It is designed for industrial use in all areas of process technology and can be used in bulk solids and liquids.

Typical applications are overfill and dry run protection. With an operating distance of 100 m, VEGAMIP 61 can be used, for example, in bulk solids silos with large diameters. Thanks to its simple and rugged measuring system, VEGAMIP 61 is virtually unaffected by the process and the chemical and physical properties of the medium.



VEGAMIP 61 can also be used for detection of vehicles and ships or for material recognition on conveyor belts.

It works even under extremely difficult conditions: different grain sizes, contamination, extreme filling noise, high temperatures, strong dust generation and abrasive products are all no problem for the instrument

The VEGAMIP 61 consists of the components:




Fig. 1: VEGAMIP 61 with plastic housing

- 1 Emitting unit VEGAMIP T61
- 2 Receiving unit VEGAMIP R61 with control electronics
- 3 Housina lid
- 4 Housing with control electronics
- 5 Process fitting

Several antenna versions are available for different applications.




Fig. 2: Antenna versions

- 1 Threaded version, internal horn antenna with PTFE cover
- 2 Plastic encapsulated antenna with PP cover
- 3 Horn antenna (316L)
- 4 VEGAMIP 61 with angled antenna extension
- 5 Encapsulated horn antenna with PTFE cover



#### **Functional principle**

The emitting unit transmits a focused microwave signal via horn antenna to the receiving unit on the opposite side. If there is medium between emitting and receiving unit, the signal is damped. This change is detected by the built-in electronics module and converted into a switching command.

# 3.3 Packaging, transport and storage

#### **Packaging**

Your instrument was protected by packaging during transport. Its capacity to handle normal loads during transport is assured by a test based on ISO 4180.

The packaging consists of environment-friendly, recyclable cardboard. For special versions, PE foam or PE foil is also used. Dispose of the packaging material via specialised recycling companies.

#### Transport

Transport must be carried out in due consideration of the notes on the transport packaging. Nonobservance of these instructions can cause damage to the device.

#### Transport inspection

The delivery must be checked for completeness and possible transit damage immediately at receipt. Ascertained transit damage or concealed defects must be appropriately dealt with.

#### Storage

Up to the time of installation, the packages must be left closed and stored according to the orientation and storage markings on the outside.

Unless otherwise indicated, the packages must be stored only under the following conditions:

- Not in the open
- Dry and dust free
- Not exposed to corrosive media
- Protected against solar radiation
- Avoiding mechanical shock and vibration

# Storage and transport temperature

- Storage and transport temperature see chapter " Supplement -Technical data - Ambient conditions"
- Relative moisture 20 ... 85 %

#### Lifting and carrying

With instrument weights of more than 18 kg (39.68 lbs) suitable and approved equipment must be used for lifting and carrying.

#### 3.4 Accessories

The instructions for the listed accessories can be found in the download area on our homepage.

#### Protective cover

The protective cover protects the sensor housing against soiling and intense heat from solar radiation.

#### **Flanges**

Screwed flanges are available in different versions according to the following standards: DIN 2501, EN 1092-1, BS 10, ASME B 16.5, JIS B 2210-1984, GOST 12821-80.



# Mounting adapter "Abrasion protection"

In case of extremely abrasive conditions you can cover the emitting and receiving units with a ceramic abrasion protection. This mounting adapter "Abrasion protection" is screwed onto the thread of VEGAMIP 61 like an adapter.

The mounting adapter "Abrasion protection" can only be used with the threaded version (internal horn antenna with PTFE cover)




Fig. 3: VEGAMIP 61 with ceramic mounting adapter "Abrasion protection" -40 ... +80 °C (-40 ... +176 °C)

# Mounting adapter "High temperature"

With high process temperatures exceeding 80 °C, you have to use a mounting adapter "High temperature" for the emitting and the receiving unit. The mounting adapter "High temperature" can only be used with the threaded version (internal horn antenna with PTFE cover).




Fig. 4: VEGAMIP 61 with mounting adapter "High temperature" -40  $\dots$  +450 °C (-40  $\dots$  +842 °F)

x Length: Mounting adapter "High temperature"

# Mounting adapter "High temperature with extension"

In case of high process temperatures of more than 80 °C you have to use a "high temperature" mounting adapter for the emitting and receiving unit. As an option, the "high temperature" mounting adapter can be also equipped with extension for front-flush mounting. Thus the instrument can also be mounted into long sockets where there is danger of buildup in the socket. The extension is available in five lengths: 40, 60, 80 100 and 150 mm (1.57, 2.36, 3.15, 3.94, 5.91 in).




Fig. 5: VEGAMIP 61 with mounting adapter "High temperature with extension" -40 ... +450 °C (-40 ... +842 °F)



# 4 Mounting

#### 4.1 General instructions

#### Screwing in

Devices with threaded fitting are screwed into the process fitting with a suitable wrench via the hexagon.

See chapter " Dimensions" for wrench size.



#### Warning:

The housing or the electrical connection may not be used for screwing in! Depending on the device version, tightening can cause damage, e. g. to the rotation mechanism of the housing.

#### **Process conditions**



#### Note:

For safety reasons, the instrument must only be operated within the permissible process conditions. You can find detailed information on the process conditions in chapter " *Technical data*" of the operating instructions or on the type label.

Hence make sure before mounting that all parts of the instrument exposed to the process are suitable for the existing process conditions.

These are mainly:

- Active measuring component
- Process fitting
- Process seal

Process conditions in particular are:

- Process pressure
- · Process temperature
- Chemical properties of the medium
- Abrasion and mechanical influences

# Protection against moisture

Protect your instrument against moisture ingress through the following measures:

- Use a suitable connection cable (see chapter " Connecting to power supply")
- Tighten the cable gland or plug connector
- Lead the connection cable downward in front of the cable entry or plug connector

This applies mainly to outdoor installations, in areas where high humidity is expected (e.g. through cleaning processes) and on cooled or heated vessels.



#### Note

Make sure that during installation or maintenance no moisture or dirt can get inside the instrument.

To maintain the housing protection, make sure that the housing lid is closed during operation and locked, if necessary.



#### Cable glands

#### Metric threads

In the case of instrument housings with metric thread, the cable glands are screwed in at the factory. They are sealed with plastic plugs as transport protection.

You have to remove these plugs before electrical connection.

#### **NPT thread**

In the case of instrument housings with self-sealing NPT threads, it is not possible to have the cable entries screwed in at the factory. The free openings for the cable glands are therefore covered with red dust protection caps as transport protection. The dust protection caps do not provide sufficient protection against moisture.

Prior to setup you have to replace these protective caps with approved cable glands or close the openings with suitable blind plugs.

# 4.2 Mounting instructions

#### Mounting

You can find the mounting instructions for VEGAMIP 61 in the operating instructions of the receiving unit.



# 5 Connecting to power supply

# Safety instructions

# 5.1 Preparing the connection

Always keep in mind the following safety instructions:

- Carry out electrical connection by trained, qualified personnel authorised by the plant operator
- If overvoltage surges are expected, overvoltage arresters should be installed



#### Warning:

Only connect or disconnect in de-energized state.

#### Voltage supply

Connect the operating voltage according to the connection diagrams. The electronics module is designed in protection class I. To maintain this protection class, it is absolutely necessary that the earth conductor be connected to the inner earth conductor terminal. Keep the general installation regulations in mind. Take note of the corresponding installation regulations for hazardous areas with Ex applications.

The data for power supply are specified in chapter " Technical data".

#### Connection cable

The instrument is connected with standard three-wire cable without shielding. If electromagnetic interference is expected which is above the test values of EN 61326 for industrial areas, shielded cable should be used.

Make sure that the cable used has the required temperature resistance and fire safety for max. occurring ambient temperature

Use cable with round cross section for instruments with housing and cable gland. To ensure the seal effect of the cable gland (IP protection rating), find out which cable outer diameter the cable gland is suitable for.

Use a cable gland fitting the cable diameter.

Cover all housing openings conforming to standard according to EN 60079-1.

#### Cable glands

## Metric threads:

In the case of instrument housings with metric thread, the cable glands are screwed in at the factory. They are sealed with plastic plugs as transport protection.



## Note:

You have to remove these plugs before electrical connection.

#### NPT thread:

In the case of instrument housings with self-sealing NPT threads, it is not possible to have the cable entries screwed in at the factory. The free openings for the cable glands are therefore covered with red dust protection caps as transport protection.



#### Note

Prior to setup you have to replace these protective caps with approved cable glands or close the openings with suitable blind plugs.



On plastic housings, the NPT cable gland or the Conduit steel tube must be screwed into the threaded insert without grease.

Max. torque for all housings, see chapter " Technical data".

## 5.2 Connection procedure

#### Connection technology

The voltage supply and signal output are connected via the springloaded terminals in the housing.

## Connection procedure

Proceed as follows:

- 1. Unscrew the housing lid
- Loosen compression nut of the cable gland and remove blind plug
- 3. Remove approx. 10 cm (4 in) of the cable mantle, strip approx. 1 cm (0.4 in) of insulation from the ends of the individual wires
- 4. Insert the cable into the sensor through the cable entry



Fig. 6: Connection steps 4 and 5

5. Insert the wire ends into the terminals according to the wiring plan

# •

#### Information:

Solid cores as well as flexible cores with wire end sleeves are inserted directly into the terminal openings. In case of flexible cores without end sleeves, press the terminal from above with a small flat head screwdriver, the terminal opening is then free. When the flat head screwdriver is released, the terminal closes again.

- Check the hold of the wires in the terminals by lightly pulling on them
- Connect the shielding to the internal ground terminal, connect the external ground terminal to potential equalisation
- 8. Tighten the compression nut of the cable entry gland. The seal ring must completely encircle the cable
- 9. Screw the housing lid back on

The electrical connection is finished.

#### Information:

The terminal block is pluggable and can be removed from the electronics. To do this, lift the terminal block with a small screwdriver and pull it out. When reinserting the terminal block, you should hear it snap in.



# Wiring plan

# 5.3 Wiring plan, single chamber housing

Connect VEGAMIP 61 as follows.




Fig. 7: Wiring plan emitting unit - VEGAMIP 61 (transmitter)

1 Voltage supply



# 6 Setup

# 6.1 Adjustment elements

You can find the adjustment of VEGAMIP 61 in the operating instructions of the VEGAMIP R61 (receiving unit).



## 7 Maintenance and fault rectification

#### 7.1 Maintenance

#### Maintenance

If the device is used properly, no special maintenance is required in normal operation.

#### Cleaning

The cleaning helps that the type label and markings on the instrument are visible.

Take note of the following:

- Use only cleaning agents which do not corrode the housings, type label and seals
- Use only cleaning methods corresponding to the housing protection rating

# 7.2 Rectify faults

# Reaction when malfunc-

The operator of the system is responsible for taking suitable measures to rectify faults.

#### Fault rectification

You can find information on fault rectification in the operating instructions manual of the receiving unit.

# 7.3 Exchanging the electronics



If the electronics module is defective, it can be replaced by the user. In Ex applications only an electronics module with respective Ex approval may be used.

You can find all the information you need to carry out an electronics exchange in the handbook of the new electronics module.

# 7.4 How to proceed if a repair is necessary

You can find an instrument return form as well as detailed information about the procedure in the download area of our homepage. By doing this you help us carry out the repair quickly and without having to call back for needed information.

Proceed as follows in case of repair:

- Print and fill out one form per instrument
- Clean the instrument and pack it damage-proof
- Attach the completed form and, if need be, also a safety data sheet outside on the packaging
- Ask the agency serving you to get the address for the return shipment. You can find the agency on our homepage.



#### 8 Dismount

# 8.1 Dismounting steps

To remove the device, carry out the steps in chapters " *Mounting*" and " *Connecting to power suplly*" in reverse.



#### Warning:

When dismounting, pay attention to the process conditions in vessels or pipelines. There is a risk of injury, e.g. due to high pressures or temperatures as well as aggressive or toxic media. Avoid this by taking appropriate protective measures.

# 8.2 Disposal



Pass the instrument on to a specialised recycling company and do not use the municipal collecting points.

Remove any batteries in advance, if they can be removed from the device, and dispose of them separately.

If personal data is stored on the old device to be disposed of, delete it before disposal.

If you have no way to dispose of the old instrument properly, please contact us concerning return and disposal.



# 9 Supplement

#### 9.1 Technical data

#### General data

Material 316L corresponds to 1.4404 or 1.4435

Materials, wetted parts

Process fitting - threadProcess fitting - flange316L

Antenna	Instrument seal	Cover or wetted materials	
Threaded version, internal horn antenna	FKM (A+P 70.1606)	PTFE	
with PTFE cover	Process seal: Klingersil C-4400	316L	
Plastic encapsulated antenna with PP cover	-	PP	
Horn antenna (316L)	FKM (SHS FDM 70C3 GLT)	PTFE	
	FFKM (Kalrez 6375)	316L	
	Process seal: Klingersil C-4400		
Encapsulated horn antenna with PTFE cover	-	PTFE	
Mounting adapter "Abrasion protection" (op-	FKM (A+P FPM 70.16-06)	Al <sub>2</sub> O <sub>3</sub> ceramic	
tional)	Process seal: Klingersil C-4400	316L	
-1 +20 bar(-14,5 290 psig)			
+80 °C (+176 °F)			
Mounting adapter "High temperature" (op-	Graphite	Al <sub>2</sub> O <sub>3</sub> ceramic	
tion)	Process seal: Klingersil C-4400	316L	
Unpressurized			
+250 °C (+482 °F)			
Mounting adapter "High temperature" (op-	Graphite	Al <sub>2</sub> O <sub>3</sub> ceramic	
tion)	Process seal, provided by customer	316L	
Unpressurized			
+450 °C (+842 °F)			

Materials, non-wetted parts

Plastic housing
 Plastic PBT (Polyester)

- Aluminium die-cast housing Aluminium die-casting AlSi10Mg, powder-coated (Basis:

Polyester)

- Stainless steel housing (precision

casting)

316L 316l

- Stainless steel housing (electropol-

ished)

Seal between housing and housing lid Silicone

- Inspection window in housing cover Plastic

(optional for relay version)

Plastic housing: Polycarbonate (UL746-C listed)

tional for relay version) Metal housing: Glass 1)

- Ground terminal 316L

<sup>1)</sup> Aluminium, stainless steel precision casting and Ex d housing



Cable gland
 PA, stainless steel, brass

Sealing, cable gland
Blind plug, cable gland
Mounting adapter (option)
316L

Sensor length See chapter " *Dimensions*" Instrument weight (depending on pro- 0.8 ... 4 kg (0.18 ... 8.82 lbs)

cess fitting)
Process fittings

- Pipe thread, cylindrical (ISO 228 T1) G11/2 according to DIN 3852-A

- Pipe thread, conical (ASME B1.20.1) 11/2 NPT

- Flanges DIN from DN 50, ASME from 2"

Mounting adapter
 G2 or 2 NPT

Frequency range K band, 24.085 GHz (ISM band)
Measuring range 0.1 ... 100 m (0.33 ... 328 ft)

Beam angle 2)

- Threaded version, internal horn an-

tenna with PTFE cover

Plastic encapsulated antenna with PP 10°

- Horn antenna (316L), ø 40 mm 22°

(1.575 in)

Horn antenna (316L), ø 48 mm

(1.89 in)

Encapsulated antenna with PTFE cover, Flange DN 50, ASME 2"

Encapsulated antenna with PTFE cover, Flange DN 80 ... DN 150,
 ASME 3" ... 6"

Torque for NPT cable glands and Conduit tubes

Plastic housing max. 10 Nm (7.376 lbf ft)
 Aluminium/Stainless steel housing max. 50 Nm (36.88 lbf ft)

#### **Ambient conditions**

Ambient, storage and transport tempera-  $\,$  -40  $\dots$  +80  $^{\circ}\text{C}$  (-40  $\dots$  +176  $^{\circ}\text{F})$  ture

#### **Process conditions**

Measured variable Limit level of bulk solids and liquids

Process pressure 3)

VEGAMIP 61, threaded version, inter -1 ... 4 bar/-100 ... 400 kPa (-14.5 ... 58 psig) nal horn antenna with PTFE cover

- <sup>2)</sup> Outside the specified beam angle, the energy of the radar signal has a level of -3 dB (50 %).
- <sup>3)</sup> Note max. pressure of the process fitting.



<ul> <li>VEGAMIP 61, plastic encapsulated</li> </ul>
antenna with PP cover

#### Performance data

 $< 3 \, \text{mW}$ Emitted power Max. power density at a distance of 1 m  $< 1 \mu W/cm^2$ 

#### Electromechanical data

Options of the cable entry

M20 x 1.5: ½ NPT - Cable entry

- Cable gland M20 x 1.5; ½ NPT (cable diameter see below table)

M20 x 1.5; ½ NPT Blind plug

1/2 NPT - Closing cap

	Material seal insert	Cable diameter				
ble gland		4.5 8.5 mm	5 9 mm	6 12 mm	7 12 mm	10 14 mm
PA	NBR	-	•	•	-	•



Material ca-	Material seal insert	Cable diameter				
ble gland		4.5 8.5 mm	5 9 mm	6 12 mm	7 12 mm	10 14 mm
Brass, nickel- plated	NBR	•	•	•	-	-
Stainless steel	NBR	-	•	•	-	•

Wire cross-section (spring-loaded terminals)

Massive wire, stranded wire
 Stranded wire with end sleeve
 0.2 ... 2.5 mm² (AWG 24 ... 14)
 0.2 ... 1.5 mm² (AWG 24 ... 16)

#### Voltage supply

Operating voltage 20 ... 253 V AC, 50/60 Hz, 20 ... 72 V DC (at

U >60 V DC, the ambient temperature can be max.

50 °C/122 °F)

Power consumption 2 VA (AC), approx. 0.8 W (DC)

#### **Electrical protective measures**

Protection rating IP66/IP67 (NEMA Type 4X)

Overvoltage category III
Protection class I

# 9.2 Dimensions

## **VEGAMIP 61, housing versions**




Fig. 8: Housing versions

- 1 Plastic single chamber
- 2 Stainless steel single chamber (electropolished)
- 3 Stainless steel single chamber (precision casting)
- 4 Aluminium single chamber



# **VEGAMIP 61, threaded version**




Fig. 9: VEGAMIP 61, internal horn antenna (threaded version)

- 1 Internal horn antenna with PTFE cover, threaded version G11/2
- 2 Internal horn antenna with PTFE cover, threaded version 1½ NPT



## **VEGAMIP 61, encapsulated antennas**




Fig. 10: VEGAMIP 61, encapsulated antennas

- 1 Encapsulated horn antenna with PTFE cover, flange version
- 2 Plastic encapsulated antenna with PP cover
- 3 Mounting strap
- 4 Adapter flange

## **VEGAMIP 61, horn antenna**




Fig. 11: VEGAMIP 61, horn antenna/316L



## VEGAMIP 61, mounting adapter "Abrasion protection" -40 ... +80 °C (-40 ... +176 °F)




Fig. 12: Mounting adapter with ceramic cover (optional) for VEGAMIP 61 with internal horn antenna, threaded version G1½ with PTFE cover (also with 1½ NPT thread)

#### VEGAMIP 61, mounting adapter "High temperature" -40 ... +450 °C (-40 ... +842 °F)




Fig. 13: Mounting adapter with ceramic cover (optional) for VEGAMIP 61 with internal horn antenna, threaded version G1½ with PTFE cover (also with 1½ NPT thread)

- x 150 mm (5.9 in), -40 ... +250 °C (-40 ... +482 °F)
- x 300 mm (11.8 in), -40 ... +450 °C (-40 ... +842 °F)

# VEGAMIP 61, mounting adapter "High temperature with extension" -40 $\dots$ +450 °C (-40 $\dots$ +842 °F)




Fig. 14: Mounting adapter with extension for front-flush mounting, for VEGAMIP 61 with internal horn antenna, threaded version G1½ with PTFE cover (also with 1½ NPT thread)

- x 150 mm (5.9 in), -40 ... +250 °C (-40 ... +482 °F)
- x 300 mm (11.8 in), -40 ... +450 °C (-40 ... +842 °F)
- y Extension length 40, 60, 80, 100 or 150 mm (1.57, 2.36, 3.15, 3.94, 5.91 in)



# 9.3 Industrial property rights

VEGA product lines are global protected by industrial property rights. Further information see www.vega.com.

VEGA Produktfamilien sind weltweit geschützt durch gewerbliche Schutzrechte.

Nähere Informationen unter www.vega.com.

Les lignes de produits VEGA sont globalement protégées par des droits de propriété intellectuelle. Pour plus d'informations, on pourra se référer au site <a href="www.vega.com">www.vega.com</a>.

VEGA lineas de productos están protegidas por los derechos en el campo de la propiedad industrial. Para mayor información revise la pagina web <a href="https://www.vega.com">www.vega.com</a>.

Линии продукции фирмы ВЕГА защищаются по всему миру правами на интеллектуальную собственность. Дальнейшую информацию смотрите на сайте <u>www.vega.com</u>.

VEGA系列产品在全球享有知识产权保护。

进一步信息请参见网站< www.vega.com。

## 9.4 Trademark

All the brands as well as trade and company names used are property of their lawful proprietor/originator.



# **INDEX**

#### Α

Abrasion protection 11 Adjustment 17 Application area 8

## C

Cable 14 Cable screening 14

#### Ε

Electronics module 18 Emitting unit 9, 16

#### F

Fault rectification 18 Functional principle 10

## M

Mounting adapter 11

#### P

Potential equalisation 14

#### R

Receiving unit 9 Repair 18

## S

Shielding 14


#### Т

Type label 8


#### W

Wiring plan 16














# Printing date:



All statements concerning scope of delivery, application, practical use and operating conditions of the sensors and processing systems correspond to the information available at the time of printing.

Subject to change without prior notice

© VEGA Grieshaber KG, Schiltach/Germany 2022

36998-EN-220505